BOILER TUBE FAILURE REPORT (C-2 FORM)												
C2 FORM NO 1000000015 (C-2 FORM SHOULD BE SEND WITHIN 12HOURS OF SYNCHRONISATION)												
1)	STATION:	T007		2) UNIT	NO.	J02		3)	LAST UNIT OUT	AGE 14-12-2023	3	
5)	UNIT SHUT	JNIT SHUTDOWN FROM		13-01-2024		07:13:00		4)	4) LAST Unit O/H 01-10-2021			
6)	WATER FILLING CLEARANCE			14-01-2024		07:15:00		10)			in Million Units	
7)	CLEARANCE FOR LIGHT-UP (AFTER REPAIR OF BTF)			14-01-2024		09:59:00		11)	(ONLY DUE TO BTF) 1) GENERATION CAPACITY 500			
8)	UNIT SYNC	UNIT SYNCHRONIZED AT		14-01-2024		14:15:00		12)	(2) GENERATION LOSS 0 hrs:min			
9)	ORDER NUMBER 1000608			58					(ONLY DUE TO BTF)			
	CAUSE DETAILS					14) OBSERVATION		ERECTION				
15)	BTF INSPE	CTED BY		BTF COMMITTEE HEAD CHEMISTF					tce planning) NO FQA YES OPERATION YES O&E YES			
BOILER TUBE FAILURE LOCATION												
16) 1ST PASS RHS WATERWALL TUBE NO.85 FROM FRONT												
	EQUIPMEN	EQUIPMENT NUMBER T007U02BLR00324 EQUIPMENT DESCRIPTION 1ST PASS RHS WATERWALL										
	LOCATION	LOCATION DETAILS			SWS-BCS	LOCATIC			N DESCRIPTION NTPL UNIT-2 BOILER CIRCULATION SY			
	MATERIAL		s	A210 GR C		TUBE NUM			BER 0085 EQUIPMENT HEIGHT (MTS) 014			
	DESCRIPTION OF BOILER FAILED TUBE (CLEARLY IDENTIFYING TUBE NO, COIL NO, TUBE DIMENSION, TUBE MATERIAL AND X, Y, Z COORDINATES)											
17)	1											
	Tube No. 85 1st pass RHS Waterwall 14 ML, SA210 Gr.C, D51x6mm smooth tube											
PHOTOGRAPHS												
18)	8) FAILURE BEFORE START OF REPAIRED LOCATION AFTER PRIMARY FAILED TUBE REPAIR WORK RESTORATION PRIMARY FAILED TUBE											
	DETAILS OF REPAIR WORK (SPECIFY JOINT DETAILS, COIL NO/ TUBE NO AND RESTORATION WORK)											
19)	Damages to both the tubes were pinholes. Thus, the damage was ground to the root level and metallised. 2 Pin hole joints											
DE	DETAILS OF INSPECTION OF ADJACENT AND IDENTICAL LOCATIONS											
20)	No observable defects in DPT											
STATION OBSERVATION W.R.T CAUSE OF TUBE FAILURE:												
21) Replacement of the tube during overhaul												
HISTORY OF WORK IN FAILED TUBE/COIL/LOCATION IN PAST FIVE YEARS												
	Date		m Numbe						Cause			
08	3-02-2024	1000	00000015 0085 014		014	SA210 GR C						
Sul	Submited by PRADEEP SRIKANTH A Submited on 08-02-2024 Designation DEPUTY CHIEF ENGINEER											

