

GEOTECHNICAL SUMMARY - BAY JUNCTION

Report ref: GEO-2026-118

Trial pits indicate made ground to 0.8 m over firm cohesive material.

Allowable bearing pressure: 120 kPa

NOTE: The 150 kPa figure used in the RFQ technical basis is not supported by these results.