SCHOOL OF ENGINEERING

Form to accompany draft examination papers sent to external examiners

Course Code: EG3539

Diet of Examinations: August 2014

Materials required to be provided in the examination room when the examination is sat (in addition to the question paper and answer booklets): Unit converter, psychometric chart, R-134a refrigeration and ideal-gas properties of air tables.

Are candidates permitted to use approved calculators in the examination? Yes.

Details of materials which candidates are permitted to take into the examination room and use when answering the examination paper (in addition to writing and drawing instruments, and approved calculators where permitted): -

Details of any departures from the agreed syllabus for this course:

Any information which the examiners feel should be communicated to the external examiners:

The examination paper has been prepared and scrutinised following current procedures:

________________ **Course Organiser**

________________ **Scrutineer**

17/03/14 **Date**

UNIVERSITY OF ABERDEEN SESSION 2013–2014

Degree Examination in EG3539 Thermodynamics

0^{th} August 2014 00.00–00.00

Notes: *(i) Candidates ARE permitted to use an approved calculator.*

(ii) Candidates ARE permitted to use ideal-gas properties of air tables, which will be provided.

(iii) Candidates ARE permitted to use refrigerant tables, which will be provided.

(iv) Candidates ARE permitted to use psychrometric chart, which will be provided.

(v) Data sheets are attached to the paper.

PLEASE NOTE THE FOLLOWING

(i) You **must not** have in your possession any material other than that expressly permitted in the rules appropriate to this examination. Where this is permitted, such material **must not** be amended, annotated or modified in any way.

(ii) You **must not** have in your possession any material that could be determined as giving you an advantage in the examination.

(iii) You **must not** attempt to communicate with any candidate during the exam, either orally or by passing written material, or by showing material to another candidate, nor must you attempt to view another candidate's work.

Failure to comply with the above will be regarded as cheating and may lead to disciplinary action as indicated in the Academic Quality Handbook (www.abdn.ac.uk/registry/quality/appendix7x1.pdf) Section 4.14 and 5.

Candidates must attempt *all* questions.

Question 1
In an air-standard Otto cycle, the isentropic compression and expansion strokes are replaced by polytropic processes – PV^γ = constant, with $\gamma = 1.3$,

- **1–2:** Polytropic compression;
- **2–3:** Addition of heat at constant volume;
- **3–4:** Polytropic expansion and;
- **4–1:** Rejection of heat at constant volume.

The compression ratio $\left(\frac{V_1}{V_2} = \frac{V_4}{V_3}\right)$ is 9 for the modified cycle. At the beginning of compression, $P_1 = 1.0$ bar and $T_1 = 300K$. The maximum temperature during the cycle is $2000K$.

1. In Table 1, determine *(a)-(g)*. [7 marks]

	P **(bar)**	T **(K)**	$\mathbf{V}(m^3/kg)$	U (kJ/kg)
1	1	300	(a)	(b)
2	–	(c)	–	(d)
3	–	2000	–	(e)
4	–	(f)	–	(g)

Table 1: *Thermodynamic table of the modified air-standard Otto cycle.*

2. Calculate the mass-based heat (Q/m) and work (W/m) (both in kJ/kg) for each stroke in the cycle; [8 marks]
3. Calculate the thermal efficiency; [3 marks]

$$\eta = \frac{(W_{\text{cycle}}/m)}{(Q_{\text{in}}/m)}$$

4. Calculate the mean effective pressure (in bar). [2 marks]

$$\text{MEP} = \frac{(W_{\text{cycle}}/m)}{V_1 - V_2}$$

Also given:

- Isentropic relations for ideal gas:

$$TV^{\gamma-1} = \text{constant}$$
$$TP^{\frac{1-\gamma}{\gamma}} = \text{constant}$$
$$PV^\gamma = \text{constant}$$

- Molecular weight of air: $MW = 28.97 \dfrac{kg}{kgmol}$;
- Polytropic relation for an ideal gas from state i to j:

$$\frac{W_{ij}}{m} = \int_i^j PdV = \frac{R\left(T_j - T_i\right)}{1-\gamma}$$

Question 2

A vapour-compression refrigeration cycle is operated with Refrigerant R-134a as working fluid. Saturated vapour enters the compressor (with isentropic efficiency of 80%) at 2 bar, and saturated liquid exits the condenser at 8 bar. The mass flow rate of R-134a is 7 kg/min.

1. Sketch the schematic of the cycle indicating the numbering used in the calculation; [2 marks]
2. Calculate all enthalpies in the cycle ($H_k \; \forall k \in \{1,2,3,4\}$); [8 marks]
3. Calculate the compressor power (W_{C}) in kW; [2 marks]
4. Determine the refrigeration capacity (R_{n}) in *tons*; [2 marks]
5. Calculate the coefficient of performance of the cycle (COP $= R_{\mathrm{n}}/W_{\mathrm{C}}$); [2 marks]
6. Sketch the TS diagram, indicating all stages of the cycle. [4 marks]

The efficiency of the compressor can be expressed as,

$$\eta_C = \frac{H_{ks} - H_{k-1}}{H_k - H_{k-1}}$$

where H_{ks} is the ideal enthalpy of the flow at stage k.

Question 3

1. Saturated refrigerant R-134a vapour at $P_1 = 400\ kPa$ is compressed by a piston to $P_2 = 16$ bar in a reversible adiabatic process. Critical pressure and temperature of R-134a are 4.059 MPa and 101.06°C.

   (a) Calculate the work done by the piston; [6 marks]

   (b) Sketch the TS and PV diagrams including the constant pressure and temperature lines. [4 marks]

2. A reciprocating engines was designed to operate with the following stages:

   - 1–2: Isentropic compression;
   - 2–3: Addition of heat at constant volume;
   - 3–4: Addition of heat at constant pressure;
   - 4–5: Isentropic expansion and;
   - 5–1: Rejection of heat at constant volume.

   (a) Sketch the TS and PV diagrams for this cycle; [4 marks]

   (b) For this cycle, define an expression for the net work (W_{net}) as a function of mass of air (m), heat capacities (C_p and C_v) and temperatures (T_j), [6 marks]

$$W_{\text{net}} = W_{\text{net}}\left(m, C_p, C_v, T_j\right) = \text{Heat Supplied} - \text{Heat Rejected}$$

Question 4

(a) Energy conservation in a steady flow device implies

$$\dot{Q} - \dot{W}_s = \dot{m}\left(h_2 + \frac{u_2^2}{2} + gz_2\right) - \dot{m}\left(h_1 + \frac{u_1^2}{2} + gz_1\right),$$

where $\dot{Q}$ is the rate of heat addition, $\dot{W}_s$ is the rate of shaft work done by the fluid, h is the specific enthalpy and u is the fluid velocity. Briefly explain the physical significance of the fluxes making up the right-hand side of this equation. [3 marks]

(b) An ideal gas flows through a steady flow device at a rate of 3 kg/s, and does work on a set of compressor blades at a rate of 28 kW. The gas has a temperature of 60°C when it enters the device through a circular inlet of diameter 50 cm (where the flow properties are denoted by a subscript 1) and exits the device at 50°C through a circular outlet of diameter 20 cm (where the flow properties are denoted 2). The inlet and outlet are at the same vertical height, while the pressure at the inlet is 100 kPa. Assuming no heat is added or removed from the device, then determine:

i) The inlet and outlet velocities; [9 marks]

ii) The pressure at the outlet. [2 marks]

You may assume the specific heat capacity of the gas $c_p = 1000\,\mathrm{J/(kg\ K)}$ and the specific gas constant $R = 300\,\mathrm{J/(kg\ K)}$.

(c) Downstream of the compressor, the gas flows isentropically into a difuser. Explain what is meant by an isentropic flow. [2 marks]

(d) Isentropic flow along a diffuser satisfies the equation

$$\frac{1}{1-\mathrm{Ma}^2}\frac{1}{A}\frac{\mathrm{d}A}{\mathrm{d}x} = \frac{1}{\rho u^2}\frac{\mathrm{d}p}{\mathrm{d}x} = -\frac{1}{u}\frac{\mathrm{d}u}{\mathrm{d}x}.$$

With reference to this equation, explain how the pressure p, and flow velocity u vary if gas flows subsonically along the diffuser. [4 marks]

Question 5

(a) Air in an air-conditioning system is mixed adiabatically with air from outside in a steady process. If the inlets to the mixing chamber are labelled 1 and 2, and the outlet is labelled 3, then state equations corresponding to the mass conservation of dry air, the mass conservation of water vapour and the conservation of energy. Hence show that

$$\frac{\dot{m}_{a_2}}{\dot{m}_{a_1}} = \frac{h_3 - h_1}{h_2 - h_3} = \frac{\omega_3 - \omega_1}{\omega_2 - \omega_3}$$

where $\dot{m}$ is a mass flux, h is a specific enthalpy and ω is a specific humidity. [8 marks]

(b) Inlet 1 brings $25\,\mathrm{m}^3/\mathrm{min}$ of saturated air from the cooling section of the air conditioning system at a temperature of 7°C. Inlet 2 brings $40\,\mathrm{m}^3/\mathrm{min}$ of air from outside with a specific humidity of 0.01 kg water/kg dry air and a temperature of 39°C. Assuming the mixing is adiabatic and occurs at 1 atm, then determine:

i) The outlet mass flux of dry air; [4 marks]

ii) The specifc humidity of the mixture; [5 marks]

iii) The relative humidity and the dry-bulb temperature. [3 marks]

END OF PAPER


Psychrometric Chart
SI (metric) units
Barometric Pressure 101.325 kPa (Sea level)
based on data from
Carrier Corporation Cat. No. 794-001, dated 1975
Humidity Ratio (gm Water / gm of Dry Air)
0.000
0.005
0.010
0.015
0.020
0.025
0.030
Dry Bulb Temperature (°C)
-10
-5
0
5
10
15
20
25
30
35
40
45
50
55
Enthalpy at Saturation (J / g Dry Air)
0
20
40
60
80
100
120
140
Wet Bulb or Saturation Temperature (°C)
-5
0
5
10
15
20
25
30
35
Specific Volume 0.90 (m 3 / kg Dry Air)
0.75
0.80
0.85
0.95
Relative Humidity
0%
10%
20%
30%
40%
50%
60%
70%
80%
90%
100%

TABLE V

Conversion Factors

Force

1 newton	=	1 kg-m/sec^2
	=	0.012 kgf
1 kgf	=	9.81 N

Pressure

1 bar	=	750.06 mm Hg
	=	0.9869 atm
	=	10^5 N/m^2
	=	10^3 kg/m-sec^2
1 N/m^2	=	1 pascal
	=	10^{-5} bar
	=	10^{-2} kg/m-sec^2
1 atm	=	760 mm Hg
	=	1.03 kgf/cm^2 = 1.01325 bar
	=	1.01325×10^5 N/m^2

Work, Energy or Heat

1 joule	=	1 newton metre
	=	1 watt-sec
	=	2.7778×10^{-7} kWh
	=	0.239 cal
	=	0.239×10^{-3} kcal
1 cal	=	4.184 joule
	=	1.1622×10^{-6} kWh
1 kcal	=	4.184×10^3 joule
	=	427 kgfm
	=	1.1622×10^{-3} kWh
1 kWh	=	8.6×10^5 cal
	=	860 kcal
	=	3.6×10^6 joule
1 kgfm	=	$\left(\frac{1}{427}\right)$ kcal = 9.81 joules

Power

1 watt	=	1 joule/sec = 0.86 kcal/h
1 h.p.	=	75 mkgf/sec = 0.1757 kcal/sec
	=	735.3 watt
1 kW	=	1000 watts
	=	860 kcal/h

Specific heat

1 kcal/kg - °K	=	4.18 kJ/kg-K

Thermal conductivity

1 watt/m-K	=	0.8598 kcal/h-m-°C
1 kcal/h-m-°C	=	1.16123 watt/m-K
	=	1.16123 joules/s-m-K

Heat transfer co-efficient

1 watt/m^2-K	=	0.86 kcal/m^2-h-°C
1 kcal/m^2-h-°C	=	1.163 watt/m^2-K

IMPORTANT ENGINEERING CONSTANTS AND EXPRESSIONS IN SI UNITS

	Engineering constants and expressions	*M.K.S. system*	*S.I. units*
1.	Value of g_0	9.81 kg-m/kgf-sec^2	1 kg-m/N-sec^2
2.	Universal gas constant	848 kgf-m/kg mole-°K	848 × 9.81 = 8314 J/kg-mole-°K ($\because$ 1 kgf-m = 9.81 joules)
3.	Gas constant (R)	29.27 kgf m/kg-°K for air	$\frac{8314}{29}$ = 287 joules/kg-K for air
4.	Specific heats (for air)	c_v = 0.17 kcal/kg-°K c_p = 0.24 kcal/kg-°K	c_v = 0.17 × 4.184 = 0.71128 kJ/kg-K c_p = 0.24 × 4.184 = 1 kJ/kg-K
5.	Flow through nozzle-exit velocity (C_2)	91.5 $\sqrt{U}$ where U is in kcal	44.7 $\sqrt{U}$ where U is in kJ
6.	Refrigeration 1 ton	= 50 kcal/min	= 210 kJ/min
7.	**Heat transfer** The Stefan Boltzman Law is given by :	Q = σT^4 kcal/m^2-h when $\sigma = 4.9 \times 10^{-8}$ kcal/h-m^2-°K^4	Q = σT^4 watts/m^2-h when $\sigma = 5.67 \times 10^{-8}$ W/m^2K^4

TABLE A–17

Ideal-gas properties of air

T K	h kJ/kg	P_r	u kJ/kg	v_r	s° kJ/kg · K
200	199.97	0.3363	142.56	1707.0	1.29559
210	209.97	0.3987	149.69	1512.0	1.34444
220	219.97	0.4690	156.82	1346.0	1.39105
230	230.02	0.5477	164.00	1205.0	1.43557
240	240.02	0.6355	171.13	1084.0	1.47824
250	250.05	0.7329	178.28	979.0	1.51917
260	260.09	0.8405	185.45	887.8	1.55848
270	270.11	0.9590	192.60	808.0	1.59634
280	280.13	1.0889	199.75	738.0	1.63279
285	285.14	1.1584	203.33	706.1	1.65055
290	290.16	1.2311	206.91	676.1	1.66802
295	295.17	1.3068	210.49	647.9	1.68515
298	298.18	1.3543	212.64	631.9	1.69528
300	300.19	1.3860	214.07	621.2	1.70203
305	305.22	1.4686	217.67	596.0	1.71865
310	310.24	1.5546	221.25	572.3	1.73498
315	315.27	1.6442	224.85	549.8	1.75106
320	320.29	1.7375	228.42	528.6	1.76690
325	325.31	1.8345	232.02	508.4	1.78249
330	330.34	1.9352	235.61	489.4	1.79783
340	340.42	2.149	242.82	454.1	1.82790
350	350.49	2.379	250.02	422.2	1.85708
360	360.58	2.626	257.24	393.4	1.88543
370	370.67	2.892	264.46	367.2	1.91313
380	380.77	3.176	271.69	343.4	1.94001
390	390.88	3.481	278.93	321.5	1.96633
400	400.98	3.806	286.16	301.6	1.99194
410	411.12	4.153	293.43	283.3	2.01699
420	421.26	4.522	300.69	266.6	2.04142
430	431.43	4.915	307.99	251.1	2.06533
440	441.61	5.332	315.30	236.8	2.08870
450	451.80	5.775	322.62	223.6	2.11161
460	462.02	6.245	329.97	211.4	2.13407
470	472.24	6.742	337.32	200.1	2.15604
480	482.49	7.268	344.70	189.5	2.17760
490	492.74	7.824	352.08	179.7	2.19876
500	503.02	8.411	359.49	170.6	2.21952
510	513.32	9.031	366.92	162.1	2.23993
520	523.63	9.684	374.36	154.1	2.25997
530	533.98	10.37	381.84	146.7	2.27967
540	544.35	11.10	389.34	139.7	2.29906
550	555.74	11.86	396.86	133.1	2.31809
560	565.17	12.66	404.42	127.0	2.33685
570	575.59	13.50	411.97	121.2	2.35531
580	586.04	14.38	419.55	115.7	2.37348
590	596.52	15.31	427.15	110.6	2.39140
600	607.02	16.28	434.78	105.8	2.40902
610	617.53	17.30	442.42	101.2	2.42644
620	628.07	18.36	450.09	96.92	2.44356
630	638.63	19.84	457.78	92.84	2.46048
640	649.22	20.64	465.50	88.99	2.47716
650	659.84	21.86	473.25	85.34	2.49364
660	670.47	23.13	481.01	81.89	2.50985
670	681.14	24.46	488.81	78.61	2.52589
680	691.82	25.85	496.62	75.50	2.54175
690	702.52	27.29	504.45	72.56	2.55731
700	713.27	28.80	512.33	69.76	2.57277
710	724.04	30.38	520.23	67.07	2.58810
720	734.82	32.02	528.14	64.53	2.60319
730	745.62	33.72	536.07	62.13	2.61803
740	756.44	35.50	544.02	59.82	2.63280
750	767.29	37.35	551.99	57.63	2.64737
760	778.18	39.27	560.01	55.54	2.66176
780	800.03	43.35	576.12	51.64	2.69013
800	821.95	47.75	592.30	48.08	2.71787
820	843.98	52.59	608.59	44.84	2.74504
840	866.08	57.60	624.95	41.85	2.77170
860	888.27	63.09	641.40	39.12	2.79783
880	910.56	68.98	657.95	36.61	2.82344
900	932.93	75.29	674.58	34.31	2.84856
920	955.38	82.05	691.28	32.18	2.87324
940	977.92	89.28	708.08	30.22	2.89748
960	1000.55	97.00	725.02	28.40	2.92128
980	1023.25	105.2	741.98	26.73	2.94468
1000	1046.04	114.0	758.94	25.17	2.96770
1020	1068.89	123.4	776.10	23.72	2.99034
1040	1091.85	133.3	793.36	23.29	3.01260
1060	1114.86	143.9	810.62	21.14	3.03449
1080	1137.89	155.2	827.88	19.98	3.05608
1100	1161.07	167.1	845.33	18.896	3.07732
1120	1184.28	179.7	862.79	17.886	3.09825
1140	1207.57	193.1	880.35	16.946	3.11883
1160	1230.92	207.2	897.91	16.064	3.13916
1180	1254.34	222.2	915.57	15.241	3.15916
1200	1277.79	238.0	933.33	14.470	3.17888
1220	1301.31	254.7	951.09	13.747	3.19834
1240	1324.93	272.3	968.95	13.069	3.21751

TABLE A–17

Ideal-gas properties of air (*Concluded*)

T K	h kJ/kg	P_r	u kJ/kg	v_r	$s°$ kJ/kg · K	T K	h kJ/kg	P_r	u kJ/kg	v_r	$s°$ kJ/kg · K
1260	1348.55	290.8	986.90	12.435	3.23638	1600	1757.57	791.2	1298.30	5.804	3.52364
1280	1372.24	310.4	1004.76	11.835	3.25510	1620	1782.00	834.1	1316.96	5.574	3.53879
1300	1395.97	330.9	1022.82	11.275	3.27345	1640	1806.46	878.9	1335.72	5.355	3.55381
1320	1419.76	352.5	1040.88	10.747	3.29160	1660	1830.96	925.6	1354.48	5.147	3.56867
1340	1443.60	375.3	1058.94	10.247	3.30959	1680	1855.50	974.2	1373.24	4.949	3.58335
1360	1467.49	399.1	1077.10	9.780	3.32724	1700	1880.1	1025	1392.7	4.761	3.5979
1380	1491.44	424.2	1095.26	9.337	3.34474	1750	1941.6	1161	1439.8	4.328	3.6336
1400	1515.42	450.5	1113.52	8.919	3.36200	1800	2003.3	1310	1487.2	3.994	3.6684
1420	1539.44	478.0	1131.77	8.526	3.37901	1850	2065.3	1475	1534.9	3.601	3.7023
1440	1563.51	506.9	1150.13	8.153	3.39586	1900	2127.4	1655	1582.6	3.295	3.7354
1460	1587.63	537.1	1168.49	7.801	3.41247	1950	2189.7	1852	1630.6	3.022	3.7677
1480	1611.79	568.8	1186.95	7.468	3.42892	2000	2252.1	2068	1678.7	2.776	3.7994
1500	1635.97	601.9	1205.41	7.152	3.44516	2050	2314.6	2303	1726.8	2.555	3.8303
1520	1660.23	636.5	1223.87	6.854	3.46120	2100	2377.7	2559	1775.3	2.356	3.8605
1540	1684.51	672.8	1242.43	6.569	3.47712	2150	2440.3	2837	1823.8	2.175	3.8901
1560	1708.82	710.5	1260.99	6.301	3.49276	2200	2503.2	3138	1872.4	2.012	3.9191
1580	1733.17	750.0	1279.65	6.046	3.50829	2250	2566.4	3464	1921.3	1.864	3.9474

Note: The properties P_r (relative pressure) and v_r (relative specific volume) are dimensionless quantities used in the analysis of isentropic processes, and should not be confused with the properties pressure and specific volume.

Source: Kenneth Wark, *Thermodynamics,* 4th ed. (New York: McGraw-Hill, 1983), pp. 785–86, table A–5. Originally published in J. H. Keenan and J. Kaye, *Gas Tables* (New York: John Wiley & Sons, 1948).

TABLE A-10 Properties of Saturated Refrigerant 134a (Liquid–Vapor): Temperature Table

		Specific Volume m^3/kg		Internal Energy kJ/kg		Enthalpy kJ/kg			Entropy $kJ/kg \cdot K$		
Temp. °C	Press. bar	Sat. Liquid $v_f \times 10^3$	Sat. Vapor v_g	Sat. Liquid u_f	Sat. Vapor u_g	Sat. Liquid h_f	Evap. h_{fg}	Sat. Vapor h_g	Sat. Liquid s_f	Sat. Vapor s_g	Temp. °C
−40	0.5164	0.7055	0.3569	−0.04	204.45	0.00	222.88	222.88	0.0000	0.9560	−40
−36	0.6332	0.7113	0.2947	4.68	206.73	4.73	220.67	225.40	0.0201	0.9506	−36
−32	0.7704	0.7172	0.2451	9.47	209.01	9.52	218.37	227.90	0.0401	0.9456	−32
−28	0.9305	0.7233	0.2052	14.31	211.29	14.37	216.01	230.38	0.0600	0.9411	−28
−26	1.0199	0.7265	0.1882	16.75	212.43	16.82	214.80	231.62	0.0699	0.9390	−26
−24	1.1160	0.7296	0.1728	19.21	213.57	19.29	213.57	232.85	0.0798	0.9370	−24
−22	1.2192	0.7328	0.1590	21.68	214.70	21.77	212.32	234.08	0.0897	0.9351	−22
−20	1.3299	0.7361	0.1464	24.17	215.84	24.26	211.05	235.31	0.0996	0.9332	−20
−18	1.4483	0.7395	0.1350	26.67	216.97	26.77	209.76	236.53	0.1094	0.9315	−18
−16	1.5748	0.7428	0.1247	29.18	218.10	29.30	208.45	237.74	0.1192	0.9298	−16
−12	1.8540	0.7498	0.1068	34.25	220.36	34.39	205.77	240.15	0.1388	0.9267	−12
−8	2.1704	0.7569	0.0919	39.38	222.60	39.54	203.00	242.54	0.1583	0.9239	−8
−4	2.5274	0.7644	0.0794	44.56	224.84	44.75	200.15	244.90	0.1777	0.9213	−4
0	2.9282	0.7721	0.0689	49.79	227.06	50.02	197.21	247.23	0.1970	0.9190	0
4	3.3765	0.7801	0.0600	55.08	229.27	55.35	194.19	249.53	0.2162	0.9169	4
8	3.8756	0.7884	0.0525	60.43	231.46	60.73	191.07	251.80	0.2354	0.9150	8
12	4.4294	0.7971	0.0460	65.83	233.63	66.18	187.85	254.03	0.2545	0.9132	12
16	5.0416	0.8062	0.0405	71.29	235.78	71.69	184.52	256.22	0.2735	0.9116	16
20	5.7160	0.8157	0.0358	76.80	237.91	77.26	181.09	258.36	0.2924	0.9102	20
24	6.4566	0.8257	0.0317	82.37	240.01	82.90	177.55	260.45	0.3113	0.9089	24
26	6.8530	0.8309	0.0298	85.18	241.05	85.75	175.73	261.48	0.3208	0.9082	26
28	7.2675	0.8362	0.0281	88.00	242.08	88.61	173.89	262.50	0.3302	0.9076	28
30	7.7006	0.8417	0.0265	90.84	243.10	91.49	172.00	263.50	0.3396	0.9070	30
32	8.1528	0.8473	0.0250	93.70	244.12	94.39	170.09	264.48	0.3490	0.9064	32
34	8.6247	0.8530	0.0236	96.58	245.12	97.31	168.14	265.45	0.3584	0.9058	34
36	9.1168	0.8590	0.0223	99.47	246.11	100.25	166.15	266.40	0.3678	0.9053	36
38	9.6298	0.8651	0.0210	102.38	247.09	103.21	164.12	267.33	0.3772	0.9047	38
40	10.164	0.8714	0.0199	105.30	248.06	106.19	162.05	268.24	0.3866	0.9041	40
42	10.720	0.8780	0.0188	108.25	249.02	109.19	159.94	269.14	0.3960	0.9035	42
44	11.299	0.8847	0.0177	111.22	249.96	112.22	157.79	270.01	0.4054	0.9030	44
48	12.526	0.8989	0.0159	117.22	251.79	118.35	153.33	271.68	0.4243	0.9017	48
52	13.851	0.9142	0.0142	123.31	253.55	124.58	148.66	273.24	0.4432	0.9004	52
56	15.278	0.9308	0.0127	129.51	255.23	130.93	143.75	274.68	0.4622	0.8990	56
60	16.813	0.9488	0.0114	135.82	256.81	137.42	138.57	275.99	0.4814	0.8973	60
70	21.162	1.0027	0.0086	152.22	260.15	154.34	124.08	278.43	0.5302	0.8918	70
80	26.324	1.0766	0.0064	169.88	262.14	172.71	106.41	279.12	0.5814	0.8827	80
90	32.435	1.1949	0.0046	189.82	261.34	193.69	82.63	276.32	0.6380	0.8655	90
100	39.742	1.5443	0.0027	218.60	248.49	224.74	34.40	259.13	0.7196	0.8117	100

Source: Tables A-10 through A-12 are calculated based on equations from D. P. Wilson and R. S. Basu, "Thermodynamic Properties of a New Stratospherically Safe Working Fluid—Refrigerant 134a," *ASHRAE Trans.*, Vol. 94, Pt. 2, 1988, pp. 2095–2118.

TABLE A-11 Properties of Saturated Refrigerant 134a (Liquid–Vapor): Pressure Table

		Specific Volume m^3/kg		Internal Energy kJ/kg		Enthalpy kJ/kg			Entropy $kJ/kg \cdot K$		
Press. bar	Temp. °C	Sat. Liquid $v_f \times 10^3$	Sat. Vapor v_g	Sat. Liquid u_f	Sat. Vapor u_g	Sat. Liquid h_f	Evap. h_{fg}	Sat. Vapor h_g	Sat. Liquid s_f	Sat. Vapor s_g	Press. bar
0.6	−37.07	0.7097	0.3100	3.41	206.12	3.46	221.27	224.72	0.0147	0.9520	0.6
0.8	−31.21	0.7184	0.2366	10.41	209.46	10.47	217.92	228.39	0.0440	0.9447	0.8
1.0	−26.43	0.7258	0.1917	16.22	212.18	16.29	215.06	231.35	0.0678	0.9395	1.0
1.2	−22.36	0.7323	0.1614	21.23	214.50	21.32	212.54	233.86	0.0879	0.9354	1.2
1.4	−18.80	0.7381	0.1395	25.66	216.52	25.77	210.27	236.04	0.1055	0.9322	1.4
1.6	−15.62	0.7435	0.1229	29.66	218.32	29.78	208.19	237.97	0.1211	0.9295	1.6
1.8	−12.73	0.7485	0.1098	33.31	219.94	33.45	206.26	239.71	0.1352	0.9273	1.8
2.0	−10.09	0.7532	0.0993	36.69	221.43	36.84	204.46	241.30	0.1481	0.9253	2.0
2.4	−5.37	0.7618	0.0834	42.77	224.07	42.95	201.14	244.09	0.1710	0.9222	2.4
2.8	−1.23	0.7697	0.0719	48.18	226.38	48.39	198.13	246.52	0.1911	0.9197	2.8
3.2	2.48	0.7770	0.0632	53.06	228.43	53.31	195.35	248.66	0.2089	0.9177	3.2
3.6	5.84	0.7839	0.0564	57.54	230.28	57.82	192.76	250.58	0.2251	0.9160	3.6
4.0	8.93	0.7904	0.0509	61.69	231.97	62.00	190.32	252.32	0.2399	0.9145	4.0
5.0	15.74	0.8056	0.0409	70.93	235.64	71.33	184.74	256.07	0.2723	0.9117	5.0
6.0	21.58	0.8196	0.0341	78.99	238.74	79.48	179.71	259.19	0.2999	0.9097	6.0
7.0	26.72	0.8328	0.0292	86.19	241.42	86.78	175.07	261.85	0.3242	0.9080	7.0
8.0	31.33	0.8454	0.0255	92.75	243.78	93.42	170.73	264.15	0.3459	0.9066	8.0
9.0	35.53	0.8576	0.0226	98.79	245.88	99.56	166.62	266.18	0.3656	0.9054	9.0
10.0	39.39	0.8695	0.0202	104.42	247.77	105.29	162.68	267.97	0.3838	0.9043	10.0
12.0	46.32	0.8928	0.0166	114.69	251.03	115.76	155.23	270.99	0.4164	0.9023	12.0
14.0	52.43	0.9159	0.0140	123.98	253.74	125.26	148.14	273.40	0.4453	0.9003	14.0
16.0	57.92	0.9392	0.0121	132.52	256.00	134.02	141.31	275.33	0.4714	0.8982	16.0
18.0	62.91	0.9631	0.0105	140.49	257.88	142.22	134.60	276.83	0.4954	0.8959	18.0
20.0	67.49	0.9878	0.0093	148.02	259.41	149.99	127.95	277.94	0.5178	0.8934	20.0
25.0	77.59	1.0562	0.0069	165.48	261.84	168.12	111.06	279.17	0.5687	0.8854	25.0
30.0	86.22	1.1416	0.0053	181.88	262.16	185.30	92.71	278.01	0.6156	0.8735	30.0

TABLE A-12 Properties of Superheated Refrigerant 134a Vapor

T °C	v m^3/kg	u kJ/kg	h kJ/kg	s kJ/kg · K	v m^3/kg	u kJ/kg	h kJ/kg	s kJ/kg · K
	p = 0.6 bar = 0.06 MPa (T_{sat} = −37.07°C)				p = 1.0 bar = 0.10 MPa (T_{sat} = −26.43°C)			
Sat.	0.31003	206.12	224.72	0.9520	0.19170	212.18	231.35	0.9395
−20	0.33536	217.86	237.98	1.0062	0.19770	216.77	236.54	0.9602
−10	0.34992	224.97	245.96	1.0371	0.20686	224.01	244.70	0.9918
0	0.36433	232.24	254.10	1.0675	0.21587	231.41	252.99	1.0227
10	0.37861	239.69	262.41	1.0973	0.22473	238.96	261.43	1.0531
20	0.39279	247.32	270.89	1.1267	0.23349	246.67	270.02	1.0829
30	0.40688	255.12	279.53	1.1557	0.24216	254.54	278.76	1.1122
40	0.42091	263.10	288.35	1.1844	0.25076	262.58	287.66	1.1411
50	0.43487	271.25	297.34	1.2126	0.25930	270.79	296.72	1.1696
60	0.44879	279.58	306.51	1.2405	0.26779	279.16	305.94	1.1977
70	0.46266	288.08	315.84	1.2681	0.27623	287.70	315.32	1.2254
80	0.47650	296.75	325.34	1.2954	0.28464	296.40	324.87	1.2528
90	0.49031	305.58	335.00	1.3224	0.29302	305.27	334.57	1.2799
	p = 1.4 bar = 0.14 MPa (T_{sat} = −18.80°C)				p = 1.8 bar = 0.18 MPa (T_{sat} = −12.73°C)			
Sat.	0.13945	216.52	236.04	0.9322	0.10983	219.94	239.71	0.9273
−10	0.14549	223.03	243.40	0.9606	0.11135	222.02	242.06	0.9362
0	0.15219	230.55	251.86	0.9922	0.11678	229.67	250.69	0.9684
10	0.15875	238.21	260.43	1.0230	0.12207	237.44	259.41	0.9998
20	0.16520	246.01	269.13	1.0532	0.12723	245.33	268.23	1.0304
30	0.17155	253.96	277.97	1.0828	0.13230	253.36	277.17	1.0604
40	0.17783	262.06	286.96	1.1120	0.13730	261.53	286.24	1.0898
50	0.18404	270.32	296.09	1.1407	0.14222	269.85	295.45	1.1187
60	0.19020	278.74	305.37	1.1690	0.14710	278.31	304.79	1.1472
70	0.19633	287.32	314.80	1.1969	0.15193	286.93	314.28	1.1753
80	0.20241	296.06	324.39	1.2244	0.15672	295.71	323.92	1.2030
90	0.20846	304.95	334.14	1.2516	0.16148	304.63	333.70	1.2303
100	0.21449	314.01	344.04	1.2785	0.16622	313.72	343.63	1.2573
	p = 2.0 bar = 0.20 MPa (T_{sat} = −10.09°C)				p = 2.4 bar = 0.24 MPa (T_{sat} = −5.37°C)			
Sat.	0.09933	221.43	241.30	0.9253	0.08343	224.07	244.09	0.9222
−10	0.09938	221.50	241.38	0.9256				
0	0.10438	229.23	250.10	0.9582	0.08574	228.31	248.89	0.9399
10	0.10922	237.05	258.89	0.9898	0.08993	236.26	257.84	0.9721
20	0.11394	244.99	267.78	1.0206	0.09399	244.30	266.85	1.0034
30	0.11856	253.06	276.77	1.0508	0.09794	252.45	275.95	1.0339
40	0.12311	261.26	285.88	1.0804	0.10181	260.72	285.16	1.0637
50	0.12758	269.61	295.12	1.1094	0.10562	269.12	294.47	1.0930
60	0.13201	278.10	304.50	1.1380	0.10937	277.67	303.91	1.1218
70	0.13639	286.74	314.02	1.1661	0.11307	286.35	313.49	1.1501
80	0.14073	295.53	323.68	1.1939	0.11674	295.18	323.19	1.1780
90	0.14504	304.47	333.48	1.2212	0.12037	304.15	333.04	1.2055
100	0.14932	313.57	343.43	1.2326	0.12398	313.27	343.03	1.2326

TABLE A-12 *(Continued)*

T °C	v m³/kg	u kJ/kg	h kJ/kg	s kJ/kg · K	v m³/kg	u kJ/kg	h kJ/kg	s kJ/kg · K
	p = 2.8 bar = 0.28 MPa (T_{sat} = −1.23°C)				p = 3.2 bar = 0.32 MPa (T_{sat} = 2.48°C)			
Sat.	0.07193	226.38	246.52	0.9197	0.06322	228.43	248.66	0.9177
0	0.07240	227.37	247.64	0.9238				
10	0.07613	235.44	256.76	0.9566	0.06576	234.61	255.65	0.9427
20	0.07972	243.59	265.91	0.9883	0.06901	242.87	264.95	0.9749
30	0.08320	251.83	275.12	1.0192	0.07214	251.19	274.28	1.0062
40	0.08660	260.17	284.42	1.0494	0.07518	259.61	283.67	1.0367
50	0.08992	268.64	293.81	1.0789	0.07815	268.14	293.15	1.0665
60	0.09319	277.23	303.32	1.1079	0.08106	276.79	302.72	1.0957
70	0.09641	285.96	312.95	1.1364	0.08392	285.56	312.41	1.1243
80	0.09960	294.82	322.71	1.1644	0.08674	294.46	322.22	1.1525
90	0.10275	303.83	332.60	1.1920	0.08953	303.50	332.15	1.1802
100	0.10587	312.98	342.62	1.2193	0.09229	312.68	342.21	1.2076
110	0.10897	322.27	352.78	1.2461	0.09503	322.00	352.40	1.2345
120	0.11205	331.71	363.08	1.2727	0.09774	331.45	362.73	1.2611
	p = 4.0 bar = 0.40 MPa (T_{sat} = 8.93°C)				p = 5.0 bar = 0.50 MPa (T_{sat} = 15.74°C)			
Sat.	0.05089	231.97	252.32	0.9145	0.04086	235.64	256.07	0.9117
10	0.05119	232.87	253.35	0.9182				
20	0.05397	241.37	262.96	0.9515	0.04188	239.40	260.34	0.9264
30	0.05662	249.89	272.54	0.9837	0.04416	248.20	270.28	0.9597
40	0.05917	258.47	282.14	1.0148	0.04633	256.99	280.16	0.9918
50	0.06164	267.13	291.79	1.0452	0.04842	265.83	290.04	1.0229
60	0.06405	275.89	301.51	1.0748	0.05043	274.73	299.95	1.0531
70	0.06641	284.75	311.32	1.1038	0.05240	283.72	309.92	1.0825
80	0.06873	293.73	321.23	1.1322	0.05432	292.80	319.96	1.1114
90	0.07102	302.84	331.25	1.1602	0.05620	302.00	330.10	1.1397
100	0.07327	312.07	341.38	1.1878	0.05805	311.31	340.33	1.1675
110	0.07550	321.44	351.64	1.2149	0.05988	320.74	350.68	1.1949
120	0.07771	330.94	362.03	1.2417	0.06168	330.30	361.14	1.2218
130	0.07991	340.58	372.54	1.2681	0.06347	339.98	371.72	1.2484
140	0.08208	350.35	383.18	1.2941	0.06524	349.79	382.42	1.2746
	p = 6.0 bar = 0.60 MPa (T_{sat} = 21.58°C)				p = 7.0 bar = 0.70 MPa (T_{sat} = 26.72°C)			
Sat.	0.03408	238.74	259.19	0.9097	0.02918	241.42	261.85	0.9080
30	0.03581	246.41	267.89	0.9388	0.02979	244.51	265.37	0.9197
40	0.03774	255.45	278.09	0.9719	0.03157	253.83	275.93	0.9539
50	0.03958	264.48	288.23	1.0037	0.03324	263.08	286.35	0.9867
60	0.04134	273.54	298.35	1.0346	0.03482	272.31	296.69	1.0182
70	0.04304	282.66	308.48	1.0645	0.03634	281.57	307.01	1.0487
80	0.04469	291.86	318.67	1.0938	0.03781	290.88	317.35	1.0784
90	0.04631	301.14	328.93	1.1225	0.03924	300.27	327.74	1.1074
100	0.04790	310.53	339.27	1.1505	0.04064	309.74	338.19	1.1358
110	0.04946	320.03	349.70	1.1781	0.04201	319.31	348.71	1.1637
120	0.05099	329.64	360.24	1.2053	0.04335	328.98	359.33	1.1910
130	0.05251	339.38	370.88	1.2320	0.04468	338.76	370.04	1.2179
140	0.05402	349.23	381.64	1.2584	0.04599	348.66	380.86	1.2444
150	0.05550	359.21	392.52	1.2844	0.04729	358.68	391.79	1.2706
160	0.05698	369.32	403.51	1.3100	0.04857	368.82	402.82	1.2963

TABLE A-12 *(Continued)*

T °C	v m^3/kg	u kJ/kg	h kJ/kg	s kJ/kg · K	v m^3/kg	u kJ/kg	h kJ/kg	s kJ/kg · K
	p = 8.0 bar = 0.80 MPa (T_{sat} = 31.33°C)				p = 9.0 bar = 0.90 MPa (T_{sat} = 35.53°C)			
Sat.	0.02547	243.78	264.15	0.9066	0.02255	245.88	266.18	0.9054
40	0.02691	252.13	273.66	0.9374	0.02325	250.32	271.25	0.9217
50	0.02846	261.62	284.39	0.9711	0.02472	260.09	282.34	0.9566
60	0.02992	271.04	294.98	1.0034	0.02609	269.72	293.21	0.9897
70	0.03131	280.45	305.50	1.0345	0.02738	279.30	303.94	1.0214
80	0.03264	289.89	316.00	1.0647	0.02861	288.87	314.62	1.0521
90	0.03393	299.37	326.52	1.0940	0.02980	298.46	325.28	1.0819
100	0.03519	308.93	337.08	1.1227	0.03095	308.11	335.96	1.1109
110	0.03642	318.57	347.71	1.1508	0.03207	317.82	346.68	1.1392
120	0.03762	328.31	358.40	1.1784	0.03316	327.62	357.47	1.1670
130	0.03881	338.14	369.19	1.2055	0.03423	337.52	368.33	1.1943
140	0.03997	348.09	380.07	1.2321	0.03529	347.51	379.27	1.2211
150	0.04113	358.15	391.05	1.2584	0.03633	357.61	390.31	1.2475
160	0.04227	368.32	402.14	1.2843	0.03736	367.82	401.44	1.2735
170	0.04340	378.61	413.33	1.3098	0.03838	378.14	412.68	1.2992
180	0.04452	389.02	424.63	1.3351	0.03939	388.57	424.02	1.3245
	p = 10.0 bar = 1.00 MPa (T_{sat} = 39.39°C)				p = 12.0 bar = 1.20 MPa (T_{sat} = 46.32°C)			
Sat.	0.02020	247.77	267.97	0.9043	0.01663	251.03	270.99	0.9023
40	0.02029	248.39	268.68	0.9066				
50	0.02171	258.48	280.19	0.9428	0.01712	254.98	275.52	0.9164
60	0.02301	268.35	291.36	0.9768	0.01835	265.42	287.44	0.9527
70	0.02423	278.11	302.34	1.0093	0.01947	275.59	298.96	0.9868
80	0.02538	287.82	313.20	1.0405	0.02051	285.62	310.24	1.0192
90	0.02649	297.53	324.01	1.0707	0.02150	295.59	321.39	1.0503
100	0.02755	307.27	334.82	1.1000	0.02244	305.54	332.47	1.0804
110	0.02858	317.06	345.65	1.1286	0.02335	315.50	343.52	1.1096
120	0.02959	326.93	356.52	1.1567	0.02423	325.51	354.58	1.1381
130	0.03058	336.88	367.46	1.1841	0.02508	335.58	365.68	1.1660
140	0.03154	346.92	378.46	1.2111	0.02592	345.73	376.83	1.1933
150	0.03250	357.06	389.56	1.2376	0.02674	355.95	388.04	1.2201
160	0.03344	367.31	400.74	1.2638	0.02754	366.27	399.33	1.2465
170	0.03436	377.66	412.02	1.2895	0.02834	376.69	410.70	1.2724
180	0.03528	388.12	423.40	1.3149	0.02912	387.21	422.16	1.2980
	p = 14.0 bar = 1.40 MPa (T_{sat} = 52.43°C)				p = 16.0 bar = 1.60 MPa (T_{sat} = 57.92°C)			
Sat.	0.01405	253.74	273.40	0.9003	0.01208	256.00	275.33	0.8982
60	0.01495	262.17	283.10	0.9297	0.01233	258.48	278.20	0.9069
70	0.01603	272.87	295.31	0.9658	0.01340	269.89	291.33	0.9457
80	0.01701	283.29	307.10	0.9997	0.01435	280.78	303.74	0.9813
90	0.01792	293.55	318.63	1.0319	0.01521	291.39	315.72	1.0148
100	0.01878	303.73	330.02	1.0628	0.01601	301.84	327.46	1.0467
110	0.01960	313.88	341.32	1.0927	0.01677	312.20	339.04	1.0773
120	0.02039	324.05	352.59	1.1218	0.01750	322.53	350.53	1.1069
130	0.02115	334.25	363.86	1.1501	0.01820	332.87	361.99	1.1357
140	0.02189	344.50	375.15	1.1777	0.01887	343.24	373.44	1.1638
150	0.02262	354.82	386.49	1.2048	0.01953	353.66	384.91	1.1912
160	0.02333	365.22	397.89	1.2315	0.02017	364.15	396.43	1.2181
170	0.02403	375.71	409.36	1.2576	0.02080	374.71	407.99	1.2445
180	0.02472	386.29	420.90	1.2834	0.02142	385.35	419.62	1.2704
190	0.02541	396.96	432.53	1.3088	0.02203	396.08	431.33	1.2960
200	0.02608	407.73	444.24	1.3338	0.02263	406.90	443.11	1.3212