

TASK 2

DATA:

- 1) **Window west** = double layer glass/wooden frame/fixed /14.4 m²
- 2) **Window south 1** = double layer glass/wooden frame/fixed /3.6 m²
- 3) **Window south 2** = double layer glass/wooden frame/operable /3.6 m²

1) Window west:

- Heating

With wooden frame

$$U_{\text{window}_{\text{west}}} = 2.84 \frac{\text{W}}{\text{M}^2\text{K}}$$

$$\text{HF}_{\text{window}_{\text{west}}} = U_{\text{window}_{\text{west}}} \times \Delta T_{\text{heating}} = 2.84 * 24.8 = 70.4 \frac{\text{W}}{\text{m}^2}$$

$$Q_{\text{window}_{\text{west}}} = \text{HF}_{\text{window}_{\text{west}}} \times A_{\text{window}_{\text{west}}} = 70.4 * 14.4 = \mathbf{1014.2 \text{ W}}$$

With aluminium frame

$$U_{\text{window}_{\text{west}}} = 3.61 \frac{\text{W}}{\text{M}^2\text{K}}$$

$$\text{HF}_{\text{window}_{\text{west}}} = U_{\text{window}_{\text{west}}} \times \Delta T_{\text{heating}} = 3.61 * 24.8 = 89.53 \frac{\text{W}}{\text{m}^2}$$

$$Q_{\text{window}_{\text{west}}} = \text{HF}_{\text{window}_{\text{west}}} \times A_{\text{window}_{\text{west}}} = 89.53 * 14.4 = \mathbf{1289.23 \text{ W}}$$

The total value change: 1289.23-1014.2= 275.03 W

- Cooling

With wooden frame

$$CF_{\text{fen}} = U(\Delta t - 0.46 \text{DR}) + \text{PXi} \times \text{SHGC} \times \text{IAC} \times \text{FF}_s$$

$$\begin{aligned} CF_{\text{window}_{\text{west}} \text{heatTrasnferPart}} &= U_{\text{window}_{\text{west}}} (\Delta T_{\text{cooling}} - 0.46 \text{DR}) \\ &= 2.84 (7.9 - 0.46 * 11.9) = 6.9 \frac{\text{W}}{\text{m}^2} \end{aligned}$$

$$\text{PXi}_{\text{window}_{\text{west}}} = E_D + E_d = 559 + 188 = 747$$

$$\text{SHGC} = 0.54$$

NO internal shading so IAC = 1

From the table FFs = 0.56

$$CF_{window_{east_IrradiationPart}} = PXI \times SHGC \times IAC \times FF_S = 747 * 0.54 * 1 * 0.56 = 225.9$$

$$CF_{window_{west}} = CF_{window_{west_heatTrasnferPart}} + CF_{window_{west_IrradiationPart}} \\ = 6.9 + 225.9 = 232.8 \frac{W}{m^2}$$

$$Q_{window_{east}} = CF_{window_{east}} \times A_{window_{east}} = 232.8 * 14.4 = \mathbf{3352.32\ W}$$

With aluminium frame

$$CF_{window_{west_heatTrasnferPart}} = U_{window_{east}} (\Delta T_{cooling} - 0.46\ DR) \\ = 3.61 (7.9 - 0.46 * 11.9) = 8.76 \frac{W}{m^2}$$

$$PXI_{window_{west}} = E_D + E_d = 559 + 188 = 747$$

$$SHGC = 0.56$$

NO internal shading so $IAC = 1$

From the table $FFs = 0.56$

$$CF_{window_{east_IrradiationPart}} = PXI \times SHGC \times IAC \times FF_S = 747 * 0.56 * 1 * 0.56 = 234.26$$

$$CF_{window_{west}} = CF_{window_{west_heatTrasnferPart}} + CF_{window_{west_IrradiationPart}} \\ = 8.76 + 234.26 = 243.02 \frac{W}{m^2}$$

$$Q_{window_{east}} = CF_{window_{east}} \times A_{window_{east}} = 243.02 * 14.4 = \mathbf{3499.49\ W}$$

The total value change: $3499.49 - 3352.32 = \mathbf{147.17\ W}$

2) Window south 1:

- Heating

With wooden frame

$$U_{window_{S1}} = 2.84 \frac{W}{m^2 K}$$

$$HF_{window_{S1}} = U_{window_{S1}} \times \Delta T_{heating} = 2.84 * 24.8 = 70.4 \frac{W}{m^2}$$

$$Q_{window_{S1}} = HF_{window_{S1}} \times A_{window_{S2}} = 70.4 * 3.6 = \mathbf{253.44\ W}$$

With aluminium frame

$$U_{window_{S1}} = 3.61 \frac{W}{m^2 K}$$

$$HF_{window_{S1}} = U_{window_{S1}} \times \Delta T_{heating} = 3.61 * 24.8 = 89.53 \frac{W}{m^2}$$

$$Q_{windowS1} = HF_{windowS1} \times A_{windowS1} = 89.53 * 3.6 = \mathbf{322.31\ W}$$

The total value change: $322.31 - 253.44 = \mathbf{68.87W}$

- Cooling

With wooden frame

$$CF_{fen} = U(\Delta t - 0.46DR) + PXI \times SHGC \times IAC \times FF_s$$

$$\begin{aligned} CF_{windowS1_{heatTransferPart}} &= U_{windowS1}(\Delta T_{cooling} - 0.46 DR) \\ &= 2.84 (7.9 - 0.46 * 11.9) = 6.9 \frac{W}{m^2} \end{aligned}$$

$$PXI_{windowS1} = E_D + E_d = 348 + 209 = 557$$

$$SHGC = 0.54$$

NO internal shading so $IAC = 1$

From the table $FFs = 0.47$

$$\begin{aligned} CF_{windowS1_{IrradiationPart}} &= PXI \times SHGC \times IAC \times FF_s = 557 * 0.54 * 1 * 0.47 \\ &= 146.4 \end{aligned}$$

$$\begin{aligned} CF_{windowS1} &= CF_{windowS1_{heatTransferPart}} + CF_{windowS1_{IrradiationPart}} \\ &= 6.9 + 146.4 = 153.3 \frac{W}{m^2} \end{aligned}$$

$$Q_{windowS1} = CF_{windowS1} \times A_{windowS1} = 153.3 * 3.6 = \mathbf{551.88\ W}$$

With aluminium frame

$$\begin{aligned} CF_{windowS1_{heatTransferPart}} &= U_{windowS1}(\Delta T_{cooling} - 0.46 DR) \\ &= 3.61 (7.9 - 0.46 * 11.9) = 8.76 \frac{W}{m^2} \end{aligned}$$

$$PXI_{windowS1} = E_D + E_d = 348 + 209 = 557$$

$$SHGC = 0.56$$

NO internal shading so $IAC = 1$

From the table $FFs = 0.47$

$$\begin{aligned} CF_{windowS1_{IrradiationPart}} &= PXI \times SHGC \times IAC \times FF_s = 557 * 0.56 * 1 * 0.47 \\ &= 151.87 \end{aligned}$$

$$\begin{aligned} CF_{windowS1} &= CF_{windowS1_{heatTransferPart}} + CF_{windowS1_{IrradiationPart}} \\ &= 8.76 + 151.87 = 160.63 \frac{W}{m^2} \end{aligned}$$

$$Q_{window_{S1}} = CF_{window_{S1}} \times A_{window_{S1}} = 160.63 * 3.6 = \mathbf{578.27\ W}$$

The total value change: $578.27 - 551.88 = \mathbf{26.39W}$

3) Window south 2:

- Heating

With wooden frame

$$U_{window_{S2}} = 2.87 \frac{W}{M^2K}$$

$$HF_{window_{S2}} = U_{window_{S2}} \times \Delta T_{heating} = 2.87 * 24.8 = 71.18 \frac{W}{m^2}$$

$$Q_{window_{S2}} = HF_{window_{S2}} \times A_{window_{S2}} = 71.18 * 3.6 = \mathbf{256.25\ W}$$

With aluminium frame

$$U_{window_{S2}} = 4.62 \frac{W}{M^2K}$$

$$HF_{window_{S2}} = U_{window_{S2}} \times \Delta T_{heating} = 4.62 * 24.8 = 114.58 \frac{W}{m^2}$$

$$Q_{window_{S2}} = HF_{window_{S2}} \times A_{window_{S2}} = 114.58 * 3.6 = \mathbf{412.49\ W}$$

The total value change: $412.49 - 256.25 = \mathbf{156.24W}$

- Cooling

With wooden frame

$$CF_{fen} = U(\Delta t - 0.46DR) + PXI \times SHGC \times IAC \times FF_s$$

$$CF_{window_{S2}heatTransferPart} = U_{window_{S2}}(\Delta T_{cooling} - 0.46 DR)$$

$$= 2.87 (7.9 - 0.46 * 11.9) = 6.96 \frac{W}{m^2}$$

$$PXI_{window_{S2}} = E_D + E_d = 348 + 209 = 557$$

$$SHGC = 0.46$$

NO internal shading so $IAC = 1$

From the table $FFs = 0.47$

$$CF_{window_{S2}IrradiationPart} = PXI \times SHGC \times IAC \times FF_s = 557 * 0.46 * 1 * 0.47$$

$$= 124.75$$

$$CF_{windowS2} = CF_{windowS2_heatTrasnferPart} + CF_{windowS2_IrradiationPart}$$

$$= 6.96 + 124.75 = 131.71 \frac{W}{m^2}$$

$$Q_{\square windowS2} = CF_{windowS2} \times A_{windowS2} = 131.71 * 3.6 = \mathbf{474.16 W}$$

With aluminium frame

$$CF_{windowS2_heatTrasnferPart} = U_{windowS2} (\Delta T_{cooling} - 0.46 DR)$$

$$= 4.62 (7.9 - 0.46 * 11.9) = 11.21 \frac{W}{m^2}$$

$$PXI_{windowS2} = E_D + E_d = 348 + 209 = 557$$

$$SHGC = 0.55$$

NO internal shading so IAC = 1

From the table FFs = 0.47

$$CF_{windowS2_IrradiationPart} = PXI \times SHGC \times IAC \times FF_s = 557 * 0.55 * 1 * 0.47$$

$$= 149.15$$

$$CF_{windowS2} = CF_{windowS2_heatTrasnferPart} + CF_{windowS2_IrradiationPart}$$

$$= 11.21 + 149.15 = 160.36 \frac{W}{m^2}$$

$$Q_{\square windowS2} = CF_{windowS2} \times A_{windowS2} = 160.36 * 3.6 = \mathbf{577.3 W}$$

The total value change: 577.3-474.16= 103.14W