

NOTE: ONE WALKWAY PER SLOPE (IN THE GAP BETWEEN ITS TWO BLOCKS) + ONE STRAIGHT CONNECTOR ALONG THE NORTH EDGE. THE FARTHEST MODULE COLUMN IS ≈ 5.8 m FROM THE WALKWAY — CLEAN WITH A 6–7 m WATER-FED TELESCOPIC POLE. W1 / W2 RUN PARALLEL TO THE RIDGE, SO THEY ARE LEVEL. ROOF SIZE / GAPS SCALED FROM THE LAYOUT IMAGE (*) — VERIFY ON SITE.

WALKWAY SCHEDULE

ID	LOCATION	WIDTH	LENGTH
W1	WEST SLOPE: GAP BLOCK 1 / 2 (BESIDE T1)	300 MM	19.9 m
W2	EAST SLOPE: GAP BLOCK 3 / 4 (BESIDE T2)	300 MM	19.9 m
WC	CONNECTOR, NORTH EDGE, W1 → W2	300 MM	16.5 m
WC+	CONNECTOR, W2 → LADDER (NE) *	300 MM	6.4 m
	TOTAL 300 MM WALKWAY		62.7 m
	ORDER (+5 %)		66 m

SECTION A-A (BLOCK 1 | W1 | BLOCK 2)



5 MODULES | W1 | 5 MODULES

WALKWAY NOTES

1. FRP / HDG STEEL ANTI-SKID GRATING, UV STABILISED, MIN. 150 KG/M² RATED.
2. FIX TO PURLINS WITH CLAMPS — NO SHEET PUNCTURE, OR SEAL WITH EPDM WASHERS.
3. ≥ 50 MM CLEAR OF MODULE FRAMES; NO SHADING.
4. CONNECTOR WC IS ≈ 0.5 m FROM THE NORTH EDGE — PROVIDE LIFELINE / HANDRAIL ALONG IT.
5. WC LIFTED ON 100 MM SUPPORTS WHERE TRAY T2 PASSES UNDER IT (SEE SHEET 05).
6. IF GAP 1/2 OR 3/4 MEASURES < 0.5 m, MOUNT THE TRAY BENEATH THE WALKWAY.
7. OUTER MODULE COLUMNS (≈ 5.8 m AWAY): INSPECTION / REPLACEMENT FROM A CRAWL BOARD ON PURLIN LINES.

LEGENDS

	SOLAR MODULES
	WALKWAY 300 MM (W1, W2)
	CONNECTING WALKWAY 300 MM (WC)
	CLEANING REACH
	ROOF ACCESS LADDER
	ROOF RIDGE

SYSTEM DESCRIPTION

SITE LOCATION	— (LAT, LONG TO BE ADDED)
DC CAPACITY	100.00 kWp
TOTAL PLANT CAPACITY (AC)	80 kW
DC / AC RATIO	1.25
MODULE CAPACITY	625 Wp (ADANI N-TOPCon)
MODULE DIMENSION (L X W X H)	2382 X 1134 X 30 mm *
TOTAL PV MODULES	160 Nos.
INVERTER CAPACITY	80 kW (GOODWE GW80K-MT) 1 No.
AZIMUTH / TILT	EAST-WEST (90° / 270°), ROOF SLOPE

CUSTOMER SIGN AND STAMP:

REV.	DATE	DESCRIPTION	DRAWN BY	CHECKED BY	APPROVED BY
R0	27-10-26	FIRST ISSUE			

CLIENT: **JAIN GRANITE & MARBLE**

EPC CONTRACTOR: **NRG TECHNOLOGISTS PVT LTD**
989/6, GIDC Makarpura, Vadodara

DESIGN BY: **NRG TECHNOLOGISTS PVT LTD**
989/6, GIDC Makarpura, Vadodara

DRAWING NO.: 04

DRAWING NAME: **WALKWAY LAYOUT (MODULE CLEANING)**

PROJECT TITLE: 100.00 kWp (DC)_ROOFTOP SOLAR PLANT

RELEASED FOR: ☐ PRELIMINARY ☐ TENDER ☐ REVISION ☐ FABRICATION ☐ CONSTRUCTION ■ APPROVAL

SCALE: **1:200 (A3)**

DESIGN BY	DRAWN BY	CHECKED BY	APPROVED BY	PAPER SIZE	SHEET NO.
27-10-26	27-10-26	27-10-26	27-10-26	**A3**	**01 OF 01**