

Liquid Interconnection Line (LIL)

Command	Effect
Auto	Puts valves in LIL to Auto control (inert valve V55, vent valve V05, spray tank valve V02 and LIL supply valve V01)
Manual	Puts valves in LIL to Manual control (inert valve V55, vent valve V05, spray tank valve V02 and LIL supply valve V01)
Inert	Operates vent valve V05 and inert valve V55
Activate	Will open LIL supply valve V01.
Drain	Will operate LNG spray valve (V01) and inert valve (V55)
Select Tank 1	The valves (above listed) connected to LIL and tank 1 are controlled by the control system
Select Tank 2	The valves (above listed) connected to LIL and tank 2 are controlled by the control system
Select Both Tanks	The valves (above listed) connected to LIL and both tanks are controlled by the control system
Spray Control Auto	Top spray valve V02 is controlled by tank pressure
Open Top/Spray Valve	Manual opening of top spray valve V02

Note! The bottom connection must be activated before LIL supply valve (V01) can be activated.