



WO# 38674220  
FSSP Call/Problem #: 2558776/3106126  
Problem Code: 448 - Clogged Drain Pan  
WO Priority: P5: 4 Hours response time (1)  
Location Name: 269755001  
Location: Willmar Main Office  
401 Trott Ave Sw, Willmar, MN, 56201-3367  
Contact: Seth Elmhurst  
Phone: (320) 235-2472

Service Provider: 1077124 / Midwest Constructors Inc

Description of Work:

AFTERHOURS EMERGENCY - LESSOR ENFORCEMENT There are 2 HVACs for the facility. Both units have clogged drain lines that is causing a leak and excessive water issue. There is roughly 5 gallons of water pooling on the floor. Have been alternating use of either HVAC, it is 91 degrees outside. Facility is 24 hours.

TO BE COMPLETED BY SERVICE PROVIDER:

Service Provider Verification of Provider Services:

Company Name Midwest Constructors Inc.

Signature of Company Representative \_\_\_\_\_ Date \_\_\_\_\_

Self Preform \_\_\_\_\_ Sub Contracted \_\_\_\_\_ Combination (Self Preform/Sub Contracted) \_\_\_\_\_

TO BE COMPLETED BY USPS Employee:

Customer Verification of Site Visit:

Signature: \_\_\_\_\_ Title: \_\_\_\_\_

Date \_\_\_\_\_ Printed Name \_\_\_\_\_ (MUST BE LEGIBLE)

Comments

\_\_\_\_\_  
\_\_\_\_\_

CAN BE RETURNED VIA EMAIL - christian@mwconstructors.com  OR FAX - 763 331 0155

Hans Madsen Phone: 612-202-2657  Christian Madsen Phone: 763-213-2009