SAMPLE - NOT VALID FOR OFFICIAL USE

GOVERNMENT OF MAHARASHTRA - DIRECTORATE OF FIRE SERVICES (SAMPLE LAYOUT)

FIRE SAFETY CERTIFICATE / NO OBJECTION CERTIFICATE

Illustrative statutory-clearance layout - all particulars require official verification

DOCUMENT STATUS
Illustrative sample for portal design, testing, and demonstration only. This is not a legal or official record.

Certificate Reference / URN	MH/FIRE/2026/84920	**Issue Date**	15 January 2026
Sample validity date	31 March 2027	**Issuing status**	NOT ISSUED

1. Institution and premises

Certified Institution (proposed sample): Government College of Engineering, Karad
Campus Address: Survey No. 24, Vidyanagar, Karad, Satara, Maharashtra - 415124
Building particulars: Ground + 4 Floors Technical Education Complex; stated height 17.5 metres.

2. Illustrative inspection checklist

The following are user-supplied example particulars only. No inspection has been represented as performed, and no compliance finding is made by this mock document.

Item	Sample detail provided	Mock status
Wet risers	Functional wet risers	Requires official inspection
Automatic sprinklers	Sprinkler systems in server room	Requires official inspection
Static water storage	2 x 100,000-litre underground tanks	Capacity / availability unverified
Fire tender access	6-metre-wide clear motorable driveway around perimeter	Dimensions / access unverified

3. Sample statement (not a grant of clearance)

This page is a mock layout for software demonstration. It does not certify that the premises comply with fire-safety laws, does not grant a No Objection Certificate, and must not be relied upon for occupancy, licensing, construction, or regulatory purposes.

Signature block shown for layout only
Chief Fire Officer (CFO)
Western Zone, Satara Division
No signature, seal, or official authorization is present.

OFFICIAL SEAL
NOT A REAL SEAL
Reserved blank area