

	INGENIERÍA
VISADO ☐	FIRMA / FECHA
VISADO CON OBSERVACIONES ☒	Alvaro Polania
DEVUELTO PARA CORRECCIONES ☐	Digitally signed by Alvaro Polania
RECHAZADO ☐	Date: 2026.02.11 11:39:49 -05'00'
RECIBIDO PARA INFORMACION ☐	
EL VISADO DEL PRESENTE DOCUMENTO NO RELEVA AL PROVEEDOR DE LA RESPONSABILIDAD DE CUMPLIR CON TODAS LAS CONDICIONES ESTABLECIDAS EN LA ORDEN DE COMPRA O CONTRATO.	



Nota General: Se identificaron múltiples hojas sin contenido relevante. Se recomienda depurarlas e insertar una nota aclaratoria indicando que el cómputo de materiales de todas las áreas se encuentra consolidado en el capítulo "Underground".

0	EMISIÓN PARA LICITACIÓN	06/01/2026	MGA	TDJ	AZA
REV.	DESCRIPCION	FECHA	EJE.	REV.	APR.
		AES: 5155-00-0000-IG-EL-LM-002			
		PROYECTO: LA CALERA CPF2 - FASE 2			
FACILITIES ENGINEERING & MAJOR PROJECTS		TITULO: LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA			
Toda la información contenida en la presente documentación es confidencial y de propiedad de Pluspetrol, siendo prohibida su reproducción o copia, total o parcial, sin autorización previa.		ESC: N/A		DOCUMENTO N°: ACAL-102-LM-E-0017	
		REEMPLAZA:		REVISIÓN: 0	
				Pag: 01 de 162	

pluspetrol AESA			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
													Doc. Cliente: ACAL-102-LM-E-0017			
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNDERGROUND										Fecha de emisión:		6/1/2026	
Lista de Materiales																
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas	
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus				
1 - Puesta a Tierra (PAT)																
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	7200	0							7200	0		
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	25	0							25	0		
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	13	0							13	0		
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	1428	0							1428	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.	
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	47	0							47	0		
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	4	0							4	0		
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	10	0							10	0		
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	6	0							6	0		
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	4	0							4	0	P_MOLDE_01	
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	176	0							176	0	C_150	
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	10	0							10	0	C_250	
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	10	0							10	0		
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	6	0							6	0	C_90	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNDERGROUND										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	136	0							136	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	136	0							136	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	1184	0							1184	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	262	0							262	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	80	0							80	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNDERGROUND										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNDERGROUND										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	63	0							63	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	80	0							80	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	500	0							500	0			

	Proyecto	Doc AESA: 5155-00-0000-IG-EL-LM-002	Rev. 0
	LA CALERA CPF2 - FASE 2	Doc. Cliente: ACAL-102-LM-E-0017	
	LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNDERGROUND	Fecha de emisión:	6/1/2026

Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	900	0							900	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	60	0							60	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	60	0							60	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	60	0							60	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCBAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	200	0							200	0	

Al cierre de la revisión de este documento, no se tienen actualizados los planos de SPCDA de acuerdo con la redefinición del alcance. Deben cambiar las cantidades.

Ajustar a la nueva área, se elimina el área norte, esta cantidad debe bajar.

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNDERGROUND										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	5	0							5	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	4	0							4	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	120	0							120	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	141	0							141	0	Ajustar a la nueva cantidad. Ajustar, se instala 1 camara de inspección con cada triada. No es necesaria 1 camara por cada jabalina.
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	141	0							141	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	90	0							90	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	60	0							60	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	4	0							4	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNDERGROUND										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	120	0							120	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	78	0							78	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	1	0							1	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA E-O										Fecha de emisión:		6/1/2026			
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
1 - Puesta a Tierra (PAT)																		
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0				
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0				
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0				
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.			
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0				
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0				
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01			
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150			
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250			
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0				
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA E-O										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA E-O										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0				
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01			
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0				
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0				
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0				
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0				
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0				
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H"A° - ACERO GALVANIZADO ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01			
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0				
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0				
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0				
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0				

pluspetrol AESA		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA E-O										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

	Proyecto	Doc AESA: 5155-00-0000-IG-EL-LM-002	Rev. 0
	LA CALERA CPF2 - FASE 2	Doc. Cliente: ACAL-102-LM-E-0017	
	LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA E-O	Fecha de emisión:	6/1/2026

Lista de Materiales

Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01

2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)
--

0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCBAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA E-O										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA E-O										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 1										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 1										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 1										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

pluspetrol AESA			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 1										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 1										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 1										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
													Doc. Cliente: ACAL-102-LM-E-0017			
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 1										Fecha de emisión:		6/1/2026	
Lista de Materiales																
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas	
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus				
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115	
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02	
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0		
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43	
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43	
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43	
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0		
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01	
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 2										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
													Doc. Cliente: ACAL-102-LM-E-0017			
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA N-S 2										Fecha de emisión:		6/1/2026	
Lista de Materiales																
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas	
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus				
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115	
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02	
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0		
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43	
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43	
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43	
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0		
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01	
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA PTA										Fecha de emisión:		6/1/2026			
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
1 - Puesta a Tierra (PAT)																		
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0				
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0				
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0				
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.			
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0				
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0				
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01			
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150			
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250			
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0				
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA PTA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA PTA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA PTA										Fecha de emisión:				6/1/2026	
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

	Proyecto		Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
	LA CALERA CPF2 - FASE 2		Doc. Cliente: ACAL-102-LM-E-0017		
	LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA PTA			Fecha de emisión:	

Lista de Materiales

Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01

2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)
--

0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCBAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA PTA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA PTA										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA NORTE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA NORTE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA NORTE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
												LA CALERA CPF2 - FASE 2					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA NORTE										Doc. Cliente: ACAL-102-LM-E-0017					
												Fecha de emisión:				6/1/2026	
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA NORTE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA NORTE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SENDA NORTE										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - FLARE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
													Doc. Cliente: ACAL-102-LM-E-0017			
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - FLARE										Fecha de emisión:		6/1/2026	
Lista de Materiales																
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas	
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus				
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0		
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0		
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0		
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0		
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0		
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0		
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0		
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0		
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01	
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0		
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0		
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0		
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0		

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - FLARE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

pluspetrol AESA		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - FLARE										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - FLARE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - FLARE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - FLARE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ZONA SLUG CATCHER										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ZONA SLUG CATCHER										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ZONA SLUG CATCHER										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ZONA SLUG CATCHER										Fecha de emisión:				6/1/2026	
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ZONA SLUG CATCHER										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ZONA SLUG CATCHER										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ZONA SLUG CATCHER										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - INTERCONEXIONES										Fecha de emisión:				6/1/2026	
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
1 - Puesta a Tierra (PAT)																	
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0			
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0			
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0			
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.		
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0			
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0			
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0			
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0			
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01		
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150		
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250		
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0			
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90		

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - INTERCONEXIONES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - INTERCONEXIONES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - INTERCONEXIONES										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - INTERCONEXIONES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - INTERCONEXIONES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - INTERCONEXIONES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE CONDENSADO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE CONDENSADO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE CONDENSADO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE CONDENSADO										Fecha de emisión:		6/1/2026			
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE CONDENSADO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE CONDENSADO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
													Doc. Cliente: ACAL-102-LM-E-0017			
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE CONDENSADO										Fecha de emisión:		6/1/2026	
Lista de Materiales																
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas	
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus				
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115	
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02	
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0		
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43	
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43	
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43	
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0		
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01	
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01	

pluspetrol AESA			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - TANQUES Y BOMBAS DE EFLUENTES										Fecha de emisión:		6/1/2026			
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
1 - Puesta a Tierra (PAT)																		
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0				
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0				
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0				
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.			
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0				
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0				
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01			
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150			
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250			
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0				
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - TANQUES Y BOMBAS DE EFLUENTES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - TANQUES Y BOMBAS DE EFLUENTES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - TANQUES Y BOMBAS DE EFLUENTES										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - TANQUES Y BOMBAS DE EFLUENTES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - TANQUES Y BOMBAS DE EFLUENTES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - TANQUES Y BOMBAS DE EFLUENTES										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

pluspetrol AESA			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SKID DE GAS COMBUSTIBLE										Fecha de emisión:		6/1/2026			
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
1 - Puesta a Tierra (PAT)																		
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0				
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0				
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0				
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.			
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0				
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0				
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01			
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150			
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250			
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0				
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SKID DE GAS COMBUSTIBLE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SKID DE GAS COMBUSTIBLE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SKID DE GAS COMBUSTIBLE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0	
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0	
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0	
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0	
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0	
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0	
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0	
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0	
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SKID DE GAS COMBUSTIBLE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SKID DE GAS COMBUSTIBLE										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SKID DE GAS COMBUSTIBLE										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

pluspetrol AESA			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002										Rev. 0	
													LA CALERA CPF2 - FASE 2											
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE GAS										Fecha de emisión:										6/1/2026	
Lista de Materiales																								
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas									
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus												
1 - Puesta a Tierra (PAT)																								
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0										
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0										
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0										
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.									
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0										
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0										
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0										
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0										
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01									
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150									
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250									
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0										
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90									

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
													Doc. Cliente: ACAL-102-LM-E-0017			
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE GAS										Fecha de emisión:		6/1/2026	
Lista de Materiales																
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas	
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus				
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0		
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0		
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0		
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0		
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0		
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0		
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0		
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0		
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01	
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0		
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0		
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0		
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0		

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE GAS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE GAS										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE GAS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE GAS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

	Proyecto		Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
	LA CALERA CPF2 - FASE 2		Doc. Cliente: ACAL-102-LM-E-0017		
	LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - UNIDAD DE PROCESAMIENTO DE GAS			Fecha de emisión:	

Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
													Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS DE COMPRESORES										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
1 - Puesta a Tierra (PAT)																		
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0				
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0				
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0				
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.			
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0				
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0				
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01			
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150			
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250			
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0				
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS DE COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS DE COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS DE COMPRESORES										Fecha de emisión:				6/1/2026	
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS DE COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS DE COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SERVICIOS DE COMPRESORES										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - COMPRESORES										Fecha de emisión:				6/1/2026	
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0			
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01		
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0			
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0			
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0			
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0			
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0			
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01		
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0			
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0			
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0			
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0			

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - COMPRESORES										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - COMPRESORES										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - COMPRESORES										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

pluspetrol AESA			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ALMACENAMIENTO DE CONDENSADO CPF2										Fecha de emisión:		6/1/2026			
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
1 - Puesta a Tierra (PAT)																		
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0				
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0				
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0				
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.			
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0				
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0				
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0				
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01			
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150			
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250			
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0				
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ALMACENAMIENTO DE CONDENSADO CPF2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ALMACENAMIENTO DE CONDENSADO CPF2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

pluspetrol AESA		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ALMACENAMIENTO DE CONDENSADO CPF2										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ALMACENAMIENTO DE CONDENSADO CPF2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ALMACENAMIENTO DE CONDENSADO CPF2										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - ALMACENAMIENTO DE CONDENSADO CPF2										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - PLANTA DE TRATAMIENTO DE AGUA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - PLANTA DE TRATAMIENTO DE AGUA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - PLANTA DE TRATAMIENTO DE AGUA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - PLANTA DE TRATAMIENTO DE AGUA										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - PLANTA DE TRATAMIENTO DE AGUA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - PLANTA DE TRATAMIENTO DE AGUA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - PLANTA DE TRATAMIENTO DE AGUA										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - GENERACIÓN										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - GENERACIÓN										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - GENERACIÓN										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - GENERACIÓN										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - GENERACIÓN										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - GENERACIÓN										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - GENERACIÓN										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - HOT OIL										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

				Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
				LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
				LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - HOT OIL										Fecha de emisión:				6/1/2026	
Lista de Materiales																			
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas				
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus							
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0					
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0					
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0					
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0					
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0					
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0					
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0					
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0					
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01				
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0					
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0					
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0					
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0					

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - HOT OIL										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - HOT OIL										Fecha de emisión:				6/1/2026	
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - HOT OIL										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - HOT OIL										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - HOT OIL										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SUMIDERO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SUMIDERO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SUMIDERO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

pluspetrol AESA		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SUMIDERO										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SUMIDERO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 -----Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SUMIDERO										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SUMIDERO										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SALA ELÉCTRICA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SALA ELÉCTRICA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SALA ELÉCTRICA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

pluspetrol AESA			Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
			LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SALA ELÉCTRICA										Fecha de emisión:		6/1/2026			
Lista de Materiales																		
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas			
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus						
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0				
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0				
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0				
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0				
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0				
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01			
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0				
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0				
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0				
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01			
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0				
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01			
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0				

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SALA ELÉCTRICA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SALA ELÉCTRICA										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SALA ELÉCTRICA										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SHELTERS DE INSTRUMENTOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
1 - Puesta a Tierra (PAT)															
0	1.1	XEWBRC13359480	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 95mm2	m	0	0							0	0	
0	1.2	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	1.3	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	1.4	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	m	0	0							0	0	La cantidad de metros de este ítem contabilizado, corresponde a los afloramientos de las distintas áreas. Se contabiliza en su totalidad como underground.
0	1.5	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	1.6	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2 (PARA JABALINA SIN CAMARA DE INSPECCION PAT-01B)	u	0	0							0	0	
0	1.7	XEWMCC11260557	Mold for cable to cable with exothermic welding connection TA, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.8	XEWMCC11260663	Mold for cable to cable with exothermic welding connection XB, graphite, cable_section: 95 mm2, derivation_section: 95 mm2	u	0	0							0	0	
0	1.9	C515500IGELMPAT001	Pinza para molde de soldadura cupro-aluminotérmica	u	0	0							0	0	P_MOLDE_01
0	1.10	C515500IGELMPAT002	Cartucho/carga para soldadura cupro-aluminotérmica C150	u	0	0							0	0	C_150
0	1.11	C515500IGELMPAT003	Cartucho/carga para soldadura cupro-aluminotérmica C250	u	0	0							0	0	C_250
0	1.12	XEWMCC11260556	Mold for cable to cable with exothermic welding connection TA, graphite,cable_section: 95 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	1.13	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SHELTERS DE INSTRUMENTOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.14	XLTC_11640382	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 95 mm2.	u	0	0							0	0	
0	1.15	XLTC_11640381	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.16	XLTC_11640520	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 95 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.17	XLTC_15097239	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 70 mm2; Tap/Derivation: 70 mm2.	u	0	0							0	0	
0	1.18	XLTC_11640365	Cold Compression Terminal Cable to Cable manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.19	XLTC_11640365	Cold Compression Terminal Cable to rod manufactured from high conductivity copper, model: c-connector, according to requirements of standard IRAM 2349/ IEEE 837. Main/ Run: 35 mm2, Tap/Derivation: 35 mm2.	u	0	0							0	0	
0	1.20	XEWBRC13359476	Bare copper conductor, 7 Wires, hard wire, IRAM 2004. Section: 35mm2.	m	0	0							0	0	
0	1.21	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	1.22	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	1.23	XLHBB_12141867	Hardware hex head bolt galvanized steel. Diameter: 3/8", lenght: 1-1/2"	u	0	0							0	0	
0	1.24	XLHFW_12142203	Hardware flat washer galvanized steel. Diameter: 3/8"	u	0	0							0	0	
0	1.25	XLHSW_12142219	Hardware split lock washer galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	
0	1.26	XLHHM_12142185	Hardware hex nut galvanized steel, standard. Diameter: 3/8"	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SHELTERS DE INSTRUMENTOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.27	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	1.28	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	1.29	XLHHB_12141861	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 2 in	u	0	0							0	0	
0	1.30	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4 in	u	0	0							0	0	
0	1.31	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.32	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	1.33	XLHHB_14028055	Hardware hex head bolt galvanized steel. Diameter: 1/4 in, lenght: 1/2 in	u	0	0							0	0	
0	1.34	C515500IGELMPAT007	TACO DE ANCLAJE PARA H°A° - ACERO GALVANIZADO Ø1/4" x 30 mm	u	0	0							0	0	T_ANC_01
0	1.35	XLCLU_11758802	Cable Lug one hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.36	XLCLU_12158392	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1. Section: 70mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.37	XLCLU_12158396	Cable Lug one hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0	
0	1.38	XLCLU_11758933	Cable Lug TWO hole, tinned copper, standard barrel Length with inspection window, according to IEC 61238-1. Section: 35 mm2; Hole Diameter: 3/8 in.	u	0	0							0	0	
0	1.39	XLCLU_11758941	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 70mm² Hole 3/8"	u	0	0							0	0	

pluspetrol AESA		Proyecto										Doc AESA: 5155-00-0000-IG-EL-LM-002				Rev. 0	
		LA CALERA CPF2 - FASE 2										Doc. Cliente: ACAL-102-LM-E-0017					
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SHELTERS DE INSTRUMENTOS										Fecha de emisión:		6/1/2026			
Lista de Materiales																	
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas		
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus					
0	1.40	XLCLU_11758945	Cable Lug TWO hole, tinned copper, standard barrel length without inspection window, according to IEC 61238-1, conductor section 95mm² Hole 3/8"	u	0	0							0	0			
0	1.41	XEWGC_15100360	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 25 mm2 - 50 mm2.	u	0	0							0	0			
0	1.42	XEWGC_15100361	Tower Ground Clamp tin-plated bronze, one conductor, NC3 type. Bolt Diameter: 7/16in.; Wire Range: 70 mm2 - 120 mm2.	u	0	0							0	0			
0	1.43	XEWGC_15100358	Tower Ground Clamp tin-plated bronze, two conductors holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 6 mm2 - 50 mm2.	u	0	0							0	0			
0	1.44	XEWGC_15360955	Tower Ground Clamp tin-plated bronze, ONE conductor holding between two plates. Bolt Diameter: 3/8in.; Wire Range: 10 mm2 - 35 mm2.	u	0	0							0	0			
0	1.45	C515500IGELMPAT008	Grampa para derivación en paralelo 16-50 mm2 (REF. LCT GP-1 - 6mm2 a 35 mm2)	u	0	0							0	0	GRAMPA_01		
0	1.46	XEWGC_15100357	Tower Ground Clamp tin-plated bronze, one conductor holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 95 mm2.	u	0	0							0	0			
0	1.47	XEWGC_15100355	Tower Ground Clamp tin-plated bronze, two conductors holding directly on surface. Bolt Diameter: 3/8in.; Wire Range: 50 mm2 - 70 mm2.	u	0	0							0	0			
0	1.48	XCPSLR14478463	Steel ShapeFull Rectangular Shape, AISI 304 63,5 mm x 6,35 mm (Planchuela de acero inoxidable AISI 304 para Oreja de PAT)	m	0	0							0	0			
0	1.49	C515500IGELMPAT009	PERNO ROSCADO CONECTOR ELÉCTRICO S-BT-EF-M8/15 AN 6 HL (Ref: HILTI)	u	0	0							0	0	SBTEFM8_01		
0	1.50	XLMFBA11684583	Miscellaneous electrical Flat Bar copper, with squared edges, Width: 50mm x Thickness: 5mm.	m	0	0							0	0			
0	1.51	C515500IGELMPAT010	Aislador de baja tensión en resina epoxi tipo ASE-0, diametro = 1/2" x 1 1/2"	u	0	0							0	0	AISLA_01		
0	1.52	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0			

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SHELTERS DE INSTRUMENTOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	1.53	XLFSC_14304563	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 35mm²	m	0	0							0	0	
0	1.54	C515500IGELMPAT011	TERMOCONTRAIBLE UNIPOLAR 1x70 a 1x150 mm2	u	0	0							0	0	TERMOC_01
0	1.55	XLTCR_12198323	Cable to Rod copper, according to IRAM 2349. Section 70mm2 hole diameter 3/4" ----- TERMINAL DE COMPRESION EN FRIJO JABALINA 3/4 - CABLE DE 70mm2	u	0	0							0	0	
0	1.56	C515500IGELMPAT012	Conector para derivación en cruz: Main (Run) 70mm2; Derivation (Tap): 70mm2 Referencia: BURNDY QPX2828 (RUN: 1 Str. - 4/0 Str. // TAP: 1 Str. - 4/0 Str.)	u	0	0							0	0	C_CRUZ_01
0	1.57	C515500IGELMPAT013	Bloquete de PAT. Referencia: similar Gonella BLQ6	u	0	0							0	0	BLOQUETE01
2 - Sistema de Protección Contra Descargas Atmosféricas (SPCDA)															
0	2.1	XEWBRC13359479	Bare copper conductor, 19 Wires, hard wire, IRAM 2004. Section: 70mm²	u	0	0							0	0	
0	2.2	XLFSC_14304568	Single Core Cable, rated voltage 450/750 V, conductor class 2 , IEC 60227/ IRAM NM 247-3, IEC 60332-3-24/IRAM NM IEC 60332-3-24 flame retardant/ no flame propagation, insulation PVC - green/yellow, copper conductor, Section: 70mm²	m	0	0							0	0	
0	2.3	XEHEAC12130575	PUNTA RECEPTORA BAYONETA 5/8" DIÁMETRO 36" LARGO COBRE (CLASE II) NIQUELADO	u	0	0							0	0	
0	2.4	C515500IGELMPAT014	ADAPTADOR AJUSTABLE GIRATORIO PARA PUNTAS 5/8" MACHO — 5/8" HEMBRA DE BRONCE	u	0	0							0	0	PARAR_01
0	2.5	C515500IGELMPAT015	BASE PARA MONTAJE HORIZONTAL 5/8" DIÁMETRO CUADRADA DE BRONCE	u	0	0							0	0	PARAR_02
0	2.6	C515500IGELMPAT016	CUPLA REDUCCION DE UNION EN ACERO GALV. ROSCA NPT 2" A 5/8" PARA BALLONETA	u	0	0							0	0	PARAR_03
0	2.7	XLBMBF14151870	Conduit Tubes RMC rigid metal conduit, burr-free interior surface IRAM IAS U 500-2100, hot dip galvanized 20 microns minimum, NPT-M ends with threaded coupling and thread protect. Diameter: 2in.	m	0	0							0	0	
0	2.8	XEHCAB14243274	Lightning Cable Fastener with ceramic insulator, surface mounting, galvanized steel, 70mm2 ----- Grampa con aislador para montaje en superficie, acero galvanizado, 70mm2	u	0	0							0	0	

		Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0	
												Doc. Cliente: ACAL-102-LM-E-0017			
		LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SHELTERS DE INSTRUMENTOS										Fecha de emisión:		6/1/2026	
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.9	XLHHB_12141859	Hardware hex head bolt galvanized steel. Diameter: 1/4", lenght: 1"	u	0	0							0	0	
0	2.10	C515500IGELMPAT006	ARANDELA DE GOMA PARA SELLADO. Diameter: 1/4"	u	0	0							0	0	A_GOMA_01
0	2.11	XLHFW_12668613	Hardware flat washer galvanized steel. Diameter: 1/4"	u	0	0							0	0	
0	2.12	XLHSW_12957979	Hardware split lock washer galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.13	XLHHM_12668615	Hardware hex nut galvanized steel, standard. Diameter: 1/4"	u	0	0							0	0	
0	2.14	C515500IGELMPAT005	COMPUESTO SELLADOR MASTIC 7662 - 3M (Compuesto en FRIO)	kg	0	0							0	0	SELLADOR01
0	2.15	XEWMCR11260829	Mold for cable to rod with exothermic welding connection GR, graphite. Section 70 mm2	u	0	0							0	0	
0	2.16	C515500IGELMPAT004	Cartucho/carga para soldadura cupro-aluminotérmica C90	u	0	0							0	0	C_90
0	2.17	XEWGR311260873	Ground rod copper & steel, with threaded coupling and driving stud (without clamp), according to IRAM 2309.	u	0	0							0	0	
0	2.18	XEWGRR11260851	Ground Recept for ground rod polycarbonate, 400x400x500mm	u	0	0							0	0	
0	2.19	XLBNMC12143075	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter: 8in.	m	0	0							0	0	
0	2.20	XEWMCC11260712	Mold for cable to cable with exothermic welding connection PT, graphite, CABLE_SECTION: 70 mm2, derivation_section: 70 mm2	u	0	0							0	0	
0	2.21	XEWMCR11260846	Mold for cable to rod with exothermic welding connection GY, graphite. Section 95 mm2	u	0	0							0	0	

			Proyecto LA CALERA CPF2 - FASE 2										Doc AESA: 5155-00-0000-IG-EL-LM-002		Rev. 0
													Doc. Cliente: ACAL-102-LM-E-0017		
			LISTADO DE MATERIALES - PUESTA A TIERRA Y SPCDA - SHELTERS DE INSTRUMENTOS										Fecha de emisión:		6/1/2026
Lista de Materiales															
Rev.	Item	Código	Descripción de Material	Unidad	Rev. 0		Rev.		Rev.		Rev.		Total	Dif. c/ la Rev. anterior	Notas
					Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus	Cant.	Sur Plus			
0	2.22	C515500IGELMPAT017	Cartucho/carga para soldadura cupro-aluminotérmica C115	u	0	0							0	0	C_115
0	2.23	C515500IGELMPAT018	GRAMPA A COMPRESION PARA CAÑO EN ACERO GALV. ø2" Y CABLE EN PARALELO DE 70mm2. REFERENCIA: BURNDY MODELO GAR 1826.	u	0	0							0	0	GRAMPA_02
0	2.24	XEFUB_11717717	GRAMPA U-BOLT 2" x 3/8	u	0	0							0	0	
0	2.25	XCPL__14480233	Steel Shape Type L , F-24 , IRAM	m	0	0							0	0	PAT-43
0	2.26	XLAXCS12141265	C-Profile straight section with round perforations, hot dip galvanized ASTM A123 65 microns (standard). Length: 6000mm, Height: 44mm; Width: 44mm; Thickness: 1,6mm	u	0	0							0	0	PAT-43
0	2.27	XLAXCC12191935	C-Profile conduit fixing clamp G-01 type, hot dip galvanized ASTM A123 65 microns (standard) GRAMPA OLMAR DE A° G° 1" PARA FIJACION DE CAÑOS O CABLES A PERFIL C	u	0	0							0	0	PAT-43
0	2.28	XLBNMC12143065	Conduit Tubes Rigid non-metal conduit IRAM compliant, reinforced PVC, thickness: 3.2 mm. Diameter : 1".	m	0	0							0	0	
0	2.29	C515500IGELMPAT019	Columna metálica para montaje de pararrayo, acero galvanizado por inmersión en caliente, altura libre 12 mts. La columna deberá ser provista con bulón de puesta a tierra.	u	0	0							0	0	COL_P_01
0	2.30	C515500IGELMPAT020	DESCARGADOR (VÍA DE CHISPAS) SUMINISTRADA CON CABLES DE COBRE AISLADOS Y 02 (DOS) TERMINALES DE COMPRESIÓN TIPO YAL. COMPATIBLE PARA CABLES 16-70mm².	u	0	0							0	0	VIA_CH_01