

### Bid Document

Bid Details	
Bid End Date/Time	18-07-2020 16:00:00
Bid Opening Date/Time	18-07-2020 16:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	N/a
Office Name	Central Railway Hq Stores Deptt.
Total Quantity	5
Item Category	Online UPS
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No
Estimated Bid Value	11950

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

### Online UPS ( 5 pieces )

### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	<b>Rating in KVA (KVA)</b>	1.0 KVA	1.0 KVA
	<b>Technology</b>	MOSFET-PWM with inbuilt isolation transformer	MOSFET-PWM with inbuilt isolation transformer
	<b>Input Power</b>	single phase 160V - 260V sinewave,50Hz	single phase 160V - 260V sinewave,50Hz
	<b>Output power</b>	Single phase 230V +/-1% sinewave 50 Hz	Single phase 230V +/-1% sinewave 50 Hz
	<b>Backup time (Minutes)</b>	30	30
	<b>Minimum VAH (VAH)</b>	32024	32024
	<b>Warranty for UPS (Years)</b>	1	1
	<b>Movable trolley for Batteries</b>	Without	Without
	<b>Warranty for battery</b>	1	1
	<b>Degree of Protection</b>	IP21	IP21
	<b>Cabling 5 meters for input and out put</b>	Without	Without
	<b>Paralleling kit for synchronising</b>	Without	Without
	Installation and Commissioning	Yes	*
Constructional	Minimum thickness of M.S.Sheet Enclosure duly painted (mm)	1.0	*
	<b>Type of Battery</b>	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)
Functional	Maximum overshoot and Under shoot of output rated voltage	4	*
	Voltage Regulation from no load to full load (%)	< / = 3%	*
	<b>20% Overload limit for minimum 10 minutes</b>	Yes	Yes
	<b>Overall Efficiency (%)</b>	>/=90%	>/=90%
	Total Harmonic	Maximum 3%	*

	Distortion(THD) (%)		
	<b>50% Overload limit for minimum 1 minutes</b>	Yes	Yes
Protection	Protection for under voltage at battery terminal at 10.5V per 12 V battery	Yes	*
	Protection of Over voltage,Short Circuit & over load at UPS output terminal	Yes	*
Metering And Indications	Digital Metering in UPS for AC Input Voltage,Output AC Voltage,Current,Frequency, Battery Voltage and Current	Yes	*
	Indicators for mains presence,Battery charging and discharging,Output Over Load, Low Battery Voltage	Yes	*
Reports And Certification	Damp Heat : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	Yes	*
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes	*
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes	*
	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes	*
	Type Test Certificate No.	-	*

Type Test Certificate date	-	*
Name of Lab	-	*
Address of Lab	-	*
As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Not applicable presently	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

### Additional Specification Documents

### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Vishnu Ganpat	400089,Sr.Section Engineer(M) LTT Substation, LTT, Mumbai-400089	5	30

### Special terms and conditions for category Online UPS

1. Calculation of Minimum VAH based on Back up time Minimum VAH requirements would be calculated on the basis of following: (VAH Calculation: Battery Voltage x Battery Ah x No. of Batteries = VAH)UPS Rating15 Minutes30 Minutes60 Minutes90 Minutes120 Minutes180 Minutes240 Minutes1 KVA400 VAH800 VAH1600 VAH2400 VAH3200 VAH4800 VAH6400 VAH2 KVA800 VAH1600 VAH3200 VAH4800 VAH6400 VAH9600 VAH12800 VAH3 KVA1200 VAH2400 VAH4800 VAH7200VAH9600 VAH14400 VAH19200 VAH5 KVA2000 VAH4000 VAH8000 VAH12000 VAH16000 VAH24000 VAH32000 VAH6 KVA2400 VAH4800 VAH9600 VAH14400 VAH19200 VAH28800 VAH38400 VAH7.5 KVA3000 VAH6000 VAH12000 VAH18000 VAH24000 VAH36000 VAH48000 VAH10 KVA4000 VAH8000 VAH16000 VAH24000 VAH32000 VAH48000 VAH64000 VAH15 KVA6000 VAH12000 VAH24000 VAH36000 VAH48000 VAH72000 VAH96000 VAH20 KVA8000 VAH16000 VAH32000 VAH48000 VAH64000 VAH96000 VAH128000 VAH30 KVA12000 VAH24000 VAH48000 VAH72000 VAH96000 VAH144000 VAH192000 VAH40 KVA16000 VAH32000 VAH64000 VAH96000 VAH128000 VAH192000 VAH256000 VAH60 KVA24000 VAH48000 VAH96000 VAH144000 VAH192000 VAH288000 VAH384000 VAH80 KVA32000 VAH64000 VAH128000 VAH192000 VAH256000 VAH384000 VAH512000 VAH100 KVA40000 VAH80000 VAH160000 VAH240000 VAH320000 VAH480000 VAH640000 VAH

### Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods
2. Warranty period of the supplied products shall be 5 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by

Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**