

Bid Document

Bid Details	
Bid End Date/Time	10-07-2020 15:00:00
Bid Opening Date/Time	10-07-2020 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Petroleum And Natural Gas
Department Name	Na
Organisation Name	Hindustan Petroleum Corporation Ltd
Office Name	Petroleum House
Total Quantity	10
Item Category	Sodium Hypochlorite or Sodium Hypochlorite Solution
Experience Criteria	1 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No
Estimated Bid Value	400

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

Sodium Hypochlorite Or Sodium Hypochlorite Solution (10 liter)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Certification	Sodium Hypochlorite Solution (Grade 1) conforming to Indian Standard IS 11673(latest)	Yes	*
	Whether ISI Marked	No	*
	CM/L Number(Must declare,if ISI marked)	-	*
	Food and drug license available	Yes	*
Test Report Details	Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification	Yes	*
	Test Report to be Submitted to the Buyer on demand	Yes	*
	Food and drug license Number(Write NA ,if not available)	-	*
	Date of issue of Food and drug license	-	*
	Food and drug license to be submitted to the Buyer on demand	Yes	*
Physical Characteristics	Form	Liquid	*
	Colour	Pale Yellowish Green	*
Requirements for	Relative Density(at	1.07	*

Sodium Hypochlorite Solution	25 °/25 °C)		
	"Available Chlorine percent by mass by volume	6	*
	Total Chlorine percent by volume(as Cl)	6	*
	Free Alkali (as NaOH) (Min)g/l	1	*
	Free Sodium CarbonateNa ₂ CO ₃ (Max)g/l	0.5	*
	Iron(as Fe)(Max) ppm	0.4	*
	Sodium Chlorate	0.05	*
Packing and Marking	Quantity per Pack(in Liter)	5	5
	Packing Type	Air Tight Plastic Containers	*
	Marking(as per provisions made in clause 6 of IS 11673(latest)	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Sanjiv Mili	400008,HPCL, Richardson & Cruddas Building, 2nd Floor, J J Road, Byculla, Mumbai - 400008	10	3

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods
2. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
3. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
4. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

5. Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.
6. The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---