

Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 17:00:00
Bid Opening Date/Time	27-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Defence
Department Name	Department Of Defence
Organisation Name	Indian Navy
Office Name	*****
Total Quantity	10
Item Category	Stationary Value Regulated Lead Acid Batteries
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No
Estimated Bid Value	54500

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Stationary Value Regulated Lead Acid Batteries (10 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Stationary Value Regulated lead acid batteries conforming to IS: 15549/2005 with Amendment 1 and 2 latest	Yes	*
	ISI Marked	No	Yes, No
	ISI Marked if "YES" declare BIS License Number (CM/L Number). If "NO" write NA	-	*
	Battery Voltage	12 Volt	12 Volt
	Battery Capacity (in Ah) at 10 H Rate	100 Ah	100 Ah
	Material of Container	Styrene-acrylonitrile (SAN)	Styrene-acrylonitrile (SAN)
	Material of separators as per Cl. 4.5 of IS:15549:2005 latest	Glass Mat	*
	Battery supply condition condition	Factory Charged Condition	*
CONSTRUCTIONAL	Material and construction for Containers, Cell Lids, Plates, Electrolyte, Terminal posts, Fasteners, Connectors and Separators as per Cl. 4 of IS:15549:2005 latest	Yes	*
	Marking as per Cl. 8 of IS:15549: 2005 latest	Yes	*
	Application of battery	Float	*
	Number of cells per battery	6 Cells for 12 Volt Battery	6 Cells for 12 Volt Battery
	Method of connections between cells	Bolted	Bolted
	Over all dimension of each battery (Length x Width x Height) in mm - Must declare	-	*

	Weight of each battery (in Kg) - Must declare	-	*
	Instructions/Manuals shall be furnished for procedure and monitoring the health of battery during maintenance and preventive measures required	Yes	*
	Warranty (in Years)	2 Years	2 Years
CERTIFICATIONS	Availability of complete and satisfactory type test Report from Central Government / NABL/ ILAC accredited laboratory to showing conformity of the Specification	Yes	*
	Test report Number	-	*
	Report date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	All the test reports and certificates shall furnish to the buyer/consignee on demand	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	*****	*****ERNAKULAM	10	15

Special terms and conditions for category Stationary Value Regulated Lead Acid Batteries

- Battery serial number list shall be furnish by the seller along with the supply of the battery to Buyer

Bid Specific Additional Terms and Conditions

1. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---