

Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 12:00:00
Bid Opening Date/Time	27-07-2020 12:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Defence
Department Name	Department Of Defence
Organisation Name	Military Engineer Services
Office Name	*****
Total Quantity	12
Item Category	water storage tanks (PAC Only)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	20 %
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 20% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Water Storage Tanks (12 pieces) (Under PAC)

Make	reno
Model	reno

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Specification	Conformity to Indian Standard IS 12701 (Latest)	Yes	*
	ISI Marked	No	No
	CM/L No	0	*
Shape and Construction	Shape of the Tank	Cylindrical Vertical Tank	Cylindrical Vertical Tank
	Number of Layers	Single Layer	Single Layer
Capacity	Capacity of the Tank (Litres)	500	500
Dimension	Dimension of Tank as per IS 12701(latest)	Yes	*
Uses	Uses	Out Door Use	Out Door Use
Test Reports	Availability of Test Reports from Central Govt./State Govt/NABL/IL AC accredited Lab covering all the Declared Parameters as per IS Specification	Yes	*
	Test Report No	2017-09-DW-073	*
	Test Report Date	21/09/2017	*
	Name of the Lab	Sintex Industries Lt	*
	Address of the Lab	Kalol, North Gujarat	*
	Test Reports to be furnished to the buyer on Demand	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	*****	*****NASHIK	12	30

Bid Specific Additional Terms and Conditions

- 1.Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one

within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

2. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
3. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.
4. Procurement under this bid is reserved for purchase from Micro and Small Enterprises from the State of Bid Inviting Authority whose credentials are validated online through Udyog Aadhaar for that product category. If the bidder wants to avail the reservation benefit, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service.
5. ISO 9001: The bidder must have ISO 9001 certification.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---