

Bid Document

Bid Details	
Bid End Date/Time	16-07-2020 13:00:00
Bid Opening Date/Time	16-07-2020 13:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Coal
Department Name	Materials Management
Organisation Name	Northern Coalfields Limited
Office Name	Singrauli
Total Quantity	4000
Item Category	Porcelain insulators for overhead power lines with a nominal voltage upto and including 1000 V
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Porcelain Insulators For Overhead Power Lines With A Nominal Voltage Upto And Including 1000 V (4000 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Porcelain insulators for overhead power lines with a nominal voltage up to and including 1000 V conforming to	IS 1445 (1977) with amdt., latest	*
	The porcelain shall be sound, free from defects, thoroughly vitrified and smoothly glazed	Yes	*
	General requirements and Insulator characteristics as per Cl. 4 and Cl. 5 of IS:1445 (1977) latest	Yes	*
	Colour of the Glaze	Brown	*
	Type	Pin Insulator Type 1	Pin Insulator Type 1
	Minimum failing load (in KN)	3.5 KN for Pin Insulator	3.5 KN for Pin Insulator
	Packing	Boxes	Boxes
	Installation and Commissioning	No	No
	Warranty (in Years)	1	1
CERTIFICATIONS	Availability of type test reports from any Central Govt. laboratory / ILAC approved laboratory / NABL approved laboratory. Type test report shall be complete alongwith authenticated drawings from the test lab	Yes	*
	Type Test Report Number	-	*
	Type Test Report Date	-	*
	Name of testing lab	-	*

Address of testing lab	-	*
All the test reports shall be furnished as and when requested to do so by Purchase authority	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Anurag Krishna Agrawal	231220,REGIONAL STORES, BINA PROJECT, NCL, PO - BINA, DISTT - SONBHADRA U.P.	4000	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---