

Bid Document

Bid Details	
Bid End Date/Time	23-07-2020 16:00:00
Bid Opening Date/Time	23-07-2020 16:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	80 (Days)
Ministry/State Name	Ministry Of Agriculture And Farmers Welfare
Department Name	Department Of Agricultural Research And Education (dare)
Organisation Name	Indian Council Of Agricultural Research (icar)
Office Name	National Bureau Of Agricultural Insect Resources, Bengaluru
Total Quantity	3
Item Category	lead acid battery
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Lead Acid Battery (3 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	Types of Lead Acid of Battery	Stationary Valve Regulated Lead Acid Batteries conforming to IS:15549/2005	Stationary Lead-Acid Batteries (with tubular positive plates) in Monobloc Container conforming to IS:13369/1992, Stationary Valve Regulated Lead Acid Batteries conforming to IS:15549/2005
	Nominal Voltage of Battery (volts)	12.0 Volt	12.0 Volt
	Material of container	Polypropylene	Polypropylene, ABS
	Rated Capacity at C20 discharge (AH)	150	150
	Warranty (Years)	3 Years	3 Years
	Battery Condition	Charged	*
CONSTRUCTIONAL	Dimensions (L x W x H) (mm x mm x mm)	As per relevant IS Specifications	*
	Volume of Electrolyte (ml)	-	*
	Weight of Dry Battery (Kg) shall be as per relevant IS: Specn., corresponding Ah	Yes.	*
	No.of cells per Battery (No.)	6 Cells for 12 Volt battery	*
Certifications	Availability of Test Reports from Central Govt./NABL/ILAC accredited Lab showing conformity to the specifications	Yes	*
	Address of the Lab	-	*
	Name of the Lab	-	*
	Test Report No.	-	*
	Test Report Date	-	*

	Compulsory Registration (CRS) of BIS for safety as per IS 16046 as applicable. Secondary Cells and (Batteries containing Alkaline or other non-acid Electrolytes-Safety Requirements for Portable sealed secondary cells, and for Batteries made from them for use in portable applications	-	*
--	---	---	---

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Lakshmi L	560024, ICAR - National Bureau of Agricultural Insect Resources, P. B. No. 2491, H. A. Farm Post, Ballari Road, Hebbal, Bengaluru	3	30

Special terms and conditions for category lead acid battery

1. Battery serial number list shall be furnish by the seller along with the supply of the battery to Buyer

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
2. Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---