

Bid Document

Bid Details	
Bid End Date/Time	10-07-2020 16:00:00
Bid Opening Date/Time	2020-07-10 16:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	65 (Days)
Ministry/State Name	Ministry Of Petroleum And Natural Gas
Department Name	Na
Organisation Name	Hindustan Petroleum Corporation Ltd
Office Name	Petroleum House
Total Quantity	1
Item Category	diesel generators- DG Sets
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Advisory Bank	ICICI
ePBG Percentage(%)	10.00
Duration of ePBG required (Months).	26

(a). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Manager - Category Management

Petroleum House, NA, Hindustan Petroleum Corporation Ltd, Ministry of Petroleum and Natural Gas
(Radhika Mahto)

Splitting

Bid splitting not applied.

Diesel Generators- DG Sets (1 pieces)**Technical Specifications**

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	750	750 Or higher
	No of Phase	-	Three Phase
ENGINE	Make of Engine	-	*
	Model Number of Engine	-	*
	Capacity of Engine (cc)	-	*
	Engine Power (kWm)	-	*
	ISI Marking to IS :10001 for engine	No	*
	BIS license No, if applicable	-	*
	Type of Engine cooling	Liquid Cooled	Liquid Cooled
	Type of governer	Electronic	Electronic Or higher
	Class of governer	A1	A0, A1 Or higher
	Number of cylinders (nos)	12	*
	No of Strokes (nos)	4	*
	Rated RPM of Engine (RPM)	-	1500
	Overload capacity for one hour for every 11 hours continuous running at full load (%)	10	*

	Specific Fuel Consumption (gm/kWh)	-	*
	Starting voltage (volt)	24	*
ALTERNATOR	AC GENERATOR(ALTERNATOR) Make	-	*
	AC GENERATOR(ALTERNATOR) model Number	-	*
	Rating of AC Generator (KVA)	750	*
	Power Factor of AC generator	0.8	*
	Efficiency at rated Power factor at 75% of full Load	95	*
	Compliance of Alternator to IS:13364(part-1)	Yes	*
	Type of alternator	Brushless	*
	Voltage Regulation Grade	VG 3	*
	Alternator IP Rating	IP 23	*
	Class of Insulation	H	*
CONTROL PANEL	Control Panel	AMF	AMF
	IP Rating of Control Panel	IP 53	*
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6	1.6, 1.8, 2 Or higher
	Thickness of Foam	100	*
	Density of Foam for sound insulation	96	*
	Noise level at 1 meter (dB)	75	*
BATTERY	Battery Type & Specification	Low Maintenance free to IS: 14257 for high cranking performance	*
	Battery capacity (Ah)	-	*
	No of batteries	2	*
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Engine)	-	*
	Name and address of laboratory(Engine)	-	*

	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Alternator)	-	*
	Name and address of laboratory(Alternator)	-	*
	DG set meet requirements of Environmental(Protection) Rules 1986, in respect of noise and emission norms, as described in STC	Yes	*
WARRANTY / INSTALLATION & COMMISSIONING	Warranty	2	2.0
	Installation & Commissioning	With Installation	With Installation
	Agreed to STC of the Product	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ashok Kumar Paswan	481885,HPCL, LPG BOTTLING PLANT, MANERI INDUSTRIAL AREA, TEHSIL NIWAS, DISTT: MANDLA - 481885	1	120

Special terms and conditions for category diesel generators- DG Sets

1. In addition to General Terms and Conditions of GeM, Special T&C shall be applicable for Diesel Generating Set/DG Set. [click here to view the Special terms and conditions.](#)

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
2. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 3 days time limit. If the Seller fails to complete service

/ rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to reimburse the cost of such service / rectification to the Buyer.

3. Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of HINDUSTAN PETROLEUM CORPORATION LIMITED payable at MUMBAI. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---