

Bid Document

Bid Details	
Bid End Date/Time	23-07-2020 18:00:00
Bid Opening Date/Time	23-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	80 (Days)
Ministry/State Name	Ministry Of Power
Department Name	Na
Organisation Name	N/a
Office Name	Rec Power Distribution Company Limited
Total Quantity	1
Item Category	diesel generators- DG Sets
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Diesel Generators- DG Sets (1 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	10	10, 15, 20, 25, 30, 40, 62.5, 82.5, 100, 125, 160, 180, 200, 250, 320, 380, 400, 500, 600, 750, 50, 140, 75 Or higher
	No of Phase	-	Three Phase
ENGINE	Make of Engine	-	*
	Model Number of Engine	-	*
	Capacity of Engine (cc)	-	*
	Engine Power (kWm)	-	*
	ISI Marking to IS :10001 for engine	No	*
	BIS license No, if applicable	-	*
	Type of Engine cooling	Air Cooled	Air Cooled, Liquid Cooled
	Type of governor	Mechanical	Mechanical, Electronic Or higher
	Class of governor	A2	A0, A1, A2 Or higher
	Number of cylinders (nos)	2	*
	No of Strokes (nos)	4	*
	Rated RPM of Engine (RPM)	-	1500
	Overload capacity for one hour for every 11 hours continuous running at full load (%)	10	*
	Specific Fuel Consumption (gm/kWh)	-	*
	Starting voltage (volt)	12	*
ALTERNATOR	AC GENERATOR(ALTERNATOR) Make	-	*
	AC GENERATOR(ALTERNATOR) model Number	-	*
	Rating of AC Generator (KVA)	10	*
	Power Factor of AC generator	0.8	*
	Efficiency at rated Power factor at 75% of	84.5	*

	full Load		
	Compliance of Alternator to IS:13364(part-1)	Yes	*
	Type of alternator	Brushless	*
	Voltage Regulation Grade	VG 3	*
	Alternator IP Rating	IP 23	*
	Class of Insulation	H	*
CONTROL PANEL	Control Panel	Manual	Manual
	IP Rating of Control Panel	IP 53	*
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6	1.6, 1.8, 2 Or higher
	Thickness of Foam	20	*
	Density of Foam for sound insulation	20	*
	Noise level at 1 meter (dB)	75	*
BATTERY	Battery Type & Specification	Low Maintenance free to IS: 14257 for high cranking performance	*
	Battery capacity (Ah)	-	*
	No of batteries	1	*
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	No	*
	Test Report number and date(Engine)	-	*
	Name and address of laboratory(Engine)	-	*
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	No	*
	Test Report number and date(Alternator)	-	*
	Name and address of laboratory(Alternator)	-	*
	DG set meet requirements of Environmental(Protection) Rules 1986, in respect of noise and emission norms, as described in	Yes	*

	STC		
WARRANTY / INSTALLATION & COMMISSIONING	Warranty	1	1.0
	Installation & Commissioning	With Installation	With Installation
	Agreed to STC of the Product	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Nallam Indraneel	281001,Kishori Raman Girls Inter College, Kotwali Road, Choubey Para	1	15

Special terms and conditions for category diesel generators- DG Sets

1. In addition to General Terms and Conditions of GeM, Special T&C shall be applicable for Diesel Generating Set/DG Set. [click here to view the Special terms and conditions.](#)

Bid Specific Additional Terms and Conditions

1. Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---