

Bid Document

Bid Details	
Bid End Date/Time	20-07-2020 12:00:00
Bid Opening Date/Time	20-07-2020 12:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	80 (Days)
Ministry/State Name	Delhi
Department Name	Home Department Delhi
Organisation Name	N/a
Office Name	Tihar Jail
Total Quantity	27
Item Category	Online UPS
Bidder Turnover (Last 3 Years)	5 Lakh (s)
OEM Average Turnover (Last 3 Years)	25 Lakh (s)
Experience Criteria	1 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	50 %
Bid to RA enabled	No
Inspection Required	No
Estimated Bid Value	1458000

EMD Detail

Advisory Bank	State Bank of India
EMD Percentage(%)	3.00
EMD Amount	43740

ePBG Detail

Required	No
----------	----

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

TIHAR

Tihar Jail, Home Department Delhi, N/A,
(Dda Phq)

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

3. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Online UPS (27 pieces)**Technical Specifications**

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	Rating in KVA (KVA)	1.0 KVA	*
	Technology	IGBT-PWM with inbuilt isolation transformer	MOSFET-PWM with inbuilt isolation transformer, IGBT-PWM with inbuilt isolation transformer, IGBT-PWM without inbuilt isolation transformer
	Input Power	single phase 160V - 260V sinewave,50Hz	single phase 160V - 260V sinewave,50Hz, Three phase 300 V - 450V sinewave,50Hz
	Output power	Single phase 230V +/-1% sinewave 50 Hz	Single phase 230V +/-1% sinewave 50 Hz, 3 Phase 400V +/-1% with alternative user settable setting of 380V +/-1% 50 Hz
	Backup time (Minutes)	30	15, 30, 60, 90, 120, 180, 240, NA
	Minimum VAH (VAH)	1200	0 - 640000
	Warranty for UPS (Years)	3	1, 2, 3, 4, 5
	Movable trolley for Batteries	Without trolley but with rack	With, Without, Without trolley but with rack
	Warranty for battery	2	1, 2, NA
	Degree of Protection	IP21	IP21, IP20
	Cabling 5 meters for input and out put	Without	With, Without
	Paralleling kit for synchronising	Without	With, Without
	Installation and Commissioning	Yes	*
Constructional	Minimum thickness of M.S.Sheet Enclosure duly painted (mm)	1.2	*
	Type of Battery	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest, Stationary Cells and

			Batteries, Lead Acid type, (with tubular positive plates) conforming to IS:1651:1991 latest, NA, Lithium ion
Functional	Maximum overshoot and Under shoot of output rated voltage	4	*
	Voltage Regulation from no load to full load (%)	< / = 3%	*
	20% Overload limit for minimum 10 minutes	Yes	Yes, No, only for 5 Minutes
	Overall Efficiency (%)	> /=90%	> /=90%, > /=92%, > /=94%, > /=96%
	Total Harmonic Distortion(THD) (%)	Maximum 3%	*
	50% Overload limit for minimum 1 minutes	Yes	Yes, No, only for 3 seconds
Protection	Protection for under voltage at battery terminal at 10.5V per 12 V battery	Yes	*
	Protection of Over voltage,Short Circuit & over load at UPS output terminal	Yes	*
Metering And Indications	Digital Metering in UPS for AC Input Voltage,Output AC Voltage,Current,Frequency, Battery Voltage and Current	Yes	*
	Indicators for mains presence,Battery charging and discharging,Output Over Load, Low Battery Voltage	Yes	*
Reports And Certification	Damp Heat : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	Yes	*
	Dry Heat Test : in	Yes	*

	accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs		
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes	*
	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Pramod Kumar Mehresh N	110064,O/o the DGP, PHQ, Central Jail Tihar	27	30

Special terms and conditions for category Online UPS

1. Calculation of Minimum VAH based on Back up time Minimum VAH requirements would be calculated on the basis of following: (VAH Calculation: Battery Voltage x Battery Ah x No. of Batteries = VAH)UPS Rating15 Minutes30 Minutes60 Minutes90 Minutes120 Minutes180

Minutes240 Minutes1 KVA400 VAH800 VAH1600 VAH2400 VAH3200 VAH4800 VAH6400
VAH2 KVA800 VAH1600 VAH3200 VAH4800 VAH6400 VAH9600 VAH12800 VAH3 KVA1200
VAH2400 VAH4800 VAH7200VAH9600 VAH14400 VAH19200 VAH5 KVA2000 VAH4000
VAH8000 VAH12000 VAH16000 VAH24000 VAH32000 VAH6 KVA2400 VAH4800 VAH9600
VAH14400 VAH19200 VAH28800 VAH38400 VAH7.5 KVA3000 VAH6000 VAH12000
VAH18000 VAH24000 VAH36000 VAH48000 VAH10 KVA4000 VAH8000 VAH16000
VAH24000 VAH32000 VAH48000 VAH64000 VAH15 KVA6000 VAH12000 VAH24000
VAH36000 VAH48000 VAH72000 VAH96000 VAH20 KVA8000 VAH16000 VAH32000
VAH48000 VAH64000 VAH96000 VAH128000 VAH30 KVA12000 VAH24000 VAH48000
VAH72000 VAH96000 VAH144000 VAH192000 VAH40 KVA16000 VAH32000 VAH64000
VAH96000 VAH128000 VAH192000 VAH256000 VAH60 KVA24000 VAH48000 VAH96000
VAH144000 VAH192000 VAH288000 VAH384000 VAH80 KVA32000 VAH64000 VAH128000
VAH192000 VAH256000 VAH384000 VAH512000 VAH100 KVA40000 VAH80000 VAH160000
VAH240000 VAH320000 VAH480000 VAH640000 VAH

Bid Specific Additional Terms and Conditions

1. Provisions for workmen compensation, insurance, public liability, property damage, insurance etc. to be ensured by the contractor. Also, safety measures prescribed for working in Extra High Voltage & use of personnel protective equipment must be adhered to.
2. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.
3. ISO 9001: The bidder must have ISO 9001 certification.
4. The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.
5. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---