

### Bid Document

Bid Details	
Bid End Date/Time	25-07-2020 13:00:00
Bid Opening Date/Time	25-07-2020 13:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	80 (Days)
Ministry/State Name	Ministry Of Communications
Department Name	Department Of Posts
Organisation Name	Tamil Nadu Postal Circle Department Of Posts
Office Name	Office Of The Chief Postmaster General Tamilnadu Circle Chennai 600002
Total Quantity	3
Item Category	Online UPS
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

### Online UPS ( 3 pieces )

### Technical Specifications

\* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	<b>Rating in KVA (KVA)</b>	2.0 KVA	2.0 KVA
	<b>Technology</b>	IGBT-PWM with inbuilt isolation transformer	IGBT-PWM with inbuilt isolation transformer
	<b>Input Power</b>	single phase 160V - 260V sinewave,50Hz	single phase 160V - 260V sinewave,50Hz
	<b>Output power</b>	Single phase 230V +/-1% sinewave 50 Hz	Single phase 230V +/-1% sinewave 50 Hz
	<b>Backup time (Minutes)</b>	60	60
	<b>Minimum VAH (VAH)</b>	3200	3200
	<b>Warranty for UPS (Years)</b>	2	2
	<b>Movable trolley for Batteries</b>	With	With, Without, Without trolley but with rack
	<b>Warranty for battery</b>	2	2
	<b>Degree of Protection</b>	IP21	IP21, IP20
	<b>Cabling 5 meters for input and out put</b>	With	With, Without
	<b>Paralleling kit for synchronising</b>	With	With, Without
	Installation and Commissioning	Yes	*
Constructional	Minimum thickness of M.S.Sheet Enclosure duly painted (mm)	1.2	*
	<b>Type of Battery</b>	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)
Functional	Maximum overshoot and Under shoot of output rated voltage	4	*
	Voltage Regulation from no load to full load (%)	< / = 3%	*
	<b>20% Overload limit for minimum 10 minutes</b>	Yes	Yes
	<b>Overall Efficiency (%)</b>	>/=90%	>/=90%
	Total Harmonic Distortion(THD) (%)	Maximum 3%	*
	<b>50% Overload limit for minimum 1</b>	Yes	Yes

	<b>minutes</b>		
Protection	Protection for under voltage at battery terminal at 10.5V per 12 V battery	Yes	*
	Protection of Over voltage, Short Circuit & over load at UPS output terminal	Yes	*
Metering And Indications	Digital Metering in UPS for AC Input Voltage, Output AC Voltage, Current, Frequency, Battery Voltage and Current	Yes	*
	Indicators for mains presence, Battery charging and discharging, Output Over Load, Low Battery Voltage	Yes	*
Reports And Certification	Damp Heat : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C, two cycles of (12+12) hours each 2007)	Yes	*
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes	*
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes	*
	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*

Name of Lab	-	*
Address of Lab	-	*
As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

### Additional Specification Documents

### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ranganathan N	620001,ASPOs (HQ), Tiruchirappalli Division Tiruchirappalli 620001	3	15

### Special terms and conditions for category Online UPS

- Calculation of Minimum VAH based on Back up time Minimum VAH requirements would be calculated on the basis of following: (VAH Calculation: Battery Voltage x Battery Ah x No. of Batteries = VAH)UPS Rating15 Minutes30 Minutes60 Minutes90 Minutes120 Minutes180 Minutes240 Minutes1 KVA400 VAH800 VAH1600 VAH2400 VAH3200 VAH4800 VAH6400 VAH2 KVA800 VAH1600 VAH3200 VAH4800 VAH6400 VAH9600 VAH12800 VAH3 KVA1200 VAH2400 VAH4800 VAH7200VAH9600 VAH14400 VAH19200 VAH5 KVA2000 VAH4000 VAH8000 VAH12000 VAH16000 VAH24000 VAH32000 VAH6 KVA2400 VAH4800 VAH9600 VAH14400 VAH19200 VAH28800 VAH38400 VAH7.5 KVA3000 VAH6000 VAH12000 VAH18000 VAH24000 VAH36000 VAH48000 VAH10 KVA4000 VAH8000 VAH16000 VAH24000 VAH32000 VAH48000 VAH64000 VAH15 KVA6000 VAH12000 VAH24000 VAH36000 VAH48000 VAH72000 VAH96000 VAH20 KVA8000 VAH16000 VAH32000 VAH48000 VAH64000 VAH96000 VAH128000 VAH30 KVA12000 VAH24000 VAH48000 VAH72000 VAH96000 VAH144000 VAH192000 VAH40 KVA16000 VAH32000 VAH64000 VAH96000 VAH128000 VAH192000 VAH256000 VAH60 KVA24000 VAH48000 VAH96000 VAH144000 VAH192000 VAH288000 VAH384000 VAH80 KVA32000 VAH64000 VAH128000 VAH192000 VAH256000 VAH384000 VAH512000 VAH100 KVA40000 VAH80000 VAH160000 VAH240000 VAH320000 VAH480000 VAH640000 VAH

### Bid Specific Additional Terms and Conditions

- Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)
- Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding,

successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

3. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
4. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.
5. ISO 9001: The bidder must have ISO 9001 certification.
6. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 3 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**