

Bid Number: GEM/2020/B/700264

Dated: 07-07-2020

# **Bid Document**

Bid Document			
Bid Details			
28-07-2020 10:00:00			
28-07-2020 10:30:00			
90 (Days)			
30 (Days)			
Ministry Of Defence			
Department Of Defence			
Indian Army			
******			
1			
Online UPS			
3 Year (s)			
Yes			
Yes			
Experience Criteria *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer			
No			
No			

#### **EMD Detail**

Required	No

## ePBG Detail

Day to d	NI.
Required	No
•	

#### Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for

number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

# Online UPS (1 pieces)

## **Technical Specifications**

## \* As per GeM Category Specification

Specification	<b>Specification Name</b>	Values	Bid Requirement (Allowed Values)
Generic	Rating in KVA (KVA)	2.0 KVA	2.0 KVA
	Technology	IGBT-PWM with inbuilt isolation transformer	IGBT-PWM with inbuilt isolation transformer
	Input Power	single phase 160V - 260V sinewave,50Hz	single phase 160V - 260V sinewave,50Hz
	Output power	Single phase 230V +/-1% sinewave 50 Hz	Single phase 230V +/-1% sinewave 50 Hz
	Backup time (Minutes)	90	90
	Minimum VAH (VAH)	4800	4800
	Warranty for UPS (Years)	2	2
	Movable trolly for Batteries	Without trollery but with rack	With, Without trollery but with rack
	Warranty for battery	2	2
	Degree of Protection	IP21	IP21
	Cabling 5 meters for input and out put	With	With
	Paralleling kit for synchronising	With	With
	Installation and Commissioning	Yes	*
Constructional	Minimum thickness of M.S.Sheet Enclosure duly painted (mm)	1.2	*
	Type of Battery	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)
Functional	Maximum overshoot and Under shoot of output rated voltage	4	*
	Voltage Regulation	< / = 3%	*

	from no load to full load (%)		
	20% Overload limit for minimum 10 minutes	Yes	Yes
	Overall Efficiency (%)	>/=90%	>/=90%
	Total Harmonic Distortion(THD) (%)	Maximum 3%	*
	50% Overload limit for minimum 1 minutes	Yes	Yes
Protection	Protection for under voltage at battery terminal at 10.5V per 12 V battery	Yes	*
	Protection of Over voltage, Short Circuit & over load at UPS output terminal	Yes	*
Metering And Indications	Digital Metering in UPS for AC Input Voltage,Output AC Volt age,Current,Frequency, Battery Voltage and Current	Yes	*
	Indicators for mains presence,Battery charging and discharging,Output Over Load, Low Battery Voltage	Yes	*
Reports And Certification	Damp Heat: in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	Yes	*
	Dry Heat Test: in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes	*
	Cold Test: in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes	*

Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes	*
Type Test Certificate No.	-	*
Type Test Certificate date	-	*
Name of Lab	-	*
Address of Lab	-	*
As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

<sup>\*</sup> Specifications highlighted in bold are the Golden Parameters.

#### **Additional Specification Documents**

## **Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporti ng Officer	Address	Quantity	Delivery Days
1	******	**************************************	1	30

## Special terms and conditions for category Online UPS

1. Calculation of Minimum VAH based on Back up time Minimum VAH requirements would be calculated on the basis of following: (VAH Calculation: Battery Voltage x Battery Ah x No. of Batteries = VAH)UPS Rating15 Minutes30 Minutes60 Minutes90 Minutes120 Minutes180 Minutes240 Minutes1 KVA400 VAH800 VAH1600 VAH2400 VAH3200 VAH4800 VAH6400 VAH2 KVA800 VAH1600 VAH3200 VAH4800 VAH6400 VAH9600 VAH12800 VAH3 KVA1200 VAH2400 VAH4800 VAH7200VAH9600 VAH14400 VAH19200 VAH5 KVA2000 VAH4000 VAH8000 VAH12000 VAH16000 VAH24000 VAH32000 VAH6 KVA2400 VAH4800 VAH9600 VAH14400 VAH19200 VAH28800 VAH38400 VAH7.5 KVA3000 VAH6000 VAH12000 VAH18000 VAH24000 VAH36000 VAH48000 VAH16000 VAH12000 VAH24000 VAH32000 VAH48000 VAH64000 VAH15 KVA6000 VAH12000 VAH24000 VAH36000 VAH48000 VAH16000 VAH24000 VAH32000 VAH48000 VAH64000 VAH2000 VAH32000 VAH48000 VAH64000 VAH32000 VAH48000 VAH16000 VAH32000 VAH48000 VAH64000 VAH32000 VAH48000 VAH32000 VAH48000 VAH32000 VAH48000 VAH32000 VAH48000 VAH32000 VAH32000 VAH48000 VAH32000 VAH64000 VAH64000 VAH64000 VAH64000 VAH64000 VAH64000

<sup>\*</sup> Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

VAH192000 VAH256000 VAH384000 VAH512000 VAH100 KVA40000 VAH80000 VAH160000 VAH240000 VAH320000 VAH480000 VAH640000 VAH

# **Bid Specific Additional Terms and Conditions**

1. Successful bidder will have to ensure that adequate number of dedicated technical service personals / engineers are designated / deployed for attending to the Service Request in a time bound manner and for ensuring Timely Servicing / rectification of defects during warranty period, as per Service level agreement indicated in the relevant clause of the bid.

This Bid is also governed by the General Terms and Conditions

---Thank You---