

Bid Document

Bid Details	
Bid End Date/Time	29-06-2020 19:00:00
Bid Opening Date/Time	2020-06-29 19:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Heavy Industries And Public Enterprises
Department Name	Department Of Heavy Industry
Organisation Name	Cement Corporation Of India Limited (cci)
Office Name	Rajban Cement Factory
Total Quantity	30
Item Category	dusk to dawn controller-Sensitive switch
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Dusk To Dawn Controller-Sensitive Switch (30 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Rated Power (Watt)	15 KW	15 KW
	Ingress protection rating of enclosure (IP Rating)	IP 65	IP 65
	Warranty (Years)	2 Years	2 Years
CONSTRUCTIONAL	Sensor Technology	Lux based sensor	*
	Material of Enclosure	CRCA with 1.0 mm thickness	*
	Overall dimension (mm)	(L x W x H) MAX. 450 MM X 300 MM X 125 MM	*
FUNCTIONAL	Frequency (HZ)	50 Hz	*
	Lux level based ON/OFF Switch	YES	*
	Lux level for switching (Lux)	ON Condition: < / = 40 LUX. OFF Condition: From 80 LUX	*
	Detection angle range of Sensor (Degree)	120 degree	*
	Permanent ON Facility.	No	*
	Time Delay (Seconds)	Minimum 30 Seconds for sensing LUX level	*
	Time based ON/OFF facility	Yes	*
	User settable Dusk Time ON	No	*
	User settable Dawn Time OFF	Yes	*
	Operating Temperature range. (Deg C)	-10 degree C to +55 degree C	*
	Operating Voltage range (Volt)	230 Volt	*
CERTIFICATIONS	Availability of Test Reports from Central Govt./State Govt/NABL/IL AC accredited Lab to prove conformity to the specification	YES	*
	Test Report No	-	*
	Test Report Date	-	*
	Name of the Lab	-	*

Address of the Lab	-	*
--------------------	---	---

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Neelesh Kumar Tripathi	173029,Cement Corporation of India Ltd., Rajban Cement Factory,Distt. Sirmour(H.P.)	30	15

Bid Specific Additional Terms and Conditions

1. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
2. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
3. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---