

Bid Document

Bid Details	
Bid End Date/Time	20-07-2020 12:00:00
Bid Opening Date/Time	20-07-2020 12:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Urban Development
Department Name	Na
Organisation Name	Central Public Works Department (cpwd)
Office Name	Madhopur Central Division Nz1
Total Quantity	4
Item Category	automatic line voltage corrector or step type auto transformer
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Automatic Line Voltage Corrector Or Step Type Auto Transformer (4 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Ungrouped			
GENERIC	Conforming to IS:8448 latest	Yes	*
	Rating in KVA	4.0 KVA	4.0 KVA
	ISI Marked	No	No
	ISI Marked if Yes CM/L No. (If No write NA)	-	*
	Type of winding	Copper	Copper
	Input	single Phase Sine wave (120V-280v)	single Phase Sine wave (120V-280v)
	Display Type of Meter	Digital Volt Meter	Digital Volt Meter
CONSTRUCTIONAL	Mounting Type	Wall mounting	*
	Current rating of the Relay/contactors (Amp)	Conforming to IS:8448 latest	*
	Overall weight of ALVC (Kg)	-	*
	Provision of power supply cord / terminal as applicable for input and output as per IS:8448	Yes	*
FUNCTIONAL	Output	Single Phase sine wave (210V-250V)	*
	Overall efficiency of ALVC (%)	> / = 95%	*
	The product shall conform to the acceptance tests as per Cl. 12.1.1 of IS:8448 latest	Yes	*
CERTIFICATIONS	Availability of Type Test Report from Central Govt. /NABL/ILAC Accredited lab to prove conformity to the Specification IS:8448 latest	Yes	*
	Type Test report No.	-	*
	TTC report date	-	*
	Name of Lab	-	*

Address of Lab		-	*	
----------------	--	---	---	--

* Specifications highlighted in bold are the Golden Parameters.
 * Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Ram Dass	145024,V.P.O. Madhopur Cantt.	4	15

Bid Specific Additional Terms and Conditions

- 1.ISO 9001: The bidder must have ISO 9001 certification.
- 2.Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---