

Bid Document

Bid Details	
Bid End Date/Time	23-07-2020 17:00:00
Bid Opening Date/Time	23-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Defence
Department Name	Department Of Defence
Organisation Name	Military Engineer Services
Office Name	*****
Total Quantity	1
Item Category	Molded Case Circuit Breakers (MCCB)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Molded Case Circuit Breakers (MCCB) (1 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Governing Indian Standard specification as per IS/IEC:60947 part-2:2003 latest	YES	*
	ISI marked	NO	YES, NO
	If ISI Marked 'Yes' declare CM/L Number If 'NO' write NA	-	*
	Rated Current (in Ampere)	250A	*
	No of poles/Protected poles(PP)	4 Pole	1 Pole, 2 Pole, 3 Pole, 4 Pole
	Rated Short circuit capacity (in KA)	MCCB with RSCB capacity of 10/16/25/35 KA tripping range	MCCB with RSCB capacity 10/16 KA tripping range, MCCB with RSCB capacity of 10/16/25/35 KA tripping range
	Breaking current (in KA)	35 KA	10 KA, 16 KA, 25 KA, 35 KA
	Rated Voltage	240/415 Volt 50 Hz AC	240 Volt 50 Hz AC, 240/415 Volt 50 Hz AC
CERTIFICATIONS	Availability of Type Test Report from Central Govt./NABL/ILAC accredited lab to prove conformity to specification	YES	*
	Test Report Number (Must declare)	-	*
	Test Report Date (Must declare)	-	*
	Name of Lab (Must declare)	-	*
	Address of Test Lab (Must declare)	-	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	*****	*****EAST KHASI HILLS	1	30

Bid Specific Additional Terms and Conditions

1. ISO 9001: The bidder must have ISO 9001 certification.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---