

Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 12:00:00
Bid Opening Date/Time	27-07-2020 12:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	N/a
Office Name	Office Of The Principal Chief Materials Manager, East Coast Railway, North Block, 2nd Floor, Chandrasekharpur, Bhubaneswar-751017.
Total Quantity	5
Item Category	diesel generators- DG Sets
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Past Performance, OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	20 %
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 20% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Diesel Generators- DG Sets (5 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	5	5, 7.5, 10, 15, 20, 25, 30, 40, 62.5, 82.5, 100, 125, 160, 180, 200, 250, 320, 380, 400, 500, 600, 750, 50, 140, 75 Or higher
	No of Phase	-	Single phase
ENGINE	Make of Engine	-	*
	Model Number of Engine	-	*
	Capacity of Engine (cc)	-	*
	Engine Power (kWm)	-	*
	ISI Marking to IS :10001 for engine	No	*
	BIS license No, if applicable	-	*
	Type of Engine cooling	Air Cooled	Air Cooled
	Type of governer	Mechanical	Mechanical, Electronic Or higher
	Class of governer	A2	A0, A1, A2 Or higher
	Number of cylinders (nos)	1	*
	No of Strokes (nos)	4	*
	Rated RPM of Engine (RPM)	-	1500
	Overload capacity for one hour for every 11 hours continuous running at full load (%)	10	*
	Specific Fuel Consumption (gm/kWh)	-	*
	Starting voltage (volt)	12	*
ALTERNATOR	AC GENERATOR(ALTERNATOR) Make	-	*
	AC GENERATOR(ALTERNATOR) model Number	-	*
	Rating of AC Generator (KVA)	5	*
	Power Factor of AC generator	0.8	*
	Efficiency at rated Power factor at 75% of full Load	89	*
	Compliance of Alternator to IS:13364(part-1)	Yes	*

	Type of alternator	Brushless	*
	Voltage Regulation Grade	VG 3	*
	Alternator IP Rating	IP 23	*
	Class of Insulation	H	*
CONTROL PANEL	Control Panel	Manual	Manual
	IP Rating of Control Panel	IP 54	*
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6	1.6, 1.8, 2 Or higher
	Thickness of Foam	25	*
	Density of Foam for sound insulation	28	*
	Noise level at 1 meter (dB)	75	*
BATTERY	Battery Type & Specification	Low Maintenance free to IS: 14257 for high cranking performance	*
	Battery capacity (Ah)	-	*
	No of batteries	1	*
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Engine)	-	*
	Name and address of laboratory(Engine)	-	*
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Alternator)	-	*
	Name and address of laboratory(Alternator)	-	*
	DG set meet requirements of Environmental(Protection) Rules 1986, in respect of noise and emission norms, as described in STC	Yes	*
WARRANTY / INSTALLATION & COMMISSIONING	Warranty	1	1.0
	Installation & Commissioning	Without Installation	With Installation, Without Installation
	Agreed to STC of the Product	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Biswajit Sahu	751017,Office of the Dy. Chief Materials Manager (CRW). East Coast Railway, Chandrasekharpur, Mancheswar, Bhubaneswar. Pin-751017.	5	45

Special terms and conditions for category diesel generators- DG Sets

- 1.In addition to General Terms and Conditions of GeM, Special T&C shall be applicable for Diesel Generating Set/DG Set. [click here to view the Special terms and conditions.](#)

Bid Specific Additional Terms and Conditions

- 1.Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
- 2.Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
- 3.**Nominated Inspection Agency:** On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:
Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC): RITES
Post Receipt Inspection at consignee site before acceptance of stores: Consignee for Installation and commissioning

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---