

Bid Document

Bid Details	
Bid End Date/Time	20-07-2020 15:00:00
Bid Opening Date/Time	20-07-2020 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Madhya Pradesh
Department Name	Urban Development And Environment Department
Organisation Name	E-nagar Palika Government Of Madhya Pradesh
Office Name	Nagar Parishad Patan
Total Quantity	100
Item Category	dusk to dawn controller-Sensitive switch (PAC Only)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Dusk To Dawn Controller-Sensitive Switch (100 pieces) (Under PAC)

Make	surya
Model	hpelectronicsballast

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Rated Power (Watt)	15 KW	15 KW
	Ingress protection rating of enclosure (IP Rating)	IP 65	IP 65
	Warranty (Years)	1 Year	1 Year
CONSTRUCTIONAL	Sensor Technology	Lux based sensor	*
	Material of Enclosure	CRCA with 1.0 mm thickness	*
	Overall dimension (mm)	(L x W x H) MAX. 300 MM X 200 MM X 100 MM	*
FUNCTIONAL	Frequency (HZ)	50 Hz	*
	Lux level based ON/OFF Switch	YES	*
	Lux level for switching (Lux)	ON Condition: < / = 40 LUX. OFF Condition: From 80 LUX	*
	Detection angle range of Sensor (Degree)	120 degree	*
	Permanent ON Facility.	Yes	*
	Time Delay (Seconds)	Minimum 30 Seconds for sensing LUX level	*
	Time based ON/OFF facility	No	*
	User settable Dusk Time ON	No	*
	User settable Dawn Time OFF	No	*
	Operating Temperature range. (Deg C)	-10 degree C to +55 degree C	*
	Operating Voltage range (Volt)	230 Volt	*
CERTIFICATIONS	Availability of Test	YES	*

	Reports from Central Govt./State Govt/NABL/IL AC accredited Lab to prove conformity to the specification		
	Test Report No	589617	*
	Test Report Date	15/10/2016	*
	Name of the Lab	BALLAST TEST	*
	Address of the Lab	Padma Tower- 1, Rajendra Place, New Delhi - 110008, Delhi, India	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Sonali Bajpai	483113, WARD NO.11 NAGAR PARISHAD PATAN	100	30

Bid Specific Additional Terms and Conditions

1. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.
2. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---