

### RA Document

RA Details	
RA Technical End Date/Time	20-07-2020 11:00:00
RA Opening Date/Time	20-07-2020 11:30:00
RA Life Cycle (From Publish Date)	90 (Days)
RA Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	N/a
Office Name	Southern Railway
Total Quantity	10
Item Category	lead acid battery
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Inspection Required	No
Estimated RA Value	31250

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

RA splitting not applied.

### Lead Acid Battery ( 10 pieces )

## Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	<b>Types of Lead Acid of Battery</b>	Small sized Valve Regulated Lead -Acid Batteries (SMF) conforming to JISC: 8702/1998 (Part 1,2 & 3) with latest amendments	Small sized Valve Regulated Lead -Acid Batteries (SMF) conforming to JISC: 8702/1998 (Part 1,2 & 3) with latest amendments
	<b>Nominal Voltage of Battery (volts)</b>	12.0 Volt	12.0 Volt
	<b>Material of container</b>	Polypropylene	Polypropylene
	<b>Rated Capacity at C20 discharge (AH)</b>	42	42
	<b>Warranty (Years)</b>	3 Years	3 Years
	Battery Condition	Charged	*
CONSTRUCTIONAL	Dimensions (L x W x H) (mm x mm x mm)	As per relevant IS Specifications	*
	Volume of Electrolyte (ml)	-	*
	Weight of Dry Battery (Kg) shall be as per relevant IS: Specn., corresponding Ah	Yes.	*
	No.of cells per Battery (No.)	6 Cells for 12 Volt battery	*
Certifications	Availability of Test Reports from Central Govt./NABL/ILAC accredited Lab showing conformity to the specifications	Yes	*
	Address of the Lab	-	*
	Name of the Lab	-	*
	Test Report No.	-	*
	Test Report Date	-	*
	Compulsory Registration (CRS) of BIS for safety as per IS 16046 as applicable. Secondary Cells and (Batteries containing Alkaline or other non-acid Electrolytes-Safety	-	*

	Requirements for Portable sealed secondary cells, and for Batteries made from them for use in portable applications		
--	---	--	--

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

### Additional Specification Documents

#### Consignee/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days	
1	Gowthaman V	620001,Office of the Senior Divisional Materials Manager Southern Railway Tiruchirapalli Division Tamil nadu 620001	10	30	N/A

#### Special terms and conditions for category lead acid battery

1. Battery serial number list shall be furnish by the seller along with the supply of the battery to Buyer

#### Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This RA is also governed by the General Terms and Conditions](#)

---Thank You---