

Bid Document

Bid Details	
Bid End Date/Time	25-07-2020 17:00:00
Bid Opening Date/Time	25-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Tamil Nadu
Department Name	Higher Education Department Tamil Nadu
Organisation Name	Bharathiar University
Office Name	Tamil Nadu
Total Quantity	20
Item Category	Buy Back - Stationary lead acid batteries (with tubular positive plates) in monobloc containers
Experience Criteria	3 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

Buy Back - Stationary Lead Acid Batteries (with Tubular Positive Plates) In Monobloc Containers (20 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Scope of Buy back	Cells / Battery with buy back means exchange of one new unit with one old unit	Yes	*
Description of New Battery to be supplied by Seller	Stationary lead acid batteries (with tubular positive plates) in monobloc containers conforming to	IS: 13369/1992 with Amendment 1 ,2 and 3 latest	*
	BIS Marked	No	Yes, No
	BIS Marked if "YES" declare BIS License Number (CM/L Number). If "NO" write NA	-	*
	Battery Voltage/Capacity (in Ah) at 10 H Rate	12 V/80 Ah	12 V/80 Ah
	Material of Container	P (Plastic)	H (Hard - rubber), P (Plastic), FRP (Fibre reinforced plastic)
	Maximum overall dimension (Length x Width x Height) in mm	535 x 295 x 450 for 12 Volt upto 200 Ah	535 x 295 x 450 for 12 Volt upto 200 Ah
CONSTRUCTIONAL	Materials for Containers, Electrolyte, Sealing compouns and Separators as per Cl. 5 of IS:13369:1992 latest	Yes	*
	Manual of instructions	Yes	*

	shall be furnished as per Cl. 9 of IS:13369:1992 latest		
	Battery condition	Dry uncharged	*
	Warranty (in Years)	4	*
CERTIFICATIONS	Availability of complete and satisfactory type test Report from Central Government / NABL/ ILAC accredited laboratory to showing conformity of the Specification	Yes	*
	Test report Number	-	*
	Report date	-	*
	Name and address of Lab	-	*
	All the test reports and certificates shall furnish to the buyer/consignee on demand	Yes	*
Description of Old Battery to be given by Buyer	Old battery shall be of similar volt and Ah (with +/-15% tolerance in Ah) but need not to be of same make / brand	Yes	*
	Old battery may not be in working condition	Yes	*
	The seller will collect the old Cell/Batteries from buyer end / consignee end at its own cost either at the same time of delivery or after delivery of new cells / battery	Yes	*
	Manufacturer / Seller / Supplier should have all valid licenses as applicable and meet all Govt., instructions and guidelines / Gazette notifications update as applicable to dispose of old cells / batteries	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Selvaraj P	641046,Bharathiar University, Coimbatore 641046	20	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
2. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---