

Bid Number: GEM/2020/B/698663

Dated: 05-07-2020

Bid Document

ager, South
ion from porting xemption must er
i

EMD Detail

Required No

ePBG Detail

Required	No

Splitting

Bid splitting not applied.

Miniature Circuit Breakers (60 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without	*
	Rated Short circuit capacity (Ampere)	10000 A	*
GENERIC	Governing Indian Standard specification IS/IEC 60898-1:2002	Yes	*
	Rated Current (Ampere)	63 A	63 A
	Instantaneous Tripping Range	С	С
	Rated Voltage (Volt)	415 VOLT	415 VOLT
	No of poles/Protected poles(PP)	4 pole with 3PP	4 pole with 3PP
	ISI marking	Yes	*
	CM/L No:	-	*
	CM/L Validity up to	-	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accridiated laoratory to prove conformity to the specification for each rating.	yes	*
	Test Report number	-	*
	Date of issue of Test Report by Laboratory	-	*
	Test Report to be furnished to the buyer on demand	Yes	*

^{*} Specifications highlighted in bold are the Golden Parameters.

^{*} Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporti ng Officer	Address	Quantity	Delivery Days
1	Kanhaiya Lal Pandey	570008,O/o Deputy Chief Materials Manager, Mechanical and General Stores Depot, South Western Railway, Ashokapuram, Mysore	60	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components): Only supply of Goods

This Bid is also governed by the General Terms and Conditions

---Thank You---