

### Bid Document

Bid Details	
Bid End Date/Time	21-07-2020 11:00:00
Bid Opening Date/Time	21-07-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Agriculture And Farmers Welfare
Department Name	Department Of Agriculture Cooperation And Farmers Welfare
Organisation Name	National Seeds Corporation Limited (nsc)
Office Name	Head Office Beej Bhawan Pusa Complex New Delhi
Total Quantity	10
Item Category	lead acid battery
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

### Lead Acid Battery ( 10 pieces )

### Technical Specifications

\* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	<b>Types of Lead Acid of Battery</b>	Lead-Acid Storage Batteries for Motor Vehicles conforming to IS:7372/1995	Lead-Acid Storage Batteries for Motor Vehicles conforming to IS:7372/1995
	<b>Nominal Voltage of Battery (volts)</b>	12.0 Volt	12.0 Volt
	<b>Material of container</b>	Fibre Reinforced Plastics (FRP)	Hard Rubber, Fibre Reinforced Plastics (FRP), Polypropylene, ABS
	<b>Rated Capacity at C20 discharge (AH)</b>	100	100
	<b>Warranty (Years)</b>	1 Year	1 Year, 2 Years, 3 Years, 4 Years, 5 Years
	Battery Condition	Charged	*
CONSTRUCTIONAL	Dimensions (L x W x H) (mm x mm x mm)	As per relevant IS Specifications	*
	Volume of Electrolyte (ml)	-	*
	Weight of Dry Battery (Kg) shall be as per relevant IS: Specn., corresponding Ah	Yes.	*
	No.of cells per Battery (No.)	6 Cells for 12 Volt battery	*
Certifications	Availability of Test Reports from Central Govt./NABL/ILAC accredited Lab showing conformity to the specifications	Yes	*
	Address of the Lab	-	*
	Name of the Lab	-	*
	Test Report No.	-	*
	Test Report Date	-	*
	Compulsory Registration (CRS) of BIS for safety as per IS 16046 as applicable. Secondary Cells and (Batteries containing Alkaline or other non-acid Electrolytes-Safety Requirements for Portable sealed	-	*

	secondary cells, and for Batteries made from them for use in portable applications		
--	--	--	--

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

### Additional Specification Documents

### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Shyam Mohan Chaudhary	335705,CSF JETSAR	10	15

### Special terms and conditions for category lead acid battery

1. Battery serial number list shall be furnish by the seller along with the supply of the battery to Buyer

### Bid Specific Additional Terms and Conditions

1. Over and above the normal Warranty terms as per GeM GTC, the successful bidder / OEM shall have to provide Comprehensive Warranty during the entire Standard warranty period as per contract. : The comprehensive warranty shall be covering the following scope REPLACEMENT OF BATTERIES UNDER WARRANTY (Upload an undertaking with the bid confirming compliance by the bidder if Bidder is taking onus of this compliance. In case OEM is taking onus of this compliance, OEM undertaking is to be uploaded along with Bidder undertaking)

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---