

### Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 17:00:00
Bid Opening Date/Time	27-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Ministry Of Power
Department Name	Na
Organisation Name	N/a
Office Name	Nhpc Ltd
Total Quantity	9
Item Category	Hot and Cold Air Conditioners
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	Yes
Inspection to be carried out by Buyers own empanelled agency	Yes
Type Of Inspection	Post Dispatch
Name of the Empanelled Inspection Agency/ Authority	Board of Officers
Estimated Bid Value	360000

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

## Hot And Cold Air Conditioners ( 9 pieces )

### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
CAPACITY / GENERIC	<b>Type of Air Conditioner</b>	High wall Split AC (Hot and Cold)	High wall Split AC (Hot and Cold)
	<b>Compressor (Speed Type)</b>	Inverter (Variable Speed)	Inverter (Variable Speed)
	Air Conditioning Technology	Hot and Cold	*
	<b>Heating Mechanism</b>	Heat Pump	Heat Pump
	<b>Nominal Capacity (TR)</b>	1.5	1.5
	<b>Nominal Cooling Capacity (kcal/hr)</b>	4500 for 1.5 TR	4500 for 1.5 TR
	<b>Nominal Heating Capacity</b>	90 to 100% of Cooling Capacity	90 to 100% of Cooling Capacity
	<b>Coil Material (Evaporator)</b>	Copper	Copper
	<b>Coil Material (Condensor)</b>	Copper	Copper
	<b>Fin Material (Evaporator)</b>	Aluminium	Aluminium
	<b>Fin Material (Condensor)</b>	Aluminium	Aluminium
	<b>Eco-friendly refrigerant</b>	Yes	Yes
	Minimum Set Temperature	18	*
	Maximum Set Temperature	35	*
	<b>BEE Star Rating</b>	5	5
	Remote Control - inclusive in the scope of supply	Yes	*
	Features	Auto restart,Sleep mode,24 hour On-Off Timer,Power Saver,Turbo cool,Self clean,2-way air	*

		swing,4-way air swing,Speed settings,Humidity Control,Active carbon filter,Anti-Bacteria Filter,Cyclotron filter	
	<b>Minimum length of copper pipe and suitable connecting electrical cable for installation and commissioning - inclusive in the scope of supply</b>	5 metre	5 metre
CONFORMITY / CERTIFICATION	Conformity to Indian Standard	Generally conforming to IS 1391 latest	*
DIMENSIONS / WEIGHT	Overall Dimensions of Indoor Unit (WxHxD) - mm x mm x mm	-	*
	Overall Dimensions of Outdoor Unit (WxHxD) - mm x mm x mm	-	*
	Net Weight of Indoor Unit	-	*
	Net Weight of Outdoor Unit	-	*
WARRANTY & INSTALLATION	<b>Warranty on machine</b>	1	1.0
	<b>Warranty on Compressor</b>	10	10.0
	<b>Installation and Commissioning</b>	With Installation and Commissioning	With Installation and Commissioning

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### Additional Specification Documents

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Anup Soren	193123,Uri-II Power Station, NHPC Limited, Nowpora, Tehsil - Uri	9	30

#### Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**