

Bid Document

Bid Details	
Bid End Date/Time	25-07-2020 19:00:00
Bid Opening Date/Time	25-07-2020 19:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Uttar Pradesh
Department Name	Urban Development Department Uttar Pradesh
Organisation Name	N/a
Office Name	Nagar Palika Parishad Kairana
Total Quantity	1000
Item Category	LED Luminaire (For Road and Street Lights)
Bidder Turnover (Last 3 Years)	14 Lakh (s)
Experience Criteria	3 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	Yes
Inspection to be carried out by Buyers own empanelled agency	Yes
Type Of Inspection	Post Dispatch
Name of the Empanelled Inspection Agency/ Authority	Board of Officers
Quality Assurance Plan document	1594818825.pdf
Estimated Bid Value	2800000

EMD Detail

Advisory Bank	State Bank of India
---------------	---------------------

EMD Percentage(%)	1.50
EMD Amount	42000

ePBG Detail

Required	No
----------	----

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Nagar Palika Parishad, Kairana
nagar palika parishad kairana, Urban Development Department Uttar Pradesh, N/A,
(Executive Officer)

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

LED Luminaire (For Road And Street Lights) (1000 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	LED Luminaire conformity to IS:10322/Part 5/Section 3/2012 latest and IS: 16107 (Part 2/Sec 1):2012 latest	Yes	*

	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	Types of LED Luminaire as per the IS: 16107(Part-2/ Sec.-1)/2012	Type B	*
	Types of LED Modules as per the IS:IS: 16103(Part-2)/2012	Type 3	*
	LED Rating (in Watts)/System Wattage/Rated Power	45W	45W
	Luminaire System Efficacy (Lumen/watt)	>= 100 Lm/Watt	*
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66	*
	Warranty for free replacement (in years)	2	2, 5
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz+/-2	*
	Automatic Higher Cut off voltage above 300 volt	Yes	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor at full load	≥ 0.95	*
	Driver Efficiency (in %age) Upto 100W: ≥85%, Above 100W: >=90%	Yes	*
	Total Harmonics Distortion	≤ 10	*
	"The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl. 8 of IS:16104:2012 latest)"	Yes	*
OPTICAL	LED chip Efficacy	≥130 Lm/Watt	*
	Colour temperature	6000+/-500K	*
	Working life for LED (Minimum 50,000 burning hours as per	Yes	*

	LM-80 and LM 21 reports)		
	Colour Rendering Index(CRI)	≥ 70	*
	LED Beam Angle	≥ 120	*
	Optic lense materal (UV stabilised)	Poly carbonate lense	*
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes	*
	Junctiojn / Soldering point temperature shall not exceed 85 deg.c as per LM 80 report	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Operating temperature range	-10 deg C to +50 deg C	-20 deg. C to +50 deg. C, -10 deg C to +50 deg C, -10 deg C to +55 deg C
	Operating Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	Over Voltage protection	Yes	*
	Reverse polarity	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M Ohm	*
	The luminaire shall be protected against surges and transients (Internal)	>/=5KV	*
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes	*
CONSTRUCTIONAL	The Luminaires casing/housing (single	Yes	*

piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity		
The luminaire body must be corrosion resistant powder coated	Yes	*
All fasteners must be of stainless steel	Yes	*
Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66	*
Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,	Yes	*
Luminaires light transparency should be of Toughened glass	Yes	*
Toughened transparent glass cover thickness	>/=4 mm	*
Toughened Glass shall not get discoloured shall not suffer degradation due to heat and ageing within warranty period	Yes	*
Number of electronic control gear (power supplies)	1 No.	1 No., 2 Nos., 3 Nos., 4 Nos.
Light Source	SMD LED Chip as per LM 80/IS16106	*
Driver components shall be industrial grade or above	Yes	*
PCB shall be FR4 grade minimum 0.8 to 1.0 mm thick or more	Yes	*
The Luminaires works on single phase three	Yes	*

	wires system (Phase, Neutral and Earth)		
	Suitable connector shall be provided for LED connection between driver output and LED	Yes	*
	Length of ISI marked three core wire (shall be provided along with supply of material)	100 cm	50 cm, 100 cm
MARKING	"Manufactures Name and and brand on the aluminium die cast body "	Engraved/Embossed	*
	Manufacturer's name, model number, serial number	Yes	*
	Date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics voltage and power be marked inside of each LED luminaire unit	Yes	*
	Diameter of pole Luminaire suitable for: (upto 45W Pole OD: shall be 40mm), (>45W<120W Pole OD: Shall be 50 mm), (above 120W: OD shall be 60 mm for which luminaire is suitable	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND	*
	System must have EMI/EMC compliance as applicable (Test reports shall be furnish to the buyer / consignee on demand)	Yes	*

LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Pohoto Biological report of the LED Chip being used in the luminaire)	Yes	*
Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comlpy as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for road and street lighting shall comply with Complusory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 3): 2012 as applicable	Yes	*

	on date		
--	---------	--	--

* Specifications highlighted in bold are the Golden Parameters.
 * Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Rakesh Kumar	247774,Nagar Palika Parishad Kairana Moh. Begumpura Kairana	1000	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---