

### Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 11:00:00
Bid Opening Date/Time	27-07-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	80 (Days)
Ministry/State Name	Ministry Of Coal
Department Name	Materials Management
Organisation Name	Bharat Coking Coal Limited
Office Name	Bccl Dhanbad
Total Quantity	2450
Item Category	XLPE Cables, Category: C2-FR-LSH, for Working Voltages from 3.3 kV up to and Including 33 kV
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	Yes
Inspection Required	No
Estimated Bid Value	4229714

### EMD Detail

Advisory Bank	State Bank of India
EMD Percentage(%)	2.00
EMD Amount	84594

### ePBG Detail

Advisory Bank	State Bank of India
ePBG Percentage(%)	10.00
Duration of ePBG required (Months).	14

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

**Beneficiary:**

Public Sector Undertaking

Bccl Dhanbad, Materials Management, Bharat Coking Coal Limited, Ministry of Coal, Dhanbad - 826005.

(Bharat Coking Coal Limited)

**Splitting**

Bid splitting not applied.

**MSE Purchase Preference**

MSE Purchase Preference	Yes
-------------------------	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

### **XLPE Cables, Category: C2-FR-LSH, For Working Voltages From 3.3 KV Up To And Including 33 KV ( 2450 meter )**

**Technical Specifications**

\* [As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Crosslinked Polyethylene Insulated Thermoplastics Sheathed Cables, for Working Voltages from 3.3 kV up to and Including 33 kV conforming to	IS:7098-Part 2:2011 latest	*
	ISI Marked	Yes	*
	ISI Marked if "Yes" BIS License Number (CM/L Number) - Must declare	-	*
	Category of cable with Improved fire performance	C2 - FR-LSH	*
	<b>Types of cable</b>	Three-core armoured, screened	Single-core unscreened, unarmoured (but non-magnetic metallic tape covered), Single-core screened, unarmoured, Single-core armoured (non-magnetic) screened, Single-core armoured (non-magnetic) unscreened, Three-core armoured, screened, Three-core armoured, unscreened

	<b>Voltage Grade</b>	Earthed systems: 6.35/11 kV	Earthed systems: 1.9/3.3 kV, Earthed systems: 3.8/6.6 kV, Earthed systems: 6.35/11 kV, Earthed systems: 12.7/22 kV, Earthed systems: 19/33 kV, Unearthed system: 3.3/3.3kV, Unearthed system: 11/11kV
	<b>Armoured cables upto 11 kV Grade specified in this standard are suitable for use in mines (as per Cl. 1.3 , 4.1.1, Cl. 17.5 and Cl. 21.2.1 of IS:7098 (Part 2):2011 (If "Yes" manufacturer shall have valid BIS License for the same )</b>	Yes	Yes, No
	<b>Low temperature application (If "Yes" manufacturer shall have valid BIS License for the same )</b>	Yes	Yes, No
	<b>Conductor material (as per Cl.4 of IS:7098 (Part 2):2011 latest</b>	Aluminium	Aluminium, Plain Copper
	<b>Outer sheath (Type ST2)</b>	PVC	PVC, Polyethylene
	<b>"Nominal Cross Sectional Area of Conductor</b>	240	*
CONSTRUCTIONAL	Insulation (conforming to the requiremnt as per Table.1 of IS:7098 (Part 2):2011 latest	Cross linked polyethylene	*
	<b>Armouring</b>	Galvanized formed wires armoured	Galvanized round steel wire armoured, Galvanized formed wires armoured, Unarmoured
	<b>Cable packing type (Wound on drum) (as per Cl. 22.1 of I:7098 (Part 2):2011 latest</b>	Wooden drum	Wooden drum, Steel drum
	Identification on cable as per Cl. 21 of IS:7098 (Part 2):2011 latest	Yes	*
	Marking on cable (as per Cl. 22.2 of I:7098 (Part 2):2011 latest	Yes	*
CERTIFICATIONS	Availability of Type test report with improved fire performance category from Central government/NABL/ILAC accridiated laoratory to prove conformity to the specification	Yes	*
	Test report number - Must declare	-	*
	Report date - Must declare	-	*

Name of lab - Must declare	-	*
Address of lab - Must declare	-	*
All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### Additional Specification Documents

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Rohit Kumar	828101, Depot Officer, Central Store, Ekra, BCCL, Post Office- BANSJORA, Dhanbad, Jharkhand-828101.	2450	75

#### Bid Specific Additional Terms and Conditions

- 1.Scope of supply (Bid price to include all cost components) : Only supply of Goods
- 2.Bid reserved for Make In India products: Procurement under this bid is reserved for purchase from Class 1 local suppliers as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document 50%. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.
- 3.Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.
- 4.The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---