

Bid Document

Bid Details	
Bid End Date/Time	24-07-2020 11:00:00
Bid Opening Date/Time	24-07-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Defence
Department Name	Department Of Defence
Organisation Name	Indian Army
Office Name	*****
Total Quantity	48
Item Category	lead acid battery
Bidder Turnover (Last 3 Years)	3 Lakh (s)
OEM Average Turnover (Last 3 Years)	3 Lakh (s)
Experience Criteria	1 Year (s)
MSE Exemption for Years Of Experience and Turnover	Yes
Startup Exemption for Years Of Experience and Turnover	Yes
Document required from seller	Experience Criteria,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Advisory Bank	IDBI Bank
EMD Percentage(%)	3.00
EMD Amount	17225

ePBG Detail

Advisory Bank	IDBI Bank
---------------	-----------

ePBG Percentage(%)	10.00
Duration of ePBG required (Months).	36

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

Commandant

The Infantry School, Mhow, Department of Defence, Indian Army, Ministry of Defence
(Commandant)

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

Lead Acid Battery (48 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	Types of Lead Acid of Battery	Small sized Valve Regulated Lead -Acid Batteries (SMF)	Small sized Valve Regulated Lead -Acid Batteries (SMF)

		conforming to JISC: 8702/1998 (Part 1,2 & 3) with latest amendments	conforming to JISC: 8702/1998 (Part 1,2 & 3) with latest amendments
	Nominal Voltage of Battery (volts)	12.0 Volt	12.0 Volt
	Material of container	Polypropylene	Polypropylene
	Rated Capacity at C20 discharge (AH)	120	120
	Warranty (Years)	2 Years	2 Years
	Battery Condition	Charged	*
CONSTRUCTIONAL	Dimensions (L x W x H) (mm x mm x mm)	As per relevant IS Specifications	*
	Volume of Electrolyte (ml)	-	*
	Weight of Dry Battery (Kg) shall be as per relevant IS: Specn., corresponding Ah	Yes.	*
	No.of cells per Battery (No.)	6 Cells for 12 Volt battery	*
Certifications	Availability of Test Reports from Central Govt./NABL/ILAC accredited Lab showing conformity to the specifications	Yes	*
	Address of the Lab	-	*
	Name of the Lab	-	*
	Test Report No.	-	*
	Test Report Date	-	*
	Compulsory Registration (CRS) of BIS for safety as per IS 16046 as applicable. Secondary Cells and (Batteries containing Alkaline or other non-acid Electrolytes-Safety Requirements for Portable sealed secondary cells, and for Batteries made from them for use in portable applications	-	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	*****	*****INDORE	48	21

Special terms and conditions for category lead acid battery

1. Battery serial number list shall be furnish by the seller along with the supply of the battery to Buyer

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
2. Timely Servicing / rectification of defects during warranty period: After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 3 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the Performance Security (PBG).Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imberse the cost of such service / rectification to the Buyer.
3. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
4. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---