

### Bid Document

Bid Details	
Bid End Date/Time	24-07-2020 18:00:00
Bid Opening Date/Time	24-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	45 (Days)
Ministry/State Name	Ministry Of Power
Department Name	Hydro Power
Organisation Name	Nhdc Limited
Office Name	Omkareshwar Power Station
Total Quantity	300
Item Category	Fluorescent lamps (Fluorescent tubular lamps)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No
Estimated Bid Value	11844

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

### Fluorescent Lamps (Fluorescent Tubular Lamps) ( 300 pieces )

### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Flourescent tubular lamps conforming to IS: 2418:1977 (Part1,2,3 and 4) with latest amendments	Yes	*
	ISI Marked	Yes	*
	If ISI market 'Yes' declare CM/L No	-	*
	<b>Star rating level</b>	3 Star	3 Star, 5 Star
	<b>Rated Wattage (in Watts)</b>	36W	36W
	Rated Colour	6500 K	*
	<b>Rated Luminous flux with colour rating</b>	2425 for 36W with 6500 K	2425 for 36W with 6500 K
CONSTRUCTIONAL	Cap designation	G-13	*
	Method of starting	With starter	*
	Cathode type	Pre heated	*
	Rated life of lamp	Minimum 5000 hours	*
	"The lamp dimensions shall be as specified on the individual lamp data sheet in IS : 2418 ( Part II )-1977 with latest amendments"	Yes	*
	Marking on the lamps as per IS:2418 :1977 (Part 1) with amendments and marking requirements as per energy star requirements	Yes	*
WARRANTY	Guaranteed period of replacement	1 year	*
REPORTS AND CERTIFICATION	Flourescent tubular lamps shall pass and comply with all the acceptance test requirements as per Cl 6 1 2 of 2418 1977 (Part1) with latest amendments And seller shall furnish test reports on demand by	Yes	*

buyer/consignee		
Flourescent tubular lamps shall pass and comply with all the routine test requirements as per CI 6 1 3 of : 2418:1977 (Part1) with latest amendments And seller shall furnish test reports on demand by buyer/consignee	Yes	*
For Energy Star Level Flourescent tubular lamps shall comply with Gazeetee notification No. S.0.178(E) dated 16th January, 2009, S.0.179(E) dated 16th January, 2009, No.2/11(5)/03-BEE.-1 dated 6th July, 2009, Amdt., No.2/11(5)/03-BEE-1 dated 5th January, 2010	Yes	*
Availability of Type Test Report from Central Govt./NABL/ILAC accredited lab to prove conformity to IS specifications as applicable. Test reports shall furnish on demand by buyer/consignee	Yes	*
Test Report Number	-	*
Test Report Date	-	*
Name of Lab	-	*
Address of Lab	-	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### Additional Specification Documents

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Akhilesh Patidar	450554,NHDC Ltd. Admin Block, Urja Vihar, Siddhwarkut, Distt - Khandwa, Madhya Pradesh	300	15

### **Bid Specific Additional Terms and Conditions**

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**