

### Bid Document

| Bid Details  |   |
|--|---|
| Bid End Date/Time                                      | 20-07-2020 19:00:00   |
| Bid Opening Date/Time                                  | 20-07-2020 19:30:00   |
| Bid Life Cycle (From Publish Date)                     | 90 (Days)   |
| Bid Offer Validity (From End Date)                     | 75 (Days)   |
| Ministry/State Name                                    | Ministry Of Science And Technology  |
| Department Name  | Department Of Scientific And Industrial Research (dsir)   |
| Organisation Name                                      | Council Of Scientific And Industrial Research (csir)  |
| Office Name  | Central Institute Of Mining And Fuel Research, Dhanbad  |
| Total Quantity   | 1   |
| Item Category  | Online UPS  |
| MSE Exemption for Years of Experience and Turnover     | No  |
| Startup Exemption for Years of Experience and Turnover | No  |
| Document required from seller                          | Experience Criteria,OEM Authorization Certificate<br>*In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |
| Bid to RA enabled                                      | No  |
| Inspection Required                                    | No  |

### EMD Detail

|          |    |
|----------|----|
| Required | No |
|----------|----|

### ePBG Detail

|          |    |
|----------|----|
| Required | No |
|----------|----|

### Splitting

Bid splitting not applied.

**Online UPS ( 1 pieces )****Technical Specifications**

[\\* As per GeM Category Specification](#)

| Specification  | Specification Name   | Values  | Bid Requirement (Allowed Values)              |
|----------------|--|---|---|
| Generic        | <b>Rating in KVA (KVA)</b>                                 | 7.5 KVA                                       | 7.5 KVA                                       |
|                | <b>Technology</b>  | IGBT-PWM with inbuilt isolation transformer   | IGBT-PWM with inbuilt isolation transformer   |
|                | <b>Input Power</b>   | single phase 160V - 260V sinewave,50Hz        | single phase 160V - 260V sinewave,50Hz        |
|                | <b>Output power</b>  | Single phase 230V +/-1% sinewave 50 Hz        | Single phase 230V +/-1% sinewave 50 Hz        |
|                | <b>Backup time (Minutes)</b>                               | 30  | 30  |
|                | <b>Minimum VAH (VAH)</b>                                   | 8064  | 8064  |
|                | <b>Warranty for UPS (Years)</b>                            | 2   | 2   |
|                | <b>Movable trolley for Batteries</b>                       | Without trolley but with rack                 | With, Without, Without trolley but with rack  |
|                | <b>Warranty for battery</b>                                | 2   | 2   |
|                | <b>Degree of Protection</b>                                | IP20  | IP20  |
|                | <b>Cabling 5 meters for input and out put</b>              | Without                                       | With, Without                                 |
|                | <b>Paralleling kit for synchronising</b>                   | Without                                       | With, Without                                 |
|                | Installation and Commissioning                             | Yes   | *   |
| Constructional | Minimum thickness of M.S.Sheet Enclosure duly painted (mm) | 1.2   | *   |
|                | <b>Type of Battery</b>                                     | SMF-VRLA conforming to JISC:8702(Pt.I,II&III) | SMF-VRLA conforming to JISC:8702(Pt.I,II&III) |
| Functional     | Maximum overshoot and Under shoot of output rated voltage  | 4   | *   |
|                | Voltage Regulation from no load to full load (%)           | < / = 3%                                      | *   |
|                | <b>20% Overload limit for minimum 10 minutes</b>           | Yes   | Yes   |
|                | <b>Overall Efficiency (%)</b>                              | >/=90%  | >/=90%  |

|                           |   |            |     |
|---------------------------|---|------------|-----|
|                           | Total Harmonic Distortion(THD) (%)  | Maximum 3% | *   |
|                           | <b>50% Overload limit for minimum 1 minutes</b>   | Yes        | Yes |
| Protection                | Protection for under voltage at battery terminal at 10.5V per 12 V battery  | Yes        | *   |
|                           | Protection of Over voltage,Short Circuit & over load at UPS output terminal   | Yes        | *   |
| Metering And Indications  | Digital Metering in UPS for AC Input Voltage,Output AC Voltage,Current,Frequency, Battery Voltage and Current                 | Yes        | *   |
|                           | Indicators for mains presence,Battery charging and discharging,Output Over Load, Low Battery Voltage                          | Yes        | *   |
| Reports And Certification | Damp Heat : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007) | Yes        | *   |
|                           | Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs                     | Yes        | *   |
|                           | Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.                        | Yes        | *   |
|                           | Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.        | Yes        | *   |
|                           | Type Test Certificate   | -          | *   |

|   |     |   |
|---|-----|---|
| No.   |     |   |
| Type Test Certificate date  | -   | * |
| Name of Lab   | -   | * |
| Address of Lab  | -   | * |
| As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable | Yes | * |

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

### Additional Specification Documents

### Consignees/Reporting Officer and Quantity

| S.No. | Consignee/Reporting Officer | Address  | Quantity | Delivery Days |
|-------|-----------------------------|--|----------|---------------|
| 1     | Partho Biswapati Choudhury  | 440001,17/C TELENKHEDI AREA, CIVIL LINE, NAGPUR-440001 | 1        | 30            |

### Special terms and conditions for category Online UPS

1. Calculation of Minimum VAH based on Back up time Minimum VAH requirements would be calculated on the basis of following: (VAH Calculation: Battery Voltage x Battery Ah x No. of Batteries = VAH)UPS Rating15 Minutes30 Minutes60 Minutes90 Minutes120 Minutes180 Minutes240 Minutes1 KVA400 VAH800 VAH1600 VAH2400 VAH3200 VAH4800 VAH6400 VAH2 KVA800 VAH1600 VAH3200 VAH4800 VAH6400 VAH9600 VAH12800 VAH3 KVA1200 VAH2400 VAH4800 VAH7200VAH9600 VAH14400 VAH19200 VAH5 KVA2000 VAH4000 VAH8000 VAH12000 VAH16000 VAH24000 VAH32000 VAH6 KVA2400 VAH4800 VAH9600 VAH14400 VAH19200 VAH28800 VAH38400 VAH7.5 KVA3000 VAH6000 VAH12000 VAH18000 VAH24000 VAH36000 VAH48000 VAH10 KVA4000 VAH8000 VAH16000 VAH24000 VAH32000 VAH48000 VAH64000 VAH15 KVA6000 VAH12000 VAH24000 VAH36000 VAH48000 VAH72000 VAH96000 VAH20 KVA8000 VAH16000 VAH32000 VAH48000 VAH64000 VAH96000 VAH128000 VAH30 KVA12000 VAH24000 VAH48000 VAH72000 VAH96000 VAH144000 VAH192000 VAH40 KVA16000 VAH32000 VAH64000 VAH96000 VAH128000 VAH192000 VAH256000 VAH60 KVA24000 VAH48000 VAH96000 VAH144000 VAH192000 VAH288000 VAH384000 VAH80 KVA32000 VAH64000 VAH128000 VAH192000 VAH256000 VAH384000 VAH512000 VAH100 KVA40000 VAH80000 VAH160000 VAH240000 VAH320000 VAH480000 VAH640000 VAH

### Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**