

Bid Document

Bid Details	
Bid End Date/Time	29-06-2020 11:00:00
Bid Opening Date/Time	2020-06-29 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Ministry Of Power
Department Name	Na
Organisation Name	N/a
Office Name	Bhakra Beas Management Board, Chandigarh
Total Quantity	4
Item Category	Switch Fuse Unit
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Estimated Bid Value	20000

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Switch Fuse Unit (4 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Conformity to the specification	as per IS/IEC:60947-3:1999 latest	*
	Whether product ISI Marked (Select 2 for ISI Marked product, Select 1 for Non ISI Marked product)	1	2, 1 Or higher
	BIS License Number (CM/L Number) - Must declare (If Non ISI Marked write N/A)	-	*
	Switch Fue Unit contains	Enclosure with door,Fuse units- Rewirable,Terminals,Contactors,Operating handle	Enclosure with door, Fuse units- Rewirable, Terminals, Contactors, Operating handle
	Utilisation category	AC-23A	AC-23A
	Warranty (in Years)	1	1
RATINGS	Rated operational Voltage (in Volt)	415	415
	Rated frequency (in Hz)	50	50
	Number of Pole	4 Pole	3 Pole and Neutral, 4 Pole
	Current rating (in Ampere)	100	100
	Rated Insulation voltage (in Volt)	440	440
	Rated impulse withstand voltage (in KV)	4	4
	Rated short circuit breaking capacity, Minimum (in KA, r.m.s.)	10	10
CONSTRUCTION	Type of enclosure	Surface Mounted	*
	Material of enclosure	CRCA Sheet, 2 mm thick	*
	Knock-outs at enclosure cable entry	Top and bottom	*
	Mounting holes for fixing the enclosure	Yes	*
	Door interlocking facility	Yes	*

	Degree of protection	IP54	IP54
	Mechanical Endurance, Minimum (in No.of cycles)	10000	10000
	Fixing accessories for mounting of enclosures	Yes	Yes
FUSE UNIT	Type of fuse	Rewirable Porcelain Fuse units	*
	Material of terminals	Silver Plated	*
	Material of contactors	Electrolytic copper	*
CERTIFICATIONS	Availability of Type test report from Central Government/NABL/ILAC accredited laoratory to prove conformity to the specification	Yes	*
	Test report number and date - Must declare	-	*
	Name of lab and address - Must declare	-	*
	Agreed to furnish all the test reports and certificates r to the buyer/consignee on demand	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Arun Kumar Nanda	140123,SUB DIVISIONAL OFFICER S&T SUB DIVISION BBMB Ganguwal Teh ANANDPUR SAHIB DISTT ROPAR PUNJAB	4	45

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods
2. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---