

Bid Document

Bid Details	
Bid End Date/Time	18-07-2020 16:00:00
Bid Opening Date/Time	18-07-2020 16:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	N/a
Office Name	Central Railway Hq Stores Deptt.
Total Quantity	50
Item Category	Sluice Valves
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Sluice Valves (50 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
CONFORMITY / CERTIFICATION	Conformity to Indian Standard	IS: 14846 - latest	*
	ISI Marking to IS 14846	No	No
	If ISI marked, CML No	-	*
	Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification	No	No
	Test Report No and Date	-	*
	Name and Address of the Lab	-	*
SIZE / DIMENSIONAL / MATERIAL	Material of Body and Bonnet	Grey Cast Iron, Gr-FG 200 of IS: 210 - latest	Grey Cast Iron, Gr-FG 200 of IS: 210 - latest
	Material of Body seat ring, wedge facing ring and bushes	Leaded tin bronze, Gr-LTB - 2 of IS: 318	Leaded tin bronze, Gr-LTB - 2 of IS: 318
	Material of Stem	High Tensile Brass, Gr-HT2 of IS: 320 or Gr-FHTB 2 of IS: 6912	High Tensile Brass, Gr-HT2 of IS: 320 or Gr-FHTB 2 of IS: 6912
	Material of Hand Wheel	Grey Cast Iron, Gr-FG 200 of IS: 210 - latest	Grey Cast Iron, Gr-FG 200 of IS: 210 - latest
	Nominal Pressure Rating	PN 1.6	PN 1.6
	Nominal Size of Valve	65	65
	Type of Valve Ends	Flanged	*
	Coating	As per Clause 9.1 and 9.2 of IS: 14846	*
	Test Pressure for leak testing of Body	2.4 Mpa for PN 1.6 Rating	2.4 Mpa for PN 1.6 Rating
	Test Pressure for leak testing of Seat	1.6 Mpa for PN 1.6 Rating	1.6 Mpa for PN 1.6 Rating
	Compliance to Flaw detection / Liquid Penetrant Test for Stems as per Clause 10-2 of IS: 14846	Yes	*
	Accessories inclusive in the scope of	Locking Arrangement for Hand Wheel	Locking Arrangement for Hand Wheel

	supply		
	Overall Weight	7	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Vishnu Kumar Mata Prasad Awasthi	421301,ELECTRIC LOCO SHED CENTRAL RAILWAY WALDHUNI KALYAN	50	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---