

Bid Document

Bid Details	
Bid End Date/Time	18-07-2020 18:00:00
Bid Opening Date/Time	18-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Telangana
Department Name	Health Medical & Family Welfare Department Telangana
Organisation Name	Tsmsidc
Office Name	Directorate Of Treasuries
Total Quantity	15
Item Category	Line Interactive UPS with AVR (PAC Only)
Experience Criteria	2 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	50 %
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 50% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Line Interactive UPS With AVR (15 pieces) (Under PAC)

Make	apc
Model	apcbx600c-in

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Rating in KVA/ min VAH capacity of battery (KVA/VAH)	0.6/84	0.6/84
	Technology	MOSFET-PWM	MOSFET-PWM, IGBT-PWM
	Type of battery	SMF-VRLA confirming to JISC-8702 Pt 1,2 &3	SMF-VRLA confirming to JISC-8702 Pt 1,2 &3
	Rated Output (Volt)	Single Phase Quasi-Sin-wave 230 V AC, 50 Hz	Single phase sinewave 230v AC , 50Hz, Single Phase Quasi-Sin-wave 230 V AC, 50 Hz
	Degree of protection	IP 20	IP 20
	Inverter Efficiency (%)	> / = 70%	> / = 60%, > / = 70%
	Warranty for the battery from the date of delivery	1 year	1 year

	Warranty for Line Interactive UPS	3 Years	3 Years
	Installation and commissioning instructions	Yes	*
CONSTRUCTIONAL	Type of enclosure	ABS	*
	AC out put for printer (not through inverter)	No	No
	Inverter out put socket AC out put for printer (not through inverter)	3 Three pin	3 Three pin
FUNCTIONAL	Total harmonic distortion (%)	< / = 40%	*
	Input (Volt)	Single phase sinewave(160-280v)	*
	Switching over time (Mili sec)	Maximum 10 milli seconds	*
	Overload Time (Minutes)	> / = 5 minutes	> / = 5 minutes
	Load power factor	> / = 0.6	> / = 0.6
	Variation in AVR output in AC mode (%) AVR (Voltage regulation) output voltage in AC Mode	230 Volts +/-15%, 50 +/-3 Hz	230 Volts +/-15%, 50 +/-3 Hz
	Overload (%)	> /=10%	*
	Variation in output voltage in battery mode (%) (UPS output voltage in battery mode)	230 Volts +/- 10%	*
	Variation on output frequency in battery mode (Hz)	< /=0.5	*
PROTECTION	Protection against (over discharge) discharge per 12v battery (Volt)	10.5	*
	Protection for outside input voltage range: If Input voltage goes outside the range 160 to 280 Volts, the system shall switch over to battery mode	Yes	*
	Protection against short circuit of UPS	Yes	*

	Protection for over voltage and over load	Yes	*
REPORTS AND CERTIFICATIONS	Damp heat Test at 45 degree , RH -95% for 2-cycle as per IS:9000 pt-5/sec-1	Yes	*
	Dry heat Test at 45 degree for 16 Hrs as per IS:9000 pt-3/sec-5	Yes	*
	Cold Test as per IS:9000 pt-2/sec-4	Yes	*
	Availability of the type test report from central Govt./NABL/ILAC Accredited Lab	Yes	*
	Type Test certificate no. and date	R-83000450, 14/06/17	*
	Name Of Lab	Schneider Electric	*
	Address of Lab	Uttarakhand 263153	*
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	D Devdas	500095, The Managing Director, TSMSIDC , 3rd Floor, DM & HS Campus, Sulthan Bazaar, Koti-500095	15	15

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
2. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---