

Bid Document

Bid Details	
Bid End Date/Time	22-07-2020 20:00:00
Bid Opening Date/Time	22-07-2020 20:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Jharkhand
Department Name	Revenue Registration And Land Reforms Department Jharkhand
Organisation Name	N/a
Office Name	Nagar Untari Garhwa
Total Quantity	120
Item Category	lighting pole or post and hardware- tubular street light poles
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

**Lighting Pole Or Post And Hardware- Tubular Street Light Poles (120
meter)**

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Tubular steel poles shall be conforming to IS 2713/80(Part-1& 2) with amdt No-1 latest	Yes	*
	Designation of Tubular steel poles as per table 2 of IS 2713/80 Part-2 with amdt No 1	410SP-4	410SP-4
	Length of Tubular steel poles (Metre)	7	7
	Coating on the tubular steel poles	Galvanised min. Mass of Zinc coating 360 Gms. sq. Mtr.	Galvanised min. Mass of Zinc coating 360 Gms. sq. Mtr.
	BIS Marked	No	No
	If Yes, Declare BIS License Number, If No Write Not Applicable	-	*
CONSTRUCTIONAL	Type of steel poles	Swaged (SP)	*
	Finials , Base plates and taper plug shall be as per clause 15 of IS 2713(Part-1)/1980	YES	*
	Grade of steel tube, as per IS:1161/1998	YST 240	*
CERTIFICATIONS	Availability of Type Test Reports of the product from Central Govt/NABL/ILAC accredited Lab showing compliance to the specification	YES	*
	Test Reports No.	-	*
	Test Reports Date	-	*
	Name of the Labs	-	*
	Test report and approvals to be furnished to the buyer on demand.	YES	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Nikhil Kiran	822114,EXECUTIVE OFFICER NAGAR PANCHAYAT NAGARUNTARI	120	30

Bid Specific Additional Terms and Conditions

1. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
2. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
3. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---