

Bid Document

Bid Details	
Bid End Date/Time	20-07-2020 11:00:00
Bid Opening Date/Time	20-07-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Ministry Of Power
Department Name	Na
Organisation Name	N/a
Office Name	It&c Division, Nhpc Office Complex, Sector-33, Faridabad - 121003 (haryana)
Total Quantity	150
Item Category	Buy Back - Small Sized Valve Regulated Lead Acid Batteries
Experience Criteria	1 Year (s)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

Buy Back - Small Sized Valve Regulated Lead Acid Batteries (150 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Scope of Buy back	Cells / Battery with buy back means exchange of one new unit with one old unit	Yes	*
Description of New Battery to be supplied by Seller	Small sized valve regulated lead acid battery conforming to IS: JISC:8702-1:2009 latest, JISC:8702-2:2003 latest and JISC:8702-3:2003 latest	Yes	*
	Classification	Prismatic	*
	Battery Voltage/Battery Capacity (in Ah) at 20 h rate/Type designation	12V/7.0 Ah/12P70	12V/7.0 Ah/12P70
	Material of Container	Acrylonitrile butadiene styrene (ABS)	*
	Battery supply condition	Factory Charged Condition	*
CONSTRUCTIONAL	Battery shall pass General requirements, capacity , High rate discharge, Endurance in cycle, charge retention, endurance in trickle application, gas recombination, resistance to vibration, resistance to shocks,	Yes	*

	maximum permissible current as per JISC:8702-1:2009, JISC:8702-2 and 3 :2003 and latest		
	Dimensions, terminals and marking as per JISC:8702-2:2003 latest	Yes	*
	Mass as per JISC:8702-2:2003 latest	Yes	*
	Instructions/Manuals shall be furnished for recommended charging voltage, charging current, capacity at other discharge rates, battery mass, month and year of manufacturer, supplier name and / or trade mark etc, and other instructions shall be supplied with the battery	Yes	*
	Warranty (in Years)	1	1
CERTIFICATIONS	Availability of complete and satisfactory type test Report from Central Government / NABL/ ILAC accredited laboratory to showing conformity of the Specification	Yes	*
	All the test reports and certificates shall furnish to the buyer/consignee on demand	Yes	*
Description of Old Battery to be given by Buyer	Old battery shall be of similar volt and Ah (with +/-15% tolerance in Ah) but need not to be of same make / brand	Yes	*
	Old battery may not be in working condition	Yes	*
	The seller will collect the old Cell/Batteries from buyer end / consignee end at its own cost either at the same time of delivery or after delivery of new cells / battery	Yes	*

	Manufacturer / Seller / Supplier should have all valid licenses as applicable and meet all Govt , , instructions and guidelines / Gazette notifications update as applicable to dispose of old cells / batteries	Yes	*
--	--	-----	---

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Laxmi Kant	121003,NHPC OFFICE COMPLEX SECTOR-33 FARIDABAD	150	15

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---