

Bid Document

Bid Details	
Bid End Date/Time	27-07-2020 11:00:00
Bid Opening Date/Time	27-07-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	50 (Days)
Ministry/State Name	Uttar Pradesh
Department Name	Medical Health And Family Welfare Department Uttar Pradesh
Organisation Name	N/a
Office Name	Lucknow Hq
Total Quantity	3
Item Category	Line Intractive UPS with AVR
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Line Intractive UPS With AVR (3 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Rating in KVA/ min VAH capacity of battery (KVA/VAH)	1.0/168	1.0/168
	Technology	MOSFET-PWM	MOSFET-PWM
	Type of battery	SMF-VRLA confirming to JISC-8702 Pt 1,2 &3	SMF-VRLA confirming to JISC-8702 Pt 1,2 &3
	Rated Output (Volt)	Single phase sinewave 230v AC , 50Hz	Single phase sinewave 230v AC , 50Hz
	Degree of protection	IP 20	IP 20
	Inverter Efficiency (%)	> / = 70%	> / = 70%
	Warranty for the battery from the date of delivery	1 year	1 year
	Warranty for Line Interactive UPS	1 Year	1 Year
	Installation and commissioning instructions	No	*
CONSTRUCTIONAL	Type of enclosure	ABS	*
	AC out put for printer (not through inverter)	No	No
	Inverter out put socket AC out put for printer (not through inverter)	3 Three pin	3 Three pin
FUNCTIONAL	Total harmonic distorsion (%)	< / = 40%	*
	Input (Volt)	Single phase sinewave(160-280v)	*
	Switching over time (Mili sec)	Maximum 10 milli seconds	*
	Overload Time (Minutes)	> / = 10 minutes	> / = 10 minutes
	Load power factor	> / = 0.6	> / = 0.6
	Variation in AVR output in AC mode (%) AVR (Voltage regulation) output voltage in AC Mode	230 Volts +/-9%, 50 +/-3 Hz	230 Volts +/-9%, 50 +/-3 Hz
	Overload (%)	> /=10%	*
	Variation in output voltage in battery mode (%) (UPS output voltage in battery mode)	230 Volts +/- 10%	*
	Variation on output frequency in battery mode (Hz)	< /=0.5	*
PROTECTION	Protection against (over discharge) discharge per 12v battery (Volt)	10.5	*
	Protection for outside input voltage range: If Input voltage goes outside the range 160 to 280 Volts, the system shall switch over to battery mode	Yes	*

REPORTS AND CERTIFICATIONS	Protection against short circuit of UPS	Yes	*
	Protection for over voltage and over load	Yes	*
	Damp heat Test at 45 degree , RH -95% for 2-cycle as per IS:9000 pt-5/sec-1	Yes	*
	Dry heat Test at 45 degree for 16 Hrs as per IS:9000 pt-3/sec-5	Yes	*
	Cold Test as per IS:9000 pt-2/sec-4	Yes	*
	Availability of the type test report from central Govt./NABL/ILAC Accredited Lab	Yes	*
	Type Test certificate no. and date	-	*
	Name Of Lab	-	*
	Address of Lab	-	*
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Shariq UI Islam	226010,SUDA Bhawan, 7/23, Sector-7, Gomtinagar Extension, Lucknow-226010	3	15

Bid Specific Additional Terms and Conditions

- 1.Upload Manufacturer authorization:** Wherever Authorised Distributors are submitting the bid, Manufacturers Authorisation Form (MAF)/Certificate with OEM details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid.
- 2.Scope of supply (Bid price to include all cost components) :** Supply Installation Testing and Commissioning of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---