

Bid Document

Bid Details	
Bid End Date/Time	20-07-2020 09:00:00
Bid Opening Date/Time	20-07-2020 09:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Uttar Pradesh
Department Name	Urban Development Department Uttar Pradesh
Organisation Name	E-municipalities - Eservices To Citizens And Employees Of Urban Local Bodies Of Uttar Pradesh
Office Name	Nagar Panchayat Pinhat Agra
Total Quantity	1
Item Category	diesel generators- DG Sets
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	10 %
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 10% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

Diesel Generators- DG Sets (1 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (KVA)	10	10, 15, 20, 25, 30, 40, 62.5, 82.5, 100, 125, 160, 180, 200, 250, 320, 380, 400, 500, 600, 750, 50, 140, 75 Or higher
	No of Phase	-	Single phase
ENGINE	Make of Engine	-	*
	Model Number of Engine	-	*
	Capacity of Engine (cc)	-	*
	Engine Power (kWm)	-	*
	ISI Marking to IS :10001 for engine	Yes	*
	BIS license No, if applicable	-	*
	Type of Engine cooling	Liquid Cooled	Liquid Cooled
	Type of governer	Mechanical	Mechanical, Electronic Or higher
	Class of governer	A1	A0, A1 Or higher
	Number of cylinders (nos)	2	*
	No of Strokes (nos)	4	*
	Rated RPM of Engine (RPM)	-	1500
	Overload capacity for one hour for every 11	10	*

	hours continuous running at full load (%)		
	Specific Fuel Consumption (gm/kWh)	-	*
	Starting voltage (volt)	12	*
ALTERNATOR	AC GENERATOR(ALTERNATOR) Make	-	*
	AC GENERATOR(ALTERNATOR) model Number	-	*
	Rating of AC Generator (KVA)	10	*
	Power Factor of AC generator	0.8	*
	Efficiency at rated Power factor at 75% of full Load	93	*
	Compliance of Alternator to IS:13364(part-1)	Yes	*
	Type of alternator	Brushless	*
	Voltage Regulation Grade	VG 3	*
	Alternator IP Rating	IP 23	*
	Class of Insulation	H	*
CONTROL PANEL	Control Panel	AMF	AMF
	IP Rating of Control Panel	IP 53	*
ACOUSTIC ENCLOSURE	Sheet Thickness	1.6	1.6, 1.8, 2 Or higher
	Thickness of Foam	25	*
	Density of Foam for sound insulation	28	*
	Noise level at 1 meter (dB)	73	*
BATTERY	Battery Type & Specification	Low Maintenance free to IS: 14257 for high cranking performance	*
	Battery capacity (Ah)	-	*
	No of batteries	1	*
TEST REPORTS	Availability of Type test report for Engine from Central govt/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Engine)	-	*

	Name and address of laboratory(Engine)	-	*
	Availability of Type test report for Alternator from Central government/NABL/ILAC accredited laboratory	Yes	*
	Test Report number and date(Alternator)	-	*
	Name and address of laboratory(Alternator)	-	*
	DG set meet requirements of Environmental(Protection) Rules 1986, in respect of noise and emission norms, as described in STC	Yes	*
WARRANTY / INSTALLATION & COMMISSIONING	Warranty	2	2.0
	Installation & Commissioning	With Installation	With Installation
	Agreed to STC of the Product	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Sandeep Kumar Sonkar	283123,nagar panchayat pinhat agra	1	30

Special terms and conditions for category diesel generators- DG Sets

1. In addition to General Terms and Conditions of GeM, Special T&C shall be applicable for Diesel Generating Set/DG Set. [click here to view the Special terms and conditions.](#)

Bid Specific Additional Terms and Conditions

1. SLBR52
2. Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER): Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with

Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---