

Bid Document

Bid Details	
Bid End Date/Time	20-07-2020 15:00:00
Bid Opening Date/Time	20-07-2020 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Madhya Pradesh
Department Name	Urban Development And Environment Department
Organisation Name	E-nagar Palika Government Of Madhya Pradesh
Office Name	Nagar Parishad Patan
Total Quantity	300
Item Category	Fluorescent lamps (Fluorescent tubular lamps) (PAC Only)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Fluorescent Lamps (Fluorescent Tubular Lamps) (300 pieces) (Under PAC)

Make	surya
Model	t5

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Flourescent tubular lamps conforming to IS: 2418:1977 (Part1,2,3 and 4) with latest amendments	Yes	*
	ISI Marked	Yes	*
	If ISI market 'Yes' declare CM/L No	8902261015873	*
	Star rating level	5 Star	5 Star
	Rated Wattage (in Watts)	36W HL	36W HL
	Rated Colour	6500 K	*
	Rated Luminous flux with colour rating	2425 for 36W with 6500 K	2425 for 36W with 6500 K
CONSTRUCTIONAL	Cap designation	G-13	*
	Method of starting	With starter	*
	Cathode type	Pre heated	*
	Rated life of lamp	Minimum 5000 hours	*
	"The lamp dimensions shall he as speciied on the individual lamp data sheet in IS : 2418 (Part II)-1977 with latest amendments"	Yes	*
	Marking on the lamps as per IS:2418 :1977 (Part 1) with amendments and marking requirements as per energy star requirements	Yes	*
WARRANTY	Guaranteed period of replacement	1 year	*

REPORTS AND CERTIFICATION	Flourescent tubular lamps shall pass and comply with all the acceptance test requirements as per CI 6 1 2 of 2418 1977 (Part1) with latest amendments And seller shall furnish test reports on demand by buyer/consingee	Yes	*
	Flourescent tubular lamps shall pass and comply with all the routine test requirements as per CI 6 1 3 of : 2418:1977 (Part1) with latest amendments And seller shall furnish test reports on demand by buyer/consingee	Yes	*
	For Energy Star Level Flourescent tubular lamps shall comply with Gazeetee notification No. S.0.178(E) dated 16th January, 2009, S.0.179(E) dated 16th January, 2009, No.2/11(5)/03-BEE.-1 dated 6th July, 2009, Amdt., No.2/11(5)/03-BEE-1 dated 5th January, 2010	Yes	*
	Availability of Type Test Report from Central Govt./NABL/ILAC accredited lab to prove conformity to IS specifications as appliacable. Test reports shall furnish on demand by buyer/consignee	Yes	*
	Test Report Number	T-3615	*
	Test Report Date	14/10/2017	*
	Name of Lab	SURYA LAB	*
	Address of Lab	POLT. NO. B IND AREA PIPALSANA NAINITAL	*

UTTARAKHAND

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Sonali Bajpai	483113, WARD NO.11 NAGAR PARISHAD PATAN	300	30

Bid Specific Additional Terms and Conditions

1. IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---