

Bid Document

Bid Details	
Bid End Date/Time	28-07-2020 11:00:00
Bid Opening Date/Time	28-07-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Uttar Pradesh
Department Name	Urban Development Department Uttar Pradesh
Organisation Name	E-municipalities - Eservices To Citizens And Employees Of Urban Local Bodies Of Uttar Pradesh
Office Name	Ramkola
Total Quantity	100
Item Category	LED Luminaire (For Road and Street Lights)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	80 %
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Advisory Bank	State Bank of India
EMD Percentage(%)	2.00
EMD Amount	13496

ePBG Detail

Required	No
----------	----

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

Beneficiary:

CLERK

Ramkola, Urban Development Department Uttar Pradesh, e-Municipalities - eServices to citizens and Employees of Urban Local Bodies of Uttar Pradesh ,
(Vindhyachal)

Splitting

Bid splitting not applied.

1. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one year) to be submitted along with bid in support of quantity supplied in the relevant year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

LED Luminaire (For Road And Street Lights) (100 pieces)**Technical Specifications**

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	LED Luminaire conformity to IS:10322/Part 5/Section 3/2012 latest and IS: 16107 (Part 2/Sec 1):2012 latest	Yes	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	Types of LED Luminaire as per the IS: 16107(Part-2/ Sec.-1)/2012	Type B	*
	Types of LED Modules as per the IS:IS: 16103(Part-2)/2012	Type 3	*
	LED Rating (in Watts)/System Wattage/Rated Power	60W	60W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt	*
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66	*
	Warranty for free replacement (in years)	5	5
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz+/-2	*
	Automatic Higher Cut off voltage above 300 volt	Yes	*
	Rated voltage	230 V AC 50 Hz	*

	AC Power Factor at full load	≥ 0.95	*
	Driver Efficiency (in %age) Upto 100W: $\geq 85\%$, Above 100W: $\geq 90\%$	Yes	*
	Total Harmonics Distortion	≤ 10	*
	"The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl. 8 of IS:16104:2012 lates)"	Yes	*
OPTICAL	LED chip Efficacy	≥ 130 Lm/Watt	*
	Colour temperature	6000+/-500K	*
	Working life for LED (Minimum 50,000 burning hours as per LM-80 and LM 21 reports)	Yes	*
	Colour Rendering Index(CRI)	≥ 70	*
	LED Beam Angle	≥ 120	*
	Optic lense materal (UV stabilised)	Poly carbonate lense	*
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes	*
	Junctiojn / Soldering point temperature shall not exceed 85 deg.c as per LM 80 report	Yes	*
	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Operating temperature range	-20 deg. C to +50 deg. C	-20 deg. C to +50 deg. C
	Operating Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	Over Voltage protection	Yes	*
	Reverse polarity	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M Ohm	*
	The luminaire shall be protected against surges and transients (Internal)	≥ 4 KV	*
	The luminaire shall be protected against surges and transients of ≥ 10 KV (External)	Yes	*
CONSTRUCTIONAL	The Luminaires	Yes	*

	casing/housing (single piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity		
	The luminaire body must be corrosion resistant powder coated	Yes	*
	All fasteners must be of stainless steel	Yes	*
	Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66	*
	Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,	Yes	*
	Luminaires light transparency should be of Toughened glass	Yes	*
	Toughened transparent glass cover thickness	>=4 mm	*
	Toughened Glass shall not get discoloured shall not suffer degradation due to heat and ageing within warranty period	Yes	*
	Number of electronic control gear (power supplies)	2 Nos.	2 Nos.
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Driver components shall be industrial grade or above	Yes	*
	PCB shall be FR4 grade minimum 0.8 to 1.0 mm thick or more	Yes	*
	The Luminaires works on single phase three wires system (Phase, Neutral and Earth)	Yes	*
	Suitable connector shall be provided for LED connection between driver output and LED	Yes	*
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm	50 cm
MARKING	"Manufactures Name and and brand on the aluminium die cast body "	Engraved/Embossed	*

	Manufacturer's name, model number, serial number	Yes	*
	Date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics voltage and power be marked inside of each LED luminaire unit	Yes	*
	Diameter of pole Luminaire suitable for: (upto 45W Pole OD: shall be 40mm), (>45W<120W Pole OD: Shall be 50 mm), (above 120W: OD shall be 60 mm for which luminaire is suitable	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND	*
	System must have EMI/EMC compliance as applicable (Test reports shall be furnish to the buyer / consignee on demand)	Yes	*
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
	LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
	Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standard IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
	Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes	*

DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for road and street lighting shall comply with Compulsory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 3): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Vindhyachal	274305,NAGAR PANCHAYAT RAMKOLA DISTRICT- KUSHINAGAR	100	15

Bid Specific Additional Terms and Conditions

- 1.Upload Manufacturer authorization:** Wherever Authorised Distributors are submitting the bid, Manufacturers Authorisation Form (MAF)/Certificate with OEM details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid.
- 2.Experience Criteria:** The Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for 1 year before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the primary product having highest value should meet this criterion.
- 3.OPTION CLAUSE:** The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.
- 4.Scope of supply (Bid price to include all cost components) :** Supply Installation Testing and Commissioning of Goods
- 5.Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.**
- 6.ISO 9001:** The bidder must have ISO 9001 certification.
- 7.Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.**
- 8.The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.**
- 9.To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid): BIS CERTIFICATE TEST REPORT LOCAL SERVICE CENTER PROOF.**
- 10.Availability of Service Centres:** Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
- 11.Dedicated /toll Free Telephone No. for Service Support :** BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
- 12.Escalation Matrix For Service Support :** Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.
- 13.Timely Servicing / rectification of defects during warranty period:** After having been notified of the defects / service requirement during warranty period, Seller has to complete the required Service / Rectification within 3 days time limit. If the Seller fails to complete service / rectification with defined time limit, a penalty of 0.5% of Unit Price of the product shall be charged as penalty for each week of delay from the seller. Seller can deposit the penalty with the Buyer directly else the Buyer shall have a right to recover all such penalty amount from the

Performance Security (PBG). Cumulative Penalty cannot exceed more than 10% of the total contract value after which the Buyer shall have the right to get the service / rectification done from alternate sources at the risk and cost of the Seller besides forfeiture of PBG. Seller shall be liable to re-imburse the cost of such service / rectification to the Buyer.

14. Warranty period of the supplied products shall be 5 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid
15. Procurement under this bid is reserved for purchase from Micro and Small Enterprises from the State of Bid Inviting Authority whose credentials are validated online through Udyog Aadhaar for that product category. If the bidder wants to avail the reservation benefit, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---