

Bid Document

Bid Details	
Bid End Date/Time	25-07-2020 11:00:00
Bid Opening Date/Time	25-07-2020 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Railways
Department Name	Na
Organisation Name	N/a
Office Name	North Western Railway
Total Quantity	6
Item Category	LED Luminaire (Recessed Luminaire)
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

LED Luminaire (Recessed Luminaire) (6 pieces)**Technical Specifications**

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
STANDARDS	Conformity to Indian Standard	IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012 for Recess type	*
	Photo biological safety of LEDs used shall be as per IS:16108/2012 (exempt group)	Yes	*
	DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
	Luminaire Class (as per Cl. 2.1 Section 2 of IS: 10322 (Part-1)	Class I	*
	Types of LED Modules as per the IS: 16103(Part-2)/2012	Type 3	*
	Rating of Recess type LED Luminaire/System Wattage/Rated Power	36W	36W
	Light Intensity(System Lumens) 80 Lm/Watt for 3000 deg K, 90 Lm/Watt for 4000 deg K, 100 Lm/Watt for 6000 deg K	Yes	*
	Color temperature (+/- 500 K)	6000 deg K	*
	Type of fixture (in feet)	2x2(30W to 48W)	2x2(30W to 48W)
CONSTRUCTIONAL	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest (Minimum)	IP20	*
	Mounting type	Recess type	*
	Diffuser material	Poly carbonate (UV stabilised)	*

	The luminaire body must be corrosion resistant epoxy powder coated / anodizing	Yes	*
	All fastners must be of nickel/chrome plated	Yes	*
	Number of electronic control gear (power supplies)	1	*
	Light Source	SMD LED Chip as per LM 80/IS16106	*
	Warranty for free replacement	3 Years	*
ELECTRICAL EFFICIENCY MANAGEMENT	Operating Voltage and frequency range	140V to 280 V at 50 Hz AC	*
	Rated voltage	230 V AC 50 Hz	*
	AC Power Factor	≥ 0.90	*
	Driver Efficiency	≥ 85	*
	Total Harmonics Distortion ($\leq 20\%$ (for upto 20W) ($\leq 10\%$ (for above 20W)	Yes	*
	The total circuit power shall not be more than 110 percent of the value declared by the manufacturer (as per Cl 8 of IS:16104:2012 lates)	Yes	*
OPTICAL MANAGEMENT	LED chip Efficacy (≥ 130 Lm/Watt for 6000 deg K, ≥ 120 Lm/Watt for 4000 deg K, ≥ 110 Lm/Watt for 3000 deg K)	Yes	Yes
	Working life for LED : (Minimum 50,000 burning hours as per LM-80 report)	Yes	*
	Colour Rendering Index(CRI)	≥ 80	*
	Beam Angle	≥ 120	*
	Reflector type	Diffuser	*
THERMAL MANAGEMENT	Fixture / Luminaire should be die-cast aluminium /CRCA/Extruded aluminium	Yes	*

	Capacitor shall be rated for a temperature of 105 deg. celsius or better	Yes	*
	Junction temperature / soldering temperature	< 85 deg C	*
	Operating temperature range	-10 deg. C to +55 deg. C	*
	Humidity Range	10 % to 95% RH	*
PROTECTION	Short circuit Protection	Yes	*
	Over load protecton	Yes	*
	High voltage test (1.5 KV for one minute between supply terminals and body of the unit)	Yes	*
	Insulation resistance between earth and current carrying part	>100 M ohm	*
	The luminaire shall be protected against surges and transients of ≥ 2.5 KV	Yes	*
MARKING	Manufactures Name and brand shall available on the body of the Luminaire	Engraved/Embssed	*
	Each LED liminaire shall have the manufacturer's name, model number, serial number, date of manufacture (month-year), and lot number as identification mark inside each unit and the outside of each packaging box	Yes	*
	The operation characteristics such as rated voltage and rated power in watts shall be marked inside each LED luminaire unit	Yes	*
REPORTS AND CERTIFICATIONS	LED Make	EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / SEOUL / SAMSUNG / OSRAM / REFOND / NICHIA / CREE / LUMILEDS / PHILIPS / SYSKA /	*

	LUMENMAX	
LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government LAB /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,)	Yes	*
LM 80 & TM21(Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer on demand (LM-80 report shall have the Photo Biological report of the LED Chip being used in the luminaire)	Yes	*
Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-2/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes	*
Seller has to furnish Type test report to the buyer on demand	Yes	*
DC or AC supplied electronic control gear for LED Module shall comply as per IS:15885 (Part 2/Sec.13)	Yes	*
LED Luminaire for rcess type shall comply with Complusory Registration(CRS) of BIS for safety as per IS 10322 (Part 5/Section 2): 2012 as applicable on date	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by

Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Kishor Kumar Vishwakarma	305001,DRM OFFICE, GLO Complex, Mall Road, AJMER	6	15

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods
2. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---