

Bid Document

Bid Details	
Bid End Date/Time	13-07-2020 11:00:00
Bid Opening Date/Time	2020-07-13 11:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Pmo
Department Name	Department Of Atomic Energy
Organisation Name	Nuclear Power Corporation Of India Limited
Office Name	Kaiga Karnataka
Total Quantity	12
Item Category	Static Protective Relays
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

MSE Purchase Preference

MSE Purchase Preference	Yes
-------------------------	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to

MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

Static Protective Relays (12 pieces)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	ISI Marked	No	No
	Static protective relays conforming to	IS : 8686 (1977) Latest	*
	If ISI Marked "Yes" CM/L Number must declare. If "No" write NA	-	*
	Type	Static Relay with Output Contacts	Static Relay with Output Contacts
	Impulse voltage withstand test class	Class II	Class II
	High Frequency Disturbance test class	Class II	*
	Rated Voltage, DC (in Volt)	24,48,110,125,220,250	24, 48, 110, 125, 220, 250
	Rated Voltage, AC (in Volt)	110,220,415	110, 220, 415
	Rated continuous current, AC (in A)	1,2,5,8,10	1, 2, 5, 8, 10
	Rated continuous current, DC (in A)	1,2,5,8,10	1, 2, 5, 8, 10
	Rated insulation voltage (in Volt)	1000	1000
	Frequency of operation (n Cycles per hour)	72000	72000

	Dielectirc volatge series as per Table 1 of IS : 12083 (Part 2) - 1986	Series B	Series B
	Duty Level for AC and DC	Level II	Level II
CONSTRUCTION	Enclosure type	Wall mounted facility	*
	Enclosure Material	Flame retardant polycarbonate	*
	Degree of protecction for enclosure (IP rating)	IP50	IP50
	Operating temperature	0 C to 60 Degree C	*
	Marking on Relay	as per Cl. 8 of IS : 12083 (Part 2) - 1986	*
CERTIFICATION	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Test report number - Must declare	-	*
	Test Report date - Must declare	-	*
	Name of lab - Must declare	-	*
	Address of lab - Must declare	-	*
	All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Praveen Kumar Lagudu	581400,Plant Site, Kaiga Generating Station, PO: Kaiga	12	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods
2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---