

Bid Document

Bid Details	
Bid End Date/Time	18-07-2020 18:00:00
Bid Opening Date/Time	18-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Shipping
Department Name	Na
Organisation Name	Kandla Port Trust
Office Name	Deendayal Port Trust, Post Box No. 50, Administrative Building, Gandhidham, Kutch, Gujarat 370201
Total Quantity	10
Item Category	Line Intractive UPS with AVR
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Line Intractive UPS With AVR (10 pieces)

Technical Specifications

* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Rating in KVA/ min VAH capacity of battery (KVA/VAH)	0.6/84	0.6/84
	Technology	MOSFET-PWM	MOSFET-PWM
	Type of battery	SMF-VRLA confirming to JISC-8702 Pt 1,2 &3	SMF-VRLA confirming to JISC-8702 Pt 1,2 &3
	Rated Output (Volt)	Single Phase Quasi-Sin-wave 230 V AC, 50 Hz	Single Phase Quasi-Sin-wave 230 V AC, 50 Hz
	Degree of protection	IP 20	IP 20
	Inverter Efficiency (%)	> / = 60%	> / = 60%
	Warranty for the battery from the date of delivery	1 year	1 year
	Warranty for Line Interactive UPS	2 Years	2 Years
	Installation and commissioning instructions	No	*
CONSTRUCTIONAL	Type of enclosure	ABS	*
	AC out put for printer (not through inverter)	No	No
	Inverter out put socket AC out put for printer (not through inverter)	Not applicable	Not applicable
FUNCTIONAL	Total harmonic distortion (%)	< / = 40%	*
	Input (Volt)	Single phase sinewave(160-280v)	*
	Switching over time (Mili sec)	Maximum 10 milli seconds	*
	Overload Time (Minutes)	> / = 5 minutes	> / = 5 minutes
	Load power factor	> / = 0.6	> / = 0.6
	Variation in AVR output in AC mode (%) AVR (Voltage regulation) output voltage in AC Mode	230 Volts +/-9%, 50 +/-3 Hz	230 Volts +/-9%, 50 +/-3 Hz
	Overload (%)	> / = 10%	*

	Variation in output voltage in battery mode (%) (UPS output voltage in battery mode)	230 Volts +/- 10%	*
	Variation on output frequency in battery mode (Hz)	</=0.5	*
PROTECTION	Protection against (over discharge) discharge per 12v battery (Volt)	10.5	*
	Protection for outside input voltage range: If Input voltage goes outside the range 160 to 280 Volts, the system shall switch over to battery mode	Yes	*
	Protection against short circuit of UPS	Yes	*
	Protection for over voltage and over load	Yes	*
REPORTS AND CERTIFICATIONS	Damp heat Test at 45 degree , RH -95% for 2-cycle as per IS:9000 pt-5/sec-1	Yes	*
	Dry heat Test at 45 degree for 16 Hrs as per IS:9000 pt-3/sec-5	Yes	*
	Cold Test as per IS:9000 pt-2/sec-4	Yes	*
	Availability of the type test report from central Govt./NABL/ILAC Accredited Lab	Yes	*
	Type Test certificate no. and date	-	*
	Name Of Lab	-	*
	Address of Lab	-	*
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Manohar Devaram Dana	370201,A O Building, Store Section, Finance Department, Gandhidham Kachchh Gujarat 370201	10	30

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---