

### Bid Document

Bid Details	
Bid End Date/Time	23-07-2020 17:00:00
Bid Opening Date/Time	23-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Power
Department Name	Na
Organisation Name	N/a
Office Name	Bhakra Beas Management Board, Chandigarh
Total Quantity	10
Item Category	Switch Fuse Unit
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Inspection Required	No

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

### Switch Fuse Unit ( 10 pieces )

### Technical Specifications

\* As per GeM Category Specification

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Conformity to the specification	as per IS/IEC:60947-3:1999 latest	*
	<b>Whether product ISI Marked (Select 2 for ISI Marked product, Select 1 for Non ISI Marked product)</b>	1	2, 1 Or higher
	BIS License Number (CM/L Number) - Must declare (If Non ISI Marked write N/A)	-	*
	<b>Switch Fue Unit contains</b>	Enclosure with door, Fuse units- Rewirable, Terminals, Contactors, Operating handle	Enclosure with door, Fuse units- Rewirable, Terminals, Contactors, Operating handle
	<b>Utilisation category</b>	AC-22A	AC-22A
	<b>Warranty (in Years)</b>	2	2
RATINGS	<b>Rated operational Voltage (in Volt)</b>	240	415, 240
	<b>Rated frequency (in Hz)</b>	50	50
	<b>Number of Pole</b>	3 Pole and Neutral	3 Pole and Neutral
	<b>Current rating (in Ampere)</b>	63	63
	<b>Rated Insulation voltage (in Volt)</b>	440	440
	<b>Rated impulse withstand voltage (in KV)</b>	3	3
	<b>Rated short circuit breaking capacity, Minimum (in KA, r.m.s.)</b>	3	3
CONSTRUCTION	Type of enclosure	Surface Mounted	*
	Material of enclosure	CRCA Sheet, 2 mm thick	*
	Knock-outs at enclosure cable entry	Top and bottom	*
	Mounting holes for fixing the enclosure	Yes	*
	Door interlocking facility	Yes	*

	<b>Degree of protection</b>	IP54	IP54
	<b>Mechanical Endurance, Minimum (in No.of cycles)</b>	10000	10000
	<b>Fixing accessories for mounting of enclosures</b>	No	No
FUSE UNIT	Type of fuse	Rewirable Porcelain Fuse units	*
	Material of terminals	Silver Plated	*
	Material of contactors	Electrolytic copper	*
CERTIFICATIONS	Availability of Type test report from Central Government/NABL/ILAC accredited laboratory to prove conformity to the specification	Yes	*
	Test report number and date - Must declare	-	*
	Name of lab and address - Must declare	-	*
	Agreed to furnish all the test reports and certificates to the buyer/consignee on demand	Yes	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

### Additional Specification Documents

### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Hitender Singh	175019,Superintend Procurement Store & Disposal Division, Bhakra Beas Management Board, SUNDER NAGAR	10	15

### Bid Specific Additional Terms and Conditions

1. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having

Functional Service Centre.

2. Bidder Turn Over Criteria: The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**