

### Bid Document

Bid Details	
Bid End Date/Time	23-07-2020 18:00:00
Bid Opening Date/Time	23-07-2020 18:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Madhya Pradesh
Department Name	General Administration Department Madhya Pradesh
Organisation Name	N/a
Office Name	Dm Ujjain
Total Quantity	3
Item Category	Online UPS
Bidder Turnover (Last 3 Years)	2 Lakh (s)
Experience Criteria	2 Year (s)
MSE Exemption for Years Of Experience and Turnover	Yes
Startup Exemption for Turnover	Yes
Document required from seller	Experience Criteria,Bidder Turnover,OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Inspection Required	No

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of years as indicated in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

## Online UPS ( 3 pieces )

### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
Generic	<b>Rating in KVA (KVA)</b>	3.0 KVA	*
	<b>Technology</b>	IGBT-PWM with inbuilt isolation transformer	MOSFET-PWM with inbuilt isolation transformer, IGBT-PWM with inbuilt isolation transformer, IGBT-PWM without inbuilt isolation transformer
	<b>Input Power</b>	single phase 160V - 260V sinewave,50Hz	single phase 160V - 260V sinewave,50Hz, Three phase 300 V - 450V sinewave,50Hz
	<b>Output power</b>	Single phase 230V +/-1% sinewave 50 Hz	Single phase 230V +/-1% sinewave 50 Hz, 3 Phase 400V +/-1% with alternative user settable setting of 380V +/-1% 50 Hz
	<b>Backup time (Minutes)</b>	180	15, 30, 60, 90, 120, 180, 240, NA
	<b>Minimum VAH (VAH)</b>	14400	0 - 640000
	<b>Warranty for UPS (Years)</b>	2	1, 2, 3, 4, 5
	<b>Movable trolley for Batteries</b>	Without trolley but with rack	With, Without, Without trolley but with rack
	<b>Warranty for battery</b>	2	1, 2, NA
	<b>Degree of Protection</b>	IP20	IP21, IP20
	<b>Cabling 5 meters for input and out put</b>	Without	With, Without
	<b>Paralleling kit for</b>	With	With, Without

	<b>synchronising</b>		
	Installation and Commissioning	Yes	*
Constructional	Minimum thickness of M.S.Sheet Enclosure duly painted (mm)	1.2	*
	<b>Type of Battery</b>	SMF-VRLA conforming to JISC:8702(Pt.I,II&III)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest, Stationary Cells and Batteries, Lead Acid type, (with tubular positive plates) conforming to IS:1651:1991 latest, NA, Lithium ion
Functional	Maximum overshoot and Under shoot of output rated voltage	4	*
	Voltage Regulation from no load to full load (%)	< / = 3%	*
	<b>20% Overload limit for minimum 10 minutes</b>	Yes	Yes, No, only for 5 Minutes
	<b>Overall Efficiency (%)</b>	> /=90%	> /=90%, > /=92%, > /=94%, > /=96%
	Total Harmonic Distortion(THD) (%)	Maximum 3%	*
	<b>50% Overload limit for minimum 1 minutes</b>	Yes	Yes, No, only for 3 seconds
Protection	Protection for under voltage at battery terminal at 10.5V per 12 V battery	Yes	*
	Protection of Over voltage,Short Circuit & over load at UPS output terminal	Yes	*
Metering And Indications	Digital Metering in UPS for AC Input Voltage,Output AC Voltage,Current,Frequency, Battery Voltage and Current	Yes	*

	Indicators for mains presence,Battery charging and discharging,Output Over Load, Low Battery Voltage	Yes	*
Reports And Certification	Damp Heat : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	Yes	*
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes	*
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes	*
	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes	*

\* Specifications highlighted in bold are the Golden Parameters.

\* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement ( allowed Values) by the Buyer.

#### Additional Specification Documents

**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Bindu Dodiya	456010,Brahaspati Bhavan Kothi Palace ujjain	3	15

**Special terms and conditions for category Online UPS**

1. Calculation of Minimum VAH based on Back up time Minimum VAH requirements would be calculated on the basis of following: (VAH Calculation: Battery Voltage x Battery Ah x No. of Batteries = VAH)UPS Rating15 Minutes30 Minutes60 Minutes90 Minutes120 Minutes180 Minutes240 Minutes1 KVA400 VAH800 VAH1600 VAH2400 VAH3200 VAH4800 VAH6400 VAH2 KVA800 VAH1600 VAH3200 VAH4800 VAH6400 VAH9600 VAH12800 VAH3 KVA1200 VAH2400 VAH4800 VAH7200VAH9600 VAH14400 VAH19200 VAH5 KVA2000 VAH4000 VAH8000 VAH12000 VAH16000 VAH24000 VAH32000 VAH6 KVA2400 VAH4800 VAH9600 VAH14400 VAH19200 VAH28800 VAH38400 VAH7.5 KVA3000 VAH6000 VAH12000 VAH18000 VAH24000 VAH36000 VAH48000 VAH10 KVA4000 VAH8000 VAH16000 VAH24000 VAH32000 VAH48000 VAH64000 VAH15 KVA6000 VAH12000 VAH24000 VAH36000 VAH48000 VAH72000 VAH96000 VAH20 KVA8000 VAH16000 VAH32000 VAH48000 VAH64000 VAH96000 VAH128000 VAH30 KVA12000 VAH24000 VAH48000 VAH72000 VAH96000 VAH144000 VAH192000 VAH40 KVA16000 VAH32000 VAH64000 VAH96000 VAH128000 VAH192000 VAH256000 VAH60 KVA24000 VAH48000 VAH96000 VAH144000 VAH192000 VAH288000 VAH384000 VAH80 KVA32000 VAH64000 VAH128000 VAH192000 VAH256000 VAH384000 VAH512000 VAH100 KVA40000 VAH80000 VAH160000 VAH240000 VAH320000 VAH480000 VAH640000 VAH

**Bid Specific Additional Terms and Conditions**

1. Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.
2. Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.
3. Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

[This Bid is also governed by the General Terms and Conditions](#)

**---Thank You---**