

Bid Document

Bid Details	
Bid End Date/Time	22-07-2020 17:00:00
Bid Opening Date/Time	22-07-2020 17:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	75 (Days)
Ministry/State Name	Ministry Of Defence
Department Name	Department Of Defence Production
Organisation Name	Indian Ordnance Factories
Office Name	*****
Total Quantity	1000
Item Category	non modular electrical switches and accessories flush type
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	Yes
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

Non Modular Electrical Switches And Accessories Flush Type (1000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Electrical Accessory for domestic && similar purpose	ISI Marked, 6 A, 1 Way Piano type Switch to IS:3854/1997 with latest amendments	ISI Marked,16A, 1 Way Piono type Switch to IS:3854/1997 with latest amendments, ISI Marked, 6 A, 1 Way Piano type Switch to IS:3854/1997 with latest amendments
	Product ISI Marked	Yes	Yes
	Valid BIS License Number	-	*
CONSTRUCTIONAL	Shutter with socket	With	*
	Current carrying part must be of Brass, Copper, or any other superior material	Yes	*
	Type of Accessories	Flush Type	*
	Body material	Polycarbonate Electrical Grade	*
	Color as seen from front (Matching with other accessories)	White	*
	Accessories shall be provided with fixing screw with each set of packing	Yes	*
	Mechanical Strength of Coaxial Antina Socket, Telephone Jack and Indicator as per IS:3854	Yes	*
FUNCTIONAL	Rated Voltage (Volt)	250 vOLT	*
	Resistance to Abnormal Heat and Fire of Coaxial Antina Socket, Telephone Jack and Indicator as per IS:3854	Yes	*
CERTIFICATIONS	Availability of complete and satisfactory type test Report from Central govt/ NABL/ ILAC accredited laboratory to prove conformity to the specification	Yes	*

Name of lab where test conducted	-	*
Test certificate number	-	*
Test report date	-	*
Test report to be submitted to the Buyer on Demand	Yes	*
Marking of manufacturer name /Trade mark on accessories	Yes	*
OEM Product Series	-	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	*****	*****BHANDARA	1000	60

Bid Specific Additional Terms and Conditions

1. Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---